

PORT WELLER, ON, Canada

WMO: 714320

Lat: 43.245N

Lon: 79.218W

Elev: 79

StdP: 100.38

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.3	-11.1	-17.0	0.9	-12.0	-15.0	1.0	-10.0	16.5	-4.0	15.7	-4.2	6.5	250	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.6	29.4	22.6	27.8	22.0	26.5	21.4	24.2	27.2	23.3	26.1	22.4	25.2	3.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.4	18.4	26.2	22.4	17.3	25.1	21.4	16.2	24.2	73.7	27.1	69.7	26.1	66.2	25.2	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.7	11.1	-14.9	31.8	2.7	1.7	-16.9	33.1	-18.5	34.1	-20.1	35.1	-22.0	36.3		
(5)			-15.5	25.4	3.0	1.4	-17.7	26.4	-19.5	27.3	-21.1	28.1	-23.3	29.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	-2.7	-2.0	1.5	6.7	12.6	18.5	22.2	22.0	18.7	12.2	5.9	1.0	(6)	
	DBStd	9.65	5.11	4.56	4.32	3.73	3.93	3.52	2.70	2.53	3.33	3.96	3.92	4.24	(7)	
	HDD10.0	1561	394	337	265	113	16	0	0	0	0	22	133	281	(8)	
	HDD18.3	3467	652	571	523	349	185	41	2	2	36	195	374	539	(9)	
	CDD10.0	1474	1	0	1	13	95	256	377	372	260	89	9	1	(10)	
	CDD18.3	338	0	0	0	0	7	47	120	116	45	4	0	0	(11)	
	CDH23.3	1471	0	0	0	1	32	203	582	482	161	9	0	0	(12)	
	CDH26.7	274	0	0	0	0	3	40	124	80	27	0	0	0	(13)	
(14) Wind	WSAvg	4.6	6.1	5.7	5.5	5.0	3.7	3.2	3.0	3.2	4.0	4.9	5.4	5.8	(14)	
(15) Precipitation	PrecAvg	853	68	55	60	77	75	75	79	76	83	78	69	71	(15)	
	PrecMax	1105	116	120	106	130	160	178	188	140	190	174	122	156	(16)	
	PrecMin	682	37	24	19	34	20	20	18	32	38	28	27	29	(17)	
	PrecStd	121	24	22	25	28	38	39	41	27	35	36	23	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	12.4	15.6	20.8	26.5	30.0	31.8	31.3	29.6	24.7	18.0	14.0	(19)	
		MCWB	11.3	8.7	10.7	14.9	19.0	22.1	24.2	24.4	22.5	19.0	13.3	11.7	(20)	
	2%	DB	8.7	8.2	12.6	17.4	23.6	27.7	29.6	28.6	26.9	22.0	15.8	10.4	(21)	
		MCWB	6.9	5.6	9.2	12.2	17.7	21.2	22.8	22.6	21.7	17.5	12.7	8.5	(22)	
	5%	DB	5.9	5.3	9.7	14.7	21.2	25.6	27.9	27.2	25.1	19.8	13.6	8.1	(23)	
		MCWB	4.3	3.3	6.9	10.5	16.2	20.2	22.0	22.0	20.9	16.0	10.8	6.6	(24)	
	10%	DB	3.5	3.3	6.7	12.0	18.7	23.8	26.4	25.9	23.5	17.8	11.5	6.2	(25)	
		MCWB	2.3	1.7	4.7	8.7	14.9	19.5	21.5	21.5	20.1	15.0	9.2	4.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.8	9.6	12.0	15.9	20.2	23.7	25.8	25.5	23.9	20.8	15.3	11.9	(27)	
		MCDB	12.4	11.4	15.0	18.7	24.7	26.8	30.1	29.0	27.2	23.7	17.1	13.9	(28)	
	2%	WB	7.2	6.3	9.4	13.1	18.4	22.2	24.4	24.3	22.8	18.2	13.0	8.8	(29)	
		MCDB	8.4	8.4	11.8	16.3	22.8	25.8	27.6	27.0	25.5	21.2	15.1	10.2	(30)	
	5%	WB	4.3	3.7	7.1	11.0	17.0	21.1	23.4	23.2	21.7	16.6	11.0	6.8	(31)	
		MCDB	5.7	5.3	9.5	14.1	20.7	24.7	26.3	25.9	24.2	18.9	13.4	8.0	(32)	
	10%	WB	2.5	2.0	4.9	8.7	15.4	19.9	22.3	22.2	20.7	15.5	9.4	5.0	(33)	
		MCDB	3.6	3.2	6.7	11.5	18.4	23.1	25.2	24.9	23.1	17.7	11.5	6.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	5.5	5.7	6.4	7.3	6.9	6.6	6.1	6.0	5.6	5.0	4.5	(35)	
		MCDBR	7.9	8.7	10.0	11.8	11.4	9.6	8.6	7.9	8.3	8.5	8.4	7.1	(36)	
	5% WB	MCWBR	7.1	7.3	7.3	7.6	6.5	5.2	4.3	4.1	4.5	5.3	6.3	6.0	(37)	
		MCWBR	7.4	8.8	9.8	11.3	10.8	9.0	7.6	6.9	7.0	7.3	7.9	7.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.300	0.327	0.341	0.383	0.413	0.443	0.440	0.425	0.390	0.368	0.319	0.304	(40)	
		taud	2.429	2.343	2.388	2.307	2.272	2.224	2.254	2.285	2.360	2.391	2.496	2.461	(41)	
	Ebn at Noon		836	864	899	882	861	834	831	832	836	806	807	796	(42)	
		Edh at Noon	75	97	105	123	132	139	133	125	108	92	71	67	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.35	2.12	3.34	4.42	5.41	5.86	5.89	5.21	4.16	2.51	1.56	1.09	(44)	
	RadStd		0.12	0.19	0.35	0.47	0.57	0.43	0.45	0.27	0.37	0.23	0.21	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page