

DAWSON CREEK, BC, Canada

WMO: 714710

Lat: 55.7388N

Lon: 120.1869W

Elev: 655

StdP: 93.70

Time Zone: -7.00 (W07)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-34.6	-30.5	-39.0	0.1	-34.5	-34.9	0.2	-30.5	12.7	2.9	11.2	2.5	0.7	270	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	27.9	16.4	26.1	15.6	24.3	14.8	17.7	25.1	16.7	23.9	15.8	22.5	3.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	11.5	19.9	13.9	10.7	19.0	12.9	10.0	18.2	52.3	25.1	49.2	24.1	46.4	22.4	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.5	8.3	-37.8	31.2	3.4	1.9	-40.3	32.6	-42.3	33.7	-44.2	34.8	-46.7	36.2		
(5)			-37.2	20.1	4.1	1.2	-40.2	21.0	-42.6	21.7	-44.9	22.4	-47.9	23.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.4	-10.1	-10.5	-5.6	3.1	10.1	14.0	16.4	14.9	10.5	3.7	-6.7	-11.8	(6)
(7)		DBStd	12.26	9.97	9.26	8.30	5.16	4.15	2.97	2.49	3.38	4.40	4.99	8.32	9.00	(7)
(8)		HDD10.0	3372	623	575	484	210	49	4	0	3	46	201	500	677	(8)
(9)		HDD18.3	5834	881	808	742	457	256	132	69	114	234	454	750	936	(9)
(10)		CDD10.0	601	0	0	0	3	53	125	199	155	62	5	0	0	(10)
(11)		CDD18.3	21	0	0	0	0	0	3	10	8	1	0	0	0	(11)
(12)		CDH23.3	599	0	0	0	2	31	88	247	180	51	2	0	0	(12)
(13)		CDH26.7	122	0	0	0	0	2	12	61	39	8	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.0	2.6	2.9	3.6	3.6	3.5	3.3	3.1	3.3	3.4	2.9	2.7	(14)
(15)	Precipitation	PrecAvg	493	28	22	22	19	39	82	80	66	52	30	25	29	(15)
(16)		PrecMax	628	92	75	50	42	120	179	180	163	125	80	57	115	(16)
(17)		PrecMin	310	10	4	3	4	3	28	18	9	4	11	2	0	(17)
(18)		PrecStd	88	20	17	12	12	27	47	49	39	34	17	14	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.4	8.6	12.8	20.1	26.5	28.2	31.3	30.2	27.7	20.0	10.1	7.2	(19)
(20)			MCWB	3.8	4.0	6.8	10.3	13.5	17.1	17.7	17.0	14.9	10.8	5.5	2.9	(20)
(21)		2%	DB	7.0	6.1	8.7	16.2	23.7	25.7	28.1	27.4	24.5	16.2	7.3	5.1	(21)
(22)			MCWB	3.5	2.4	4.0	8.2	12.4	15.1	16.7	16.4	14.5	9.2	3.6	1.6	(22)
(23)		5%	DB	5.5	4.6	6.7	13.2	21.4	23.9	26.0	25.2	21.6	13.5	5.6	3.1	(23)
(24)			MCWB	2.5	1.4	2.7	6.0	11.3	14.2	16.2	15.6	13.3	7.7	2.4	0.2	(24)
(25)		10%	DB	3.9	2.9	5.1	11.1	19.0	21.8	24.0	23.2	18.9	11.5	4.1	1.4	(25)
(26)			MCWB	1.1	0.1	1.5	4.7	10.1	13.3	15.4	14.6	11.8	6.5	1.2	-1.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	4.5	7.0	10.9	14.8	18.1	19.6	18.6	17.0	12.1	6.4	3.5	(27)
(28)			MCDB	7.7	8.0	11.7	20.0	24.1	26.1	27.0	26.6	25.2	18.9	9.2	6.8	(28)
(29)		2%	WB	3.5	2.7	4.3	8.3	13.1	16.4	18.0	17.2	15.1	9.7	4.1	1.9	(29)
(30)			MCDB	6.6	5.8	8.1	15.5	21.4	23.7	25.2	25.2	22.7	14.9	6.8	4.8	(30)
(31)		5%	WB	2.5	1.5	3.0	6.4	11.9	15.1	17.0	16.2	13.7	8.2	2.6	0.3	(31)
(32)			MCDB	5.5	4.3	6.3	12.3	19.9	21.6	23.9	23.4	20.5	12.8	5.3	3.0	(32)
(33)		10%	WB	1.3	0.3	1.8	5.2	10.8	14.1	16.1	15.3	12.4	6.7	1.4	-1.3	(33)
(34)			MCDB	3.8	2.9	4.9	10.4	17.9	20.1	22.6	21.8	18.2	10.9	3.9	1.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.9	10.6	10.8	10.9	13.3	12.4	12.7	13.3	12.4	9.9	9.4	9.7	(35)
(36)			MCDBR	9.5	11.0	11.4	15.8	18.2	17.0	18.2	18.1	17.8	14.4	10.1	11.1	(36)
(37)			MCWBR	7.1	8.1	7.8	9.2	8.9	8.1	8.6	8.8	9.0	8.6	7.4	8.9	(37)
(38)		5% WB	MCDBR	9.1	11.0	11.0	14.8	16.3	14.5	15.9	16.0	16.7	13.6	10.0	11.0	(38)
(39)			MCWBR	7.0	8.4	7.8	8.9	8.3	7.5	8.3	8.2	8.9	8.4	7.6	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.237	0.250	0.286	0.325	0.351	0.348	0.349	0.347	0.311	0.286	0.244	0.226	(40)	
(41)		taud	2.329	2.382	2.347	2.387	2.382	2.404	2.436	2.437	2.538	2.562	2.426	2.265	(41)	
(42)		Ebn at Noon	720	853	892	899	890	895	887	866	860	804	713	635	(42)	
(43)		Edh at Noon	49	68	91	103	110	109	104	97	76	58	44	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.69	1.60	3.02	4.62	5.47	6.00	5.84	4.76	3.24	1.73	0.78	0.50	(44)	
(45)		RadStd	0.07	0.13	0.22	0.24	0.38	0.54	0.37	0.42	0.30	0.19	0.07	0.04	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+58	N/A

Nomenclature: See separate page