

KINDAKUN ROCKS, BC, Canada

WMO: 714720

Lat: 53.316N

Lon: 132.772W

Elev: 16

StdP: 101.13

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.4	-0.6	-12.8	1.2	-1.7	-9.6	1.7	0.3	21.2	6.8	19.5	6.9	5.6	90	0.807

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.3	16.8	14.2	15.9	14.1	15.3	13.8	15.2	16.2	14.7	15.5	14.3	15.1	4.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.8	10.5	15.6	14.4	10.2	15.2	13.9	9.9	14.7	42.8	16.3	41.3	15.7	40.1	15.3	17.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.3	16.8	14.7	DB	-4.0	19.9	2.7	3.2	-5.9	22.2	-7.4	24.0	-8.9	25.8	-10.9	28.1	(4)
(5)			WB	-6.1	16.2	2.7	0.6	-8.1	16.6	-9.7	17.0	-11.2	17.3	-13.2	17.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	5.9	5.3	5.4	6.9	8.7	10.7	12.6	13.7	13.0	10.4	7.4	5.7
	DBStd	3.63	2.65	2.41	2.26	1.95	1.84	1.48	1.33	1.22	1.40	1.71	2.48	2.61
	HDD10.0	788	129	133	142	98	49	7	0	0	0	16	81	133
	HDD18.3	3469	387	366	400	344	299	228	178	144	159	246	327	391
	CDD10.0	361	1	0	1	3	8	29	81	114	91	28	4	1
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	3	0	0	0	0	3	0	0	0	0	0	0	0
	CDH26.7	1	0	0	0	0	1	0	0	0	0	0	0	0
Wind	WSAvg	6.6	7.3	7.0	7.1	6.7	6.2	5.8	5.7	5.4	6.1	7.2	7.5	7.7
Precipitation	PrecAvg	1682	182	138	125	114	79	65	65	87	130	225	220	228
	PrecMax	2103	280	236	193	200	186	121	192	192	266	409	426	500
	PrecMin	1357	86	61	59	66	20	30	10	38	26	104	146	91
	PrecStd	200	46	55	35	32	41	25	40	39	51	79	59	91
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	11.1	12.2	15.7	17.6	17.2	16.7	18.1	18.1	15.1	13.2	11.7
		MCWB	9.2	8.2	8.6	8.6	10.4	13.1	14.3	15.7	14.5	13.5	10.5	9.4
	2%	DB	10.4	9.9	9.9	11.7	12.6	14.4	15.6	16.9	16.2	14.0	12.1	10.4
		MCWB	8.9	8.1	8.1	8.3	9.8	12.6	13.9	15.0	14.2	12.4	10.5	8.8
	5%	DB	9.6	9.0	9.1	9.8	11.2	13.3	14.9	16.1	15.5	13.3	11.3	9.5
		MCWB	8.3	7.5	7.4	8.0	9.2	11.9	13.6	14.5	13.9	11.7	10.0	8.2
	10%	DB	8.8	8.2	8.2	9.0	10.5	12.6	14.4	15.5	15.0	12.7	10.6	8.8
		MCWB	7.7	6.7	6.7	7.4	8.7	11.3	13.3	14.1	13.5	11.1	9.3	7.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	9.8	9.8	10.3	11.5	14.4	15.2	16.4	15.7	14.5	11.7	10.5
		MCDB	11.6	10.3	11.0	12.0	13.4	16.4	15.8	17.5	16.9	14.8	12.0	11.2
	2%	WB	9.7	8.8	8.8	9.1	10.6	13.4	14.7	15.6	15.0	13.2	11.0	9.3
		MCDB	10.4	9.6	9.9	10.3	11.8	14.8	15.3	16.7	15.7	13.9	11.6	10.1
	5%	WB	9.0	7.9	8.0	8.3	10.1	12.5	14.2	15.0	14.5	12.4	10.4	8.6
		MCDB	9.7	8.9	9.1	9.4	11.1	13.5	14.9	15.9	15.2	13.1	11.2	9.5
	10%	WB	8.3	7.1	7.3	7.7	9.7	11.9	13.8	14.5	14.0	11.8	9.7	8.0
		MCDB	9.0	8.1	8.4	8.9	10.6	12.7	14.6	15.3	14.8	12.6	10.7	9.1
Mean Daily Temperature Range	5% DB	MDBR	2.8	2.9	3.1	3.2	2.7	2.3	2.0	2.3	2.6	2.7	3.0	2.9
		MCDBR	3.3	3.3	4.0	4.9	4.5	3.5	2.9	3.2	3.2	3.1	3.2	3.3
		MCWBR	2.7	2.9	3.0	2.7	2.5	2.4	2.1	2.3	2.4	2.8	2.9	3.0
	5% WB	MCDBR	3.1	2.9	3.7	3.4	3.1	3.3	2.7	3.0	2.6	2.5	2.8	3.1
		MCWBR	2.8	3.0	3.0	2.6	2.3	2.3	2.1	2.5	2.3	2.8	3.0	3.1
Clear-Sky Solar Irradiance	taub	0.322	0.325	0.353	0.390	0.390	0.378	0.381	0.380	0.371	0.355	0.325	0.310	
	taud	2.344	2.457	2.383	2.270	2.335	2.422	2.463	2.474	2.454	2.387	2.335	2.309	
	Ebn at Noon	646	786	831	839	859	873	864	844	804	727	630	578	
	Edh at Noon	59	72	94	119	117	109	103	97	87	76	59	51	
All-Sky Solar Radiation	RadAvg	0.57	1.38	2.47	3.85	4.64	4.85	4.50	3.81	2.78	1.55	0.76	0.46	
	RadStd	0.06	0.21	0.27	0.17	0.30	0.37	0.38	0.31	0.25	0.17	0.08	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page