

CLINTON, BC, Canada

WMO: 714740

Lat: 51.1447N

Lon: 121.5049W

Elev: 3467

StdP: 12.95

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.5	-6.5	-22.4	1.8	-11.2	-15.2	2.7	-2.5	15.3	24.4	13.6	25.7	2.5	350	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.0	84.7	58.3	80.8	57.1	77.1	55.9	59.9	79.6	58.4	77.0	56.9	74.0	6.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.4	68.9	61.1	51.3	63.9	59.9	49.5	59.6	59.0	27.9	79.5	26.7	77.2	25.7	74.2	65.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.3	11.0	DB	-22.1	90.2	7.3	2.8	-27.4	92.2	-31.6	93.9	-35.7	95.5	-41.0	97.5	(4)
(5)			WB	-22.1	62.6	7.3	1.9	-27.4	64.0	-31.7	65.1	-35.8	66.1	-41.1	67.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	39.7	20.1	23.1	31.6	39.5	48.3	54.3	60.7	59.7	51.2	39.1	27.8	19.8	(6)
(7)		DBStd	16.77	12.40	10.09	8.61	6.26	6.94	5.98	6.29	6.18	7.17	6.85	9.72	10.85	(7)
(8)		HDD50	4735	928	754	571	318	117	22	3	4	71	343	667	937	(8)
(9)		HDD65	9294	1393	1174	1036	764	518	325	163	183	417	803	1116	1402	(9)
(10)		CDD50	974	0	0	0	5	64	152	336	306	106	5	0	0	(10)
(11)		CDD65	58	0	0	0	0	0	5	31	20	2	0	0	0	(11)
(12)		CDH74	1492	0	0	0	1	45	158	651	544	93	0	0	0	(12)
(13)		CDH80	398	0	0	0	0	4	35	195	150	14	0	0	0	(13)
(14)	Wind	WSAvg	4.7	4.2	4.5	5.3	5.4	5.0	4.8	4.6	4.5	4.4	4.9	4.7	4.3	(14)
(15)	Precipitation	PrecAvg	15.9	1.2	0.7	0.9	0.9	1.8	2.1	1.9	1.6	1.5	1.1	1.3	1.3	(15)
(16)		PrecMax	21.0	1.9	1.5	1.5	1.6	3.4	4.6	4.0	4.6	3.0	3.2	2.4	2.2	(16)
(17)		PrecMin	9.8	0.5	0.3	0.3	0.3	0.5	0.7	0.6	0.5	0.3	0.4	0.4	0.6	(17)
(18)		PrecStd	3.0	0.4	0.3	0.3	0.4	0.9	0.9	1.1	1.0	0.8	0.6	0.5	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	45.2	56.3	68.5	79.0	84.5	89.9	88.6	82.0	64.2	50.4	40.8	(19)
(20)			MCWB	36.5	37.0	42.1	49.2	53.6	57.3	60.4	59.2	56.8	50.2	42.9	36.1	(20)
(21)		2%	DB	38.3	40.7	50.0	62.0	73.4	78.8	85.4	84.3	76.3	57.3	45.4	36.9	(21)
(22)			MCWB	34.5	34.0	39.3	45.8	52.0	56.0	59.0	58.0	55.1	46.5	40.1	33.5	(22)
(23)		5%	DB	35.0	37.8	46.3	56.6	68.4	73.2	81.2	80.4	71.1	53.4	41.7	34.1	(23)
(24)			MCWB	32.3	32.6	37.5	43.0	50.1	53.6	57.6	57.2	53.4	44.4	37.8	31.5	(24)
(25)		10%	DB	32.4	35.0	43.0	52.4	63.6	68.8	77.0	76.0	65.6	49.7	38.8	31.6	(25)
(26)			MCWB	30.7	31.1	35.1	40.8	48.5	52.2	56.4	55.9	51.5	42.4	35.8	29.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.4	38.1	43.1	49.9	55.9	59.4	62.4	61.7	58.4	51.2	44.1	36.9	(27)
(28)			MCD B	40.5	44.3	54.1	65.6	73.7	78.4	83.8	81.4	75.8	61.5	48.3	38.9	(28)
(29)		2%	WB	34.8	35.1	40.1	47.0	53.2	57.0	60.4	59.6	56.2	48.3	41.1	34.0	(29)
(30)			MCD B	37.6	39.3	48.5	59.8	69.1	74.1	80.0	79.8	72.8	55.5	44.2	36.3	(30)
(31)		5%	WB	32.6	33.2	38.0	44.0	51.3	55.1	58.8	57.9	54.3	45.5	38.5	31.9	(31)
(32)			MCD B	34.5	36.9	45.2	55.1	65.9	70.1	77.7	77.0	69.0	51.9	41.3	33.9	(32)
(33)		10%	WB	30.9	31.4	36.0	41.5	49.4	53.4	57.3	56.4	52.2	43.1	36.1	29.7	(33)
(34)			MCD B	32.4	34.6	42.2	50.8	61.7	66.3	74.2	73.8	64.5	48.9	38.4	31.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.9	15.5	18.2	21.8	23.8	23.6	26.0	27.0	24.1	17.5	11.2	9.8	(35)
(36)			MCDBR	12.2	16.5	20.7	28.7	32.8	32.6	33.8	35.1	33.4	23.1	13.6	11.3	(36)
(37)			MCWBR	9.3	11.4	12.5	16.0	15.7	14.9	14.3	15.2	16.1	14.2	9.8	9.0	(37)
(38)		5% WB	MCDBR	11.1	14.8	19.7	26.7	28.9	28.0	30.2	31.6	30.1	21.0	12.6	10.5	(38)
(39)			MCWBR	8.8	10.4	12.4	15.1	14.4	13.6	13.5	14.3	14.8	13.5	9.6	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.264	0.269	0.295	0.322	0.339	0.339	0.323	0.326	0.304	0.298	0.273	0.270	(40)
(41)		taud		2.411	2.462	2.484	2.433	2.427	2.453	2.531	2.518	2.577	2.571	2.535	2.341	(41)
(42)		Ebn at Noon		248	280	291	292	291	291	294	288	285	266	246	221	(42)
(43)		Edh at Noon		18	23	27	32	34	34	31	30	25	21	16	17	(43)
(44)	All-Sky Solar Radiation	RadAvg		302	609	1023	1452	1708	1838	1989	1700	1186	686	324	230	(44)
(45)		RadStd		25	51	62	114	130	163	165	94	103	68	33	23	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page