

GREY ISLET, BC, Canada

WMO: 714760

Lat: 54.580N

Lon: 130.698W

Elev: 31

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.1	(c) 25.3	(d) 12.5	(e) 10.4	(f) 24.3	(g) 15.9	(h) 12.3	(i) 27.1	(j) 59.8	(k) 28.0	(l) 56.5	(m) 28.4	(n) 44.3	(o) 50	(p) 0.855

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.7	(c) 65.6	(d) 59.9	(e) 63.5	(f) 58.7	(g) 61.7	(h) 57.7	(i) 61.0	(j) 64.5	(k) 59.6	(l) 62.7	(m) 58.5	(n) 61.3	(o) 9.2	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.3	75.4	62.5	58.1	72.1	61.1	57.0	69.3	60.0	27.0	64.7	26.1	63.0	25.4	61.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 50.7	(b) 45.7	(c) 41.2	(e) 20.6	(f) 71.1	(g) 4.4	(h) 2.7	(i) 17.5	(j) 73.1	(k) 15.0	(l) 74.7	(m) 12.5	(n) 76.2	(o) 9.3	(p) 78.1		
(4) 50.7	(5) 45.7	(6) 41.2	(7) 20.6	(8) 71.1	(9) 4.4	(10) 2.7	(11) 17.5	(12) 73.1	(13) 15.0	(14) 74.7	(15) 12.5	(16) 76.2	(17) 9.3	(18) 78.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	38.4	38.7	40.5	44.2	49.7	54.2	57.4	57.9	54.0	48.4	42.8	39.1	
	DBStd	8.23	6.26	4.91	4.53	4.01	3.73	3.36	2.79	2.71	2.52	2.92	4.44	5.53	
	HDD50	1819	359	315	294	176	51	3	0	0	2	64	216	339	
	HDD65	6509	824	735	759	623	473	324	237	221	330	514	665	804	
	CDD50	783	0	0	0	2	43	129	228	244	121	15	1	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	1	0	0	0	0	0	1	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	18.1	28.0	24.0	21.5	16.2	12.1	10.7	9.6	10.1	13.9	19.6	24.8	27.1	
Precipitation	PrecAvg	88.7	9.3	6.9	7.0	6.0	4.1	4.0	4.0	6.3	8.5	11.5	10.8	9.9	
	PrecMax	121.9	25.2	12.3	17.0	11.6	11.5	7.2	7.4	12.8	18.2	17.7	23.1	18.3	
	PrecMin	58.2	2.8	3.2	1.3	2.7	0.0	1.0	1.9	2.5	3.0	2.9	4.5	3.9	
	PrecStd	16.5	4.1	2.6	3.1	2.2	2.6	1.5	1.4	3.0	3.9	4.1	3.7	3.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.8	49.1	51.6	56.3	62.8	68.0	68.5	68.9	63.4	56.0	52.7	50.5	
		MCWB	47.1	46.4	46.2	48.9	54.0	60.0	60.6	61.6	57.9	52.2	49.9	46.1	
	2%	DB	47.9	47.2	48.8	52.9	59.1	63.4	65.3	65.6	60.4	54.3	51.1	48.4	
		MCWB	45.6	44.5	44.5	47.4	53.0	58.0	59.9	60.1	56.3	51.0	48.7	45.4	
	5%	DB	46.5	45.9	46.9	50.4	56.6	60.7	63.0	63.6	58.6	53.2	49.8	47.0	
		MCWB	44.4	43.3	43.6	46.2	51.6	56.5	58.7	59.1	55.2	50.3	47.5	44.4	
	10%	DB	45.1	44.5	45.6	48.6	54.4	58.7	61.2	61.7	57.2	52.2	48.3	45.7	
		MCWB	43.1	42.2	42.7	45.2	50.5	55.1	57.7	58.0	54.5	49.5	45.9	43.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.7	46.7	47.4	49.9	56.1	61.4	62.8	63.0	59.2	54.5	51.0	47.2
			MCDB	49.0	48.3	50.3	53.3	60.2	65.2	66.4	66.9	62.3	55.2	52.0	48.9
2%		WB	46.0	45.0	45.6	48.3	53.8	59.0	60.8	61.2	57.5	52.4	49.5	45.9	
		MCDB	47.5	46.8	47.9	51.2	57.6	62.7	64.1	64.7	59.7	53.3	51.0	47.8	
5%		WB	44.7	43.8	44.3	47.0	52.3	57.3	59.4	59.8	56.3	51.2	48.0	44.7	
		MCDB	46.2	45.6	46.4	49.5	55.3	60.4	62.3	63.0	58.2	52.5	49.8	46.8	
10%		WB	43.5	42.7	43.2	45.8	51.1	55.6	58.4	58.6	55.3	50.2	46.3	43.4	
		MCDB	45.0	44.4	45.4	48.2	53.8	58.3	61.0	61.5	56.9	51.7	48.1	45.5	
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.0	5.6	6.3	6.9	6.6	6.6	6.7	5.5	4.8	4.8	4.9	
		MCDBR	5.9	5.6	6.6	8.7	10.4	10.5	9.7	10.1	7.6	5.7	5.9	6.5	
		MCWBR	5.0	4.3	4.8	5.4	6.3	6.5	5.9	6.0	5.0	4.2	4.9	5.4	
	5% WB	MCDBR	5.7	5.3	6.4	7.7	9.3	10.1	9.0	9.4	6.9	5.3	5.7	6.6	
		MCWBR	5.3	4.5	4.9	5.3	6.2	6.7	5.9	6.0	5.0	4.6	5.2	5.6	
Clear-Sky Solar Irradiance	taub	0.302	0.310	0.335	0.368	0.363	0.376	0.371	0.362	0.348	0.338	0.309	0.292		
	taud	2.382	2.489	2.441	2.353	2.440	2.424	2.482	2.531	2.550	2.473	2.369	2.307		
	Ebn at Noon	207	252	268	272	280	277	276	272	262	235	200	180		
	Edh at Noon	17	21	28	34	33	34	32	29	25	21	17	15		
All-Sky Solar Radiation	RadAvg	158	414	742	1196	1538	1621	1452	1259	825	450	208	126		
	RadStd	21	75	97	78	145	124	169	117	97	68	30	23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+1.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		N/A	N/A	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page