

GREY ISLET, BC, Canada

WMO: 714760

Lat: 54.580N

Lon: 130.698W

Elev: 10

StdP: 101.21

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.5	(c) -3.7	(d) -10.9	(e) 1.5	(f) -4.3	(g) -9.0	(h) 1.8	(i) -2.7	(j) 26.8	(k) -2.2	(l) 25.2	(m) -2.0	(n) 19.8	(o) 50	(p) 0.855

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.7	(c) 18.7	(d) 15.5	(e) 17.5	(f) 14.8	(g) 16.5	(h) 14.3	(i) 16.1	(j) 18.0	(k) 15.3	(l) 17.1	(m) 14.7	(n) 16.3	(o) 4.1	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	10.8	16.9	14.5	10.3	16.2	13.9	9.9	15.6	45.0	18.2	42.8	17.2	41.2	16.4	20.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	20.4	18.4	-6.3	21.7	2.4	1.5	-8.1	22.8	-9.5	23.7	-10.8	24.5	-12.6	25.6
			-7.5	17.6	2.2	0.8	-9.1	18.1	-10.4	18.6	-11.7	19.1	-13.3	19.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	3.6	3.7	4.7	6.8	9.9	12.3	14.1	14.4	12.2	9.1	6.0	3.9
	DBStd	4.57	3.48	2.73	2.52	2.23	2.07	1.87	1.55	1.50	1.40	1.62	2.46	3.07
	HDD10.0	1011	199	175	163	98	28	2	0	0	1	36	120	188
	HDD18.3	3616	458	408	422	346	263	180	132	123	183	286	369	447
	CDD10.0	435	0	0	0	1	24	72	127	136	67	8	1	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.1	12.5	10.7	9.6	7.3	5.4	4.8	4.3	4.5	6.2	8.8	11.1	12.1
Precipitation	PrecAvg	2252	237	176	179	152	103	102	102	160	217	291	274	252
	PrecMax	3097	640	312	431	295	292	182	187	324	463	449	586	466
	PrecMin	1479	70	82	32	68	0	25	47	63	75	73	114	100
	PrecStd	420	105	65	80	56	66	37	36	76	100	104	93	93
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	9.5	10.9	13.5	17.1	20.0	20.3	20.5	17.4	13.3	11.5	10.3
		MCWB	8.4	8.0	7.9	9.4	12.2	15.6	15.9	16.5	14.4	11.2	10.0	7.8
	2%	DB	8.8	8.4	9.3	11.6	15.1	17.5	18.5	18.7	15.8	12.4	10.6	9.1
		MCWB	7.5	6.9	6.9	8.6	11.7	14.4	15.5	15.6	13.5	10.6	9.3	7.5
	5%	DB	8.0	7.7	8.3	10.2	13.6	16.0	17.2	17.6	14.8	11.8	9.9	8.4
		MCWB	6.9	6.3	6.4	7.9	10.9	13.6	14.8	15.0	12.9	10.2	8.6	6.9
	10%	DB	7.3	7.0	7.6	9.2	12.5	14.8	16.2	16.5	14.0	11.2	9.0	7.6
		MCWB	6.2	5.7	6.0	7.4	10.3	12.8	14.3	14.5	12.5	9.7	7.7	6.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	8.2	8.6	10.0	13.4	16.3	17.1	17.2	15.1	12.5	10.6	8.5
		MCDB	9.4	9.1	10.2	11.8	15.7	18.5	19.1	19.4	16.9	12.9	11.1	9.4
	2%	WB	7.8	7.2	7.5	9.0	12.1	15.0	16.0	16.2	14.2	11.3	9.7	7.7
		MCDB	8.6	8.2	8.8	10.6	14.2	17.1	17.8	18.2	15.4	11.8	10.5	8.8
	5%	WB	7.0	6.6	6.8	8.3	11.3	14.0	15.2	15.5	13.5	10.7	8.9	7.0
		MCDB	7.9	7.5	8.0	9.7	13.0	15.8	16.8	17.2	14.5	11.4	9.9	8.2
	10%	WB	6.4	6.0	6.2	7.7	10.6	13.1	14.6	14.8	12.9	10.1	7.9	6.3
		MCDB	7.2	6.9	7.4	9.0	12.1	14.6	16.1	16.4	13.8	10.9	9.0	7.5
Mean Daily Temperature Range	5% DB	MDBR	2.6	2.8	3.1	3.5	3.8	3.7	3.7	3.7	3.1	2.7	2.7	2.7
		MCDBR	3.3	3.1	3.7	4.8	5.8	5.9	5.4	5.6	4.2	3.1	3.3	3.6
		MCWBR	2.8	2.4	2.6	3.0	3.5	3.6	3.3	3.3	2.8	2.3	2.7	3.0
	5% WB	MCDBR	3.2	3.0	3.6	4.3	5.2	5.6	5.0	5.2	3.9	2.9	3.2	3.7
		MCWBR	2.9	2.5	2.7	2.9	3.4	3.7	3.3	3.4	2.8	2.5	2.9	3.1
Clear-Sky Solar Irradiance	taub	0.302	0.310	0.335	0.368	0.363	0.376	0.371	0.362	0.348	0.338	0.309	0.292	
	taud	2.382	2.489	2.441	2.353	2.440	2.424	2.482	2.531	2.550	2.473	2.369	2.307	
	Ebn at Noon	653	793	846	857	883	872	870	858	826	741	629	569	
	Edh at Noon	53	67	87	108	105	108	100	90	78	67	53	46	
All-Sky Solar Radiation	RadAvg	0.50	1.30	2.34	3.77	4.85	5.11	4.58	3.97	2.60	1.42	0.66	0.40	
	RadStd	0.07	0.24	0.31	0.24	0.46	0.39	0.53	0.37	0.31	0.21	0.10	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	(e) +0.80	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47) Regional (19 neighbors)		N/A	N/A	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page