

ROSE SPIT, BC, Canada

WMO: 714770

Lat: 54.159N

Lon: 131.661W

Elev: 7

StdP: 101.25

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.3	-11.5	1.4	-2.6	-9.1	1.7	-0.6	22.8	5.8	21.1	6.5	9.2	50	0.880

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	17.2	15.2	16.3	14.7	15.6	14.3	15.6	16.5	15.1	15.9	14.6	15.3	4.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	10.8	16.0	14.7	10.4	15.4	14.2	10.1	15.0	43.8	16.6	42.2	16.0	40.9	15.5	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.6	18.4	16.1	DB	-6.1	19.1	2.7	1.7	-8.0	20.2	-9.6	21.2	-11.1	22.1	-13.0	23.3	(4)
			WB	-7.2	16.9	2.8	1.7	-9.2	18.1	-10.8	19.1	-12.4	20.0	-14.4	21.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	3.8	4.0	4.4	6.6	9.1	11.4	13.2	13.9	12.4	9.3	5.8	3.9	
	DBStd	4.25	2.99	2.54	2.30	1.72	1.70	1.43	1.31	1.19	1.46	1.83	2.60	2.63	
	HDD10.0	1027	192	169	174	103	37	3	0	0	2	33	126	189	
	HDD18.3	3706	450	402	433	352	286	208	158	138	178	279	375	447	
	CDD10.0	363	0	1	0	1	9	45	101	120	74	13	1	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	7.6	8.9	8.4	8.1	7.6	7.2	6.9	6.5	6.2	6.6	7.9	8.5	8.9	
Precipitation	PrecAvg	2539	294	219	214	171	116	97	94	139	204	330	330	331	
	PrecMax	3305	472	381	340	280	280	175	189	282	428	509	632	741	
	PrecMin	1838	148	96	88	92	29	53	36	55	88	146	191	173	
	PrecStd	360	70	73	68	46	57	29	36	59	74	90	84	114	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	11.8	10.2	12.6	14.9	17.7	18.0	18.5	17.1	14.0	11.5	9.8	
		MCWB	8.6	11.0	8.8	9.8	12.4	14.8	15.8	16.1	15.4	12.5	10.7	8.1	
	2%	DB	8.6	9.0	8.8	10.7	13.2	15.5	16.7	17.3	15.9	13.0	10.6	8.6	
		MCWB	7.8	8.1	7.6	8.6	11.2	13.5	14.9	15.4	14.5	11.7	10.0	7.7	
	5%	DB	7.7	7.9	8.0	9.7	12.3	14.4	16.0	16.5	15.1	12.4	9.9	7.9	
		MCWB	7.0	6.9	6.9	8.0	10.6	12.7	14.5	15.0	14.0	11.3	9.2	7.3	
	10%	DB	7.2	7.1	7.3	9.0	11.5	13.6	15.3	15.8	14.5	11.9	9.2	7.3	
		MCWB	6.5	6.3	6.3	7.5	10.0	12.2	14.0	14.6	13.5	10.8	8.3	6.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.8	9.3	10.2	12.7	15.0	16.2	16.6	16.0	13.3	11.0	9.0
			MCDB	10.2	12.6	9.7	10.8	13.5	16.8	17.5	17.5	16.7	13.7	11.1	9.4
2%		WB	8.2	8.5	7.8	8.9	11.5	13.8	15.4	15.7	15.1	12.2	10.0	8.0	
		MCDB	8.5	9.0	8.4	9.7	12.5	14.9	16.4	16.5	15.6	12.6	10.3	8.4	
5%		WB	7.3	7.1	7.0	8.2	10.8	13.1	14.8	15.2	14.4	11.6	9.0	7.3	
		MCDB	7.7	7.5	7.6	9.0	11.8	13.9	15.6	16.0	15.0	12.1	9.4	7.8	
10%		WB	6.8	6.5	6.4	7.7	10.2	12.4	14.2	14.7	13.9	11.0	8.2	6.6	
		MCDB	7.2	6.9	7.0	8.5	11.1	13.2	15.0	15.5	14.4	11.6	8.8	7.2	
Mean Daily Temperature Range		5% DB	MDBR	2.9	3.3	3.8	4.0	3.7	3.6	3.3	3.5	3.5	3.6	3.4	3.1
			MCDBR	3.0	3.8	4.1	4.7	4.7	4.8	4.2	4.4	4.0	3.8	3.3	3.1
	MCWBR		2.9	3.8	3.6	3.7	3.8	3.8	3.2	3.5	3.3	3.5	3.4	3.2	
	5% WB	MCDBR	3.1	3.8	3.9	4.1	4.3	4.5	4.2	4.2	3.7	3.6	3.4	3.3	
		MCWBR	3.1	3.7	3.5	3.5	3.7	3.6	3.2	3.4	3.2	3.4	3.4	3.3	
Clear-Sky Solar Irradiance	taub	0.310	0.319	0.341	0.375	0.373	0.371	0.371	0.368	0.360	0.343	0.315	0.302		
	taud	2.390	2.485	2.444	2.343	2.412	2.452	2.496	2.519	2.508	2.451	2.358	2.313		
	Ebn at Noon	652	786	841	852	874	878	871	853	814	738	629	567		
	Edh at Noon	54	68	87	110	108	105	99	92	82	70	55	48		
All-Sky Solar Radiation	RadAvg	0.52	1.34	2.41	3.84	4.88	5.13	4.67	4.03	2.69	1.49	0.69	0.42		
	RadStd	0.07	0.23	0.29	0.22	0.43	0.39	0.50	0.35	0.29	0.20	0.09	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page