

CATHEDRAL POINT, BC, Canada

WMO: 714820

Lat: 52.188N

Lon: 127.471W

Elev: 84

StdP: 14.65

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	20.5	24.2	8.1	8.4	24.1	11.9	10.1	26.0	60.7	19.9	55.3	22.8	46.5	50	0.692

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	74.0	62.9	70.8	61.8	68.1	60.5	64.5	71.1	62.8	68.6	61.4	66.4	10.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.7	82.3	67.2	60.3	78.3	65.5	59.1	75.0	64.0	29.6	71.3	28.4	68.7	27.4	66.6	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 49.2	42.3	35.8	18.2	81.4	5.6	4.3	14.2	84.5	11.0	87.0	7.8	89.4	3.8	92.5		
(5)			16.1	66.9	5.0	1.6	12.5	68.1	9.6	69.1	6.8	70.0	3.2	71.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	37.5	38.1	40.6	45.9	52.4	56.6	60.6	61.3	56.4	48.3	40.9	36.8		
	DBStd	10.09	5.84	4.86	4.80	4.64	5.31	4.77	4.56	4.15	4.10	3.89	5.01	5.33		
	HDD50	1954	388	332	294	140	35	2	0	0	2	78	274	409		
	HDD65	6244	853	752	758	574	391	258	152	131	260	517	724	874		
	CDD50	1226	0	0	1	16	109	200	330	349	194	27	0	0		
	CDD65	41	0	0	0	0	1	6	17	15	2	0	0	0		
	CDH74	106	0	0	0	0	1	22	52	30	1	0	0	0		
	CDH80	12	0	0	0	0	0	4	5	3	0	0	0	0		
	WSAvg	12.4	20.1	17.1	12.5	9.3	9.0	8.7	8.6	8.2	8.7	11.5	15.9	18.9		
	PrecAvg	71.8	8.3	5.9	6.1	4.8	3.2	3.1	2.5	3.1	5.0	9.3	10.8	9.4		
	PrecMax	94.3	14.5	12.1	10.6	9.8	6.1	5.7	5.6	6.1	11.1	16.3	17.6	14.9		
(15) Precipitation	PrecMin	51.6	4.4	1.7	1.0	2.0	0.5	0.8	0.6	0.7	1.3	3.6	5.2	3.7		
	PrecStd	10.3	2.6	2.2	2.0	1.6	1.3	1.0	1.2	1.4	2.2	3.1	3.3	2.6		
	0.4%	DB	49.7	49.1	55.4	63.8	71.3	76.8	79.2	77.4	70.6	60.3	52.9	48.5		
	MCWB	46.8	43.1	47.0	50.9	56.5	61.1	65.5	63.1	61.1	54.3	50.3	45.3	45.3		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2%	DB	46.8	46.7	50.8	58.5	66.1	70.4	74.5	72.9	66.6	57.4	50.0	45.6		
	MCWB	43.9	42.1	45.4	49.1	55.9	60.5	64.0	63.1	59.3	53.3	47.4	43.2	43.2		
	5%	DB	45.1	45.2	48.1	55.0	62.8	66.8	70.8	70.0	63.8	55.4	48.1	43.9		
	MCWB	42.7	41.4	44.1	47.6	54.3	58.9	62.6	62.1	57.8	51.9	46.0	41.9	41.9		
	10%	DB	43.6	43.6	46.1	52.2	60.0	63.6	67.5	67.5	61.7	53.5	46.5	42.6		
	MCWB	41.5	40.7	42.8	46.6	53.1	57.2	60.8	61.0	57.0	50.1	44.6	40.7	40.7		
	0.4%	WB	47.7	45.6	48.7	53.4	59.3	64.4	67.6	65.6	62.8	57.2	50.8	46.3		
	MCDB	49.2	46.8	52.4	60.5	67.4	70.9	75.9	73.0	68.1	58.8	52.0	48.2	48.2		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.0	43.6	46.7	50.9	56.8	61.3	65.1	64.0	60.8	54.9	48.0	43.8		
	MCDB	46.1	45.1	49.4	55.4	63.9	67.6	72.2	70.3	64.5	56.4	49.4	45.0	45.0		
	5%	WB	43.3	42.3	45.0	48.9	55.2	59.2	63.1	62.8	59.3	52.8	46.5	42.3		
	MCDB	44.4	44.0	47.4	53.0	61.1	65.1	69.1	68.4	62.4	54.4	47.9	43.6	43.6		
	10%	WB	41.9	41.2	43.6	47.4	53.8	57.5	61.3	61.5	57.9	50.7	45.1	41.1		
	MCDB	43.1	42.9	45.7	50.9	58.6	62.4	66.6	66.3	60.7	52.4	46.5	42.3	42.3		
	MDBR	4.7	5.8	7.2	9.1	10.2	9.3	9.5	9.1	7.6	5.7	4.9	4.7	4.7		
	5% DB	MCDBR	6.8	7.1	9.8	13.7	15.3	15.5	15.7	14.0	10.9	8.2	6.6	6.6		
(36) Mean Daily Temperature Range	MCWBR	4.9	4.5	5.7	6.7	7.6	7.7	7.3	6.2	5.4	5.2	4.9	5.1	5.1		
	5% WB	MCDBR	6.7	6.2	8.5	11.2	13.2	13.9	14.3	12.5	9.6	7.6	6.2	6.5		
	MCWBR	5.4	4.9	5.5	6.6	7.1	7.4	7.1	6.0	5.4	5.7	5.1	5.4	5.4		
	taub	0.306	0.319	0.348	0.375	0.377	0.394	0.371	0.374	0.356	0.343	0.322	0.296	0.296		
(40) Clear-Sky Solar Irradiance	taud	2.318	2.370	2.306	2.268	2.344	2.349	2.461	2.470	2.502	2.463	2.342	2.310	2.310		
	Ebn at Noon	218	253	266	272	278	273	278	271	263	241	209	199	199		
	Edh at Noon	20	25	32	38	37	37	33	31	27	23	19	17	17		
	RadAvg	210	475	707	1136	1473	1580	1610	1412	943	510	234	171	171		
(44) All-Sky Solar Radiation	RadStd	29	76	131	107	194	153	226	106	100	97	45	30	30		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-340	+173	N/A
Regional (9 neighbors)	N/A	N/A	N/A	+0.81	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page