

CATHEDRAL POINT, BC, Canada

WMO: 714820

Lat: 52.188N

Lon: 127.471W

Elev: 26

StdP: 101.02

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-6.4	-4.4	-13.3	1.2	-4.4	-11.2	1.4	-3.3	27.1	-6.7	24.7	-5.1	20.8	50	0.692

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	23.4	17.1	21.5	16.5	20.0	15.9	18.0	21.7	17.1	20.3	16.3	19.1	4.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	11.8	19.5	15.7	11.2	18.6	15.1	10.7	17.8	50.9	21.8	48.1	20.4	45.8	19.2	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	18.9	16.0	DB	-7.7	27.5	3.1	2.4	-9.9	29.2	-11.7	30.6	-13.4	31.9	-15.7	33.6	(4)
(5)			WB	-8.9	19.4	2.8	0.9	-10.8	20.1	-12.5	20.6	-14.0	21.1	-16.0	21.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	3.0	3.4	4.8	7.7	11.3	13.7	15.9	16.3	13.5	9.1	4.9	2.7	(6)
(7)		DBStd	5.61	3.24	2.70	2.67	2.58	2.95	2.65	2.53	2.31	2.28	2.16	2.78	2.96	(7)
(8)		HDD10.0	1086	216	184	163	78	19	1	0	0	1	43	152	227	(8)
(9)		HDD18.3	3469	474	418	421	319	217	143	84	73	144	287	402	486	(9)
(10)		CDD10.0	681	0	0	1	9	61	111	183	194	108	15	0	0	(10)
(11)		CDD18.3	23	0	0	0	0	1	3	9	8	1	0	0	0	(11)
(12)		CDH23.3	59	0	0	0	0	1	12	29	17	1	0	0	0	(12)
(13)		CDH26.7	7	0	0	0	0	0	2	3	2	0	0	0	0	(13)
(14)	Wind	WSAvg	5.5	9.0	7.6	5.6	4.1	4.0	3.9	3.9	3.6	3.9	5.2	7.1	8.4	(14)
(15)	Precipitation	PrecAvg	1823	212	150	156	122	82	80	63	79	127	236	275	240	(15)
(16)		PrecMax	2394	369	307	269	248	155	145	142	156	281	414	446	378	(16)
(17)		PrecMin	1311	113	44	26	51	13	20	15	18	33	92	133	95	(17)
(18)		PrecStd	262	66	56	52	40	32	25	30	36	56	79	83	65	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	9.5	13.0	17.7	21.8	24.9	26.2	25.2	21.4	15.7	11.6	9.2	(19)
(20)			MCWB	8.2	6.2	8.3	10.5	13.6	16.2	18.6	17.3	16.2	12.4	10.1	7.4	(20)
(21)		2%	DB	8.2	8.2	10.4	14.7	19.0	21.3	23.6	22.7	19.2	14.1	10.0	7.6	(21)
(22)			MCWB	6.6	5.6	7.5	9.5	13.3	15.8	17.8	17.3	15.1	11.9	8.6	6.2	(22)
(23)		5%	DB	7.3	7.3	8.9	12.8	17.1	19.3	21.6	21.1	17.7	13.0	9.0	6.6	(23)
(24)			MCWB	5.9	5.2	6.7	8.7	12.4	14.9	17.0	16.7	14.4	11.0	7.8	5.5	(24)
(25)		10%	DB	6.4	6.5	7.8	11.2	15.5	17.6	19.7	19.7	16.5	11.9	8.1	5.9	(25)
(26)			MCWB	5.3	4.8	6.0	8.1	11.7	14.0	16.0	16.1	13.9	10.0	7.0	4.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	7.6	9.3	11.9	15.2	18.0	19.8	18.7	17.1	14.0	10.4	8.0	(27)
(28)			MCD B	9.6	8.2	11.3	15.8	19.7	21.6	24.4	22.8	20.0	14.9	11.1	9.0	(28)
(29)		2%	WB	7.2	6.5	8.2	10.5	13.8	16.3	18.4	17.8	16.0	12.7	8.9	6.6	(29)
(30)			MCD B	7.8	7.3	9.7	13.0	17.7	19.8	22.3	21.3	18.1	13.6	9.7	7.2	(30)
(31)		5%	WB	6.3	5.7	7.2	9.4	12.9	15.1	17.3	17.1	15.1	11.6	8.1	5.7	(31)
(32)			MCD B	6.9	6.7	8.6	11.6	16.2	18.4	20.6	20.2	16.9	12.5	8.8	6.5	(32)
(33)		10%	WB	5.5	5.1	6.4	8.5	12.1	14.2	16.3	16.4	14.4	10.4	7.3	5.0	(33)
(34)			MCD B	6.2	6.1	7.6	10.5	14.8	16.9	19.2	19.1	15.9	11.4	8.0	5.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.6	3.2	4.0	5.1	5.7	5.2	5.3	5.0	4.2	3.2	2.7	2.6	(35)
(36)			MCD BR	3.8	3.9	5.4	7.6	8.5	8.6	8.7	7.8	6.1	4.6	3.6	3.7	(36)
(37)			MCWBR	2.7	2.5	3.2	3.7	4.2	4.3	4.1	3.4	3.0	2.9	2.7	2.8	(37)
(38)		5% WB	MCD BR	3.7	3.5	4.7	6.2	7.3	7.7	8.0	7.0	5.4	4.2	3.5	3.6	(38)
(39)			MCWBR	3.0	2.7	3.1	3.7	4.0	4.1	4.0	3.3	3.0	3.2	2.9	3.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.319	0.348	0.375	0.377	0.394	0.371	0.374	0.356	0.343	0.322	0.296	(40)	
(41)		taud	2.318	2.370	2.306	2.268	2.344	2.349	2.461	2.470	2.502	2.463	2.342	2.310	(41)	
(42)		Ebn at Noon	686	797	840	859	875	860	875	854	830	761	658	628	(42)	
(43)		Edh at Noon	63	79	102	120	117	118	104	98	85	72	61	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.66	1.50	2.23	3.58	4.64	4.98	5.08	4.45	2.97	1.61	0.74	0.54	(44)	
(45)		RadStd	0.09	0.24	0.41	0.34	0.61	0.48	0.71	0.33	0.32	0.31	0.14	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-189	+96	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page