

NITINAT LAKE, BC, Canada

WMO: 714831

Lat: 48.670N

Lon: 124.830W

Elev: 119

StdP: 14.63

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	28.5	31.0	11.4	9.9	34.7	18.1	13.7	36.9	36.2	48.4	31.8	47.2	8.5	30	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	68.9	56.7	65.1	56.2	62.4	55.8	59.6	63.8	58.4	62.1	57.3	60.8	6.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.9	72.0	60.6	56.7	68.9	59.4	55.8	66.5	58.4	26.1	64.0	25.3	62.2	24.6	60.9	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.9	21.9	16.7	DB	26.0	76.8	4.0	1.7	23.1	78.1	20.8	79.1	18.5	80.1	15.6	81.3	
			WB	23.2	62.6	4.7	2.3	19.8	64.2	17.1	65.6	14.4	66.8	11.0	68.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	41.6	42.5	44.5	46.6	50.6	53.5	56.1	57.1	55.6	50.2	44.9	41.5
	DBStd	6.74	4.46	4.19	3.60	3.27	3.74	2.98	2.76	3.13	3.82	3.63	4.25	4.41
	HDD50	1251	260	210	172	111	34	3	0	0	2	40	157	262
	HDD65	5923	725	629	635	551	447	344	277	246	282	458	602	727
	CDD50	809	0	1	3	10	53	109	189	221	171	47	5	0
	CDD65	5	0	0	0	0	0	1	1	2	1	0	0	0
	CDH74	17	0	0	0	0	1	3	4	8	1	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	6.6	8.7	8.5	8.1	6.9	6.1	5.4	4.2	4.0	4.5	6.4	8.1	8.6
(15) Precipitation	PrecAvg	118.0	18.5	11.0	11.9	8.5	4.5	3.5	2.4	3.4	4.6	12.8	18.6	17.4
	PrecMax	155.4	29.3	28.7	23.8	16.5	8.5	7.9	6.1	14.5	12.8	21.0	33.9	29.5
	PrecMin	89.8	9.6	1.7	1.7	2.2	0.6	1.4	0.3	0.0	0.5	0.9	7.0	9.4
	PrecStd	16.5	5.2	6.4	5.3	4.0	2.2	1.9	1.7	3.6	2.9	5.3	8.0	4.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	55.6	57.0	61.6	67.5	71.4	71.3	74.3	71.8	63.5	54.8	51.5
		MCWB	48.0	48.1	47.5	50.2	53.6	56.2	57.2	59.4	57.4	52.9	52.1	48.8
	2%	DB	50.0	51.7	53.9	56.0	61.3	63.1	66.4	67.5	67.0	59.3	53.1	49.9
		MCWB	47.9	46.2	47.1	48.5	52.1	54.9	56.7	57.8	56.7	51.8	50.6	47.3
	5%	DB	49.0	49.6	51.4	53.1	58.4	59.5	62.5	63.6	63.7	56.7	52.2	48.9
		MCWB	46.9	46.4	47.2	48.0	52.0	53.9	56.3	57.0	56.2	51.7	49.9	46.5
	10%	DB	47.8	48.3	50.0	51.6	55.9	57.6	60.0	61.5	61.3	55.1	51.0	47.7
		MCWB	45.8	45.4	46.5	47.3	51.2	53.1	55.6	56.7	55.9	51.3	48.8	45.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	50.4	51.3	52.4	56.5	58.4	60.2	61.7	61.2	56.3	53.1	49.9
		MCDB	50.6	52.1	52.6	55.9	61.3	63.5	65.8	68.6	65.1	58.7	54.3	50.7
	2%	WB	48.4	48.5	49.5	50.7	54.8	56.6	58.3	59.7	59.4	54.6	51.7	48.5
		MCDB	49.5	50.0	51.3	53.6	58.5	61.2	62.5	64.1	63.2	56.7	52.9	49.4
	5%	WB	47.5	47.4	48.3	49.5	53.2	55.2	57.2	58.4	58.1	53.5	50.6	47.4
		MCDB	48.7	49.0	50.3	52.0	56.9	58.5	61.1	61.9	61.6	55.4	51.8	48.5
	10%	WB	46.4	46.2	47.3	48.4	51.9	54.0	56.2	57.4	56.7	52.2	49.3	46.1
		MCDB	47.6	47.9	49.5	50.7	55.3	56.8	59.4	60.4	60.0	54.1	50.6	47.5
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.4	9.8	9.6	9.5	8.1	7.8	8.5	9.5	9.1	8.3	8.1
		MCDBR	8.0	9.8	11.4	11.4	13.3	11.2	12.4	12.7	14.0	11.2	8.1	8.6
	5% WB	MCWBR	6.8	6.9	7.4	7.1	7.0	5.7	6.2	7.1	7.4	6.7	6.7	7.4
		MCDWR	7.3	8.6	9.1	9.3	11.2	9.8	9.6	10.8	11.4	8.7	6.7	7.7
(40) Clear-Sky Solar Irradiance	taub	taub	0.318	0.313	0.336	0.352	0.370	0.356	0.347	0.347	0.339	0.335	0.320	0.312
		taud	2.504	2.568	2.508	2.460	2.429	2.486	2.553	2.556	2.569	2.547	2.524	2.487
	Ebn at Noon	Ebn at Noon	239	271	280	285	283	287	288	284	276	258	236	225
		Edh at Noon	20	23	28	32	35	33	30	29	26	23	19	17
(44) All-Sky Solar Radiation	RadAvg	RadAvg	284	567	855	1319	1660	1811	1886	1582	1197	672	342	231
	RadStd	RadStd	40	82	105	120	136	166	127	130	95	90	58	33

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page