

NITINAT LAKE, BC, Canada

WMO: 714831

Lat: 48.670N

Lon: 124.830W

Elev: 36

StdP: 100.89

Time Zone: -8.00 (NAP)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.9	-0.5	-11.4	1.4	1.5	-7.7	2.0	2.7	16.2	9.1	14.2	8.5	3.8	30	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	20.5	13.7	18.4	13.5	16.9	13.2	15.3	17.7	14.6	16.7	14.1	16.0	2.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	10.3	15.9	13.7	9.8	15.2	13.2	9.5	14.7	42.9	17.8	41.1	16.8	39.4	16.1	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	9.8	7.5	DB	-3.3	24.9	2.2	1.0	-4.9	25.6	-6.2	26.2	-7.5	26.7	-9.1	27.4	(4)
(5)			WB	-4.9	17.0	2.6	1.3	-6.8	17.9	-8.3	18.6	-9.8	19.4	-11.7	20.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	5.3	5.8	7.0	8.1	10.3	12.0	13.4	14.0	13.1	10.1	7.2	5.3	(6)
(7)		DBStd	3.75	2.48	2.33	2.00	1.81	2.08	1.66	1.53	1.74	2.12	2.02	2.36	2.45	(7)
(8)		HDD10.0	695	144	117	96	62	19	2	0	0	1	22	87	146	(8)
(9)		HDD18.3	3291	403	349	353	306	248	191	154	137	157	254	334	404	(9)
(10)		CDD10.0	449	0	1	2	6	29	61	105	123	95	26	3	0	(10)
(11)		CDD18.3	3	0	0	0	0	0	1	1	1	1	0	0	0	(11)
(12)		CDH23.3	9	0	0	0	0	1	2	2	4	1	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.9	3.8	3.6	3.1	2.7	2.4	1.9	1.8	2.0	2.9	3.6	3.8	(14)
(15)	Precipitation	PrecAvg	2996	471	280	303	216	114	90	61	87	118	325	472	443	(15)
(16)		PrecMax	3947	745	728	604	419	215	201	155	368	325	534	861	749	(16)
(17)		PrecMin	2280	245	42	43	55	15	35	8	1	12	23	178	240	(17)
(18)		PrecStd	418	132	162	134	101	57	49	42	92	74	135	202	116	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	13.1	13.9	16.5	19.7	21.9	21.8	23.5	22.1	17.5	12.7	10.8	(19)
(20)		MCWB	8.9	8.9	8.6	10.1	12.0	13.4	14.0	15.2	14.1	11.6	11.1	9.3	(20)	
(21)		2%	DB	10.0	10.9	12.2	13.3	16.3	17.3	19.1	19.7	19.4	15.2	11.7	10.0	(21)
(22)		MCWB	8.8	7.9	8.4	9.2	11.2	12.7	13.7	14.3	13.7	11.0	10.3	8.5	(22)	
(23)		5%	DB	9.4	9.8	10.8	11.7	14.7	15.3	16.9	17.6	17.6	13.7	11.2	9.4	(23)
(24)		MCWB	8.3	8.0	8.4	8.9	11.1	12.2	13.5	13.9	13.5	10.9	9.9	8.1	(24)	
(25)		10%	DB	8.8	9.0	10.0	10.9	13.3	14.2	15.5	16.4	16.3	12.8	10.5	8.7	(25)
(26)		MCWB	7.7	7.4	8.0	8.5	10.7	11.7	13.1	13.7	13.3	10.7	9.3	7.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	10.2	10.7	11.4	13.6	14.7	15.7	16.5	16.2	13.5	11.7	9.9	(27)
(28)		MDCB	10.3	11.2	11.5	13.3	16.3	17.5	18.8	20.3	18.4	14.8	12.4	10.4	(28)	
(29)		2%	WB	9.1	9.1	9.7	10.4	12.6	13.6	14.6	15.4	15.2	12.6	11.0	9.1	(29)
(30)		MDCB	9.7	10.0	10.7	12.0	14.7	16.2	17.0	17.9	17.3	13.7	11.6	9.7	(30)	
(31)		5%	WB	8.6	8.5	9.1	9.7	11.8	12.9	14.0	14.7	14.5	11.9	10.3	8.6	(31)
(32)		MDCB	9.3	9.4	10.2	11.1	13.8	14.7	16.1	16.6	16.5	13.0	11.0	9.2	(32)	
(33)		10%	WB	8.0	7.9	8.5	9.1	11.0	12.2	13.4	14.1	13.7	11.2	9.6	7.8	(33)
(34)		MDCB	8.7	8.8	9.7	10.4	13.0	13.8	15.2	15.8	15.5	12.3	10.3	8.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.4	5.2	5.5	5.3	5.3	4.5	4.3	4.7	5.3	5.1	4.6	4.5	(35)	
(36)		5% DB	MCDBR	4.5	5.5	6.3	6.3	7.4	6.2	6.9	7.1	7.8	6.2	4.5	4.8	(36)
(37)		MCWBR	3.8	3.8	4.1	3.9	3.9	3.2	3.5	3.9	4.1	3.7	3.7	4.1	(37)	
(38)		5% WB	MCDBR	4.0	4.8	5.0	5.2	6.2	5.4	5.3	6.0	6.3	4.8	3.7	4.3	(38)
(39)		MCWBR	3.8	3.8	3.7	3.5	3.7	3.2	3.2	3.9	4.1	3.6	3.5	4.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.318	0.313	0.336	0.352	0.370	0.356	0.347	0.347	0.339	0.335	0.320	0.312	(40)	
(41)		taud	2.504	2.568	2.508	2.460	2.429	2.486	2.553	2.556	2.569	2.547	2.524	2.487	(41)	
(42)		Ebn at Noon	753	855	884	899	892	905	908	895	871	812	744	708	(42)	
(43)		Edh at Noon	62	71	88	102	110	104	96	92	83	72	60	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.90	1.79	2.69	4.16	5.23	5.71	5.95	4.99	3.77	2.12	1.08	0.73	(44)	
(45)		RadStd	0.13	0.26	0.33	0.38	0.43	0.52	0.40	0.41	0.30	0.28	0.18	0.10	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page