

HERBERT ISLAND, BC, Canada

WMO: 714850

Lat: 50.940N

Lon: 127.632W

Elev: 43

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.3	33.3	14.9	11.7	34.3	21.7	16.3	36.1	57.0	41.4	53.0	42.8	16.2	90	0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.8	61.7	57.5	60.0	56.8	58.7	56.1	59.0	60.7	57.9	59.6	57.0	58.6	13.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.2	72.5	59.6	57.1	69.5	58.5	56.1	67.1	57.8	25.7	60.9	25.0	59.6	24.4	58.8	64.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 51.1	45.9	40.5	DB	27.6	67.4	4.6	4.0	24.3	70.3	21.7	72.6	19.1	74.9	15.8	77.7	(4)
(5)			WB	22.8	60.7	5.0	1.3	19.2	61.6	16.2	62.3	13.4	63.0	9.7	64.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	42.3	42.1	43.4	46.5	49.9	52.6	54.8	55.5	53.3	49.3	45.0	41.9		
	DBStd	5.94	4.32	4.19	3.79	3.11	2.99	2.46	2.24	2.17	2.47	3.01	3.89	3.97		
	HDD50	1275	238	222	205	112	38	6	0	0	3	48	153	250		
	HDD65	6173	702	642	668	556	469	373	316	294	352	486	600	715		
	CDD50	579	1	0	2	6	34	83	150	171	101	27	4	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	15.8	22.0	18.9	18.0	14.8	11.9	10.8	11.0	10.7	11.5	16.8	20.8	22.9		
	PrecAvg	79.9	9.5	5.9	6.9	5.1	3.4	3.0	2.6	3.6	5.3	10.8	12.0	11.1		
(15) Precipitation	PrecMax	104.6	16.3	13.9	12.0	9.7	5.5	5.6	7.3	7.1	11.2	18.5	19.4	22.6		
	PrecMin	59.5	3.9	0.3	1.9	1.4	1.2	1.0	0.4	0.6	0.4	3.8	6.8	4.7		
	PrecStd	10.7	3.1	2.6	2.2	1.6	1.1	1.1	1.8	1.7	2.6	3.7	3.5	3.5		
	PrecStd	10.7	3.1	2.6	2.2	1.6	1.1	1.1	1.8	1.7	2.6	3.7	3.5	3.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	52.2	54.2	57.5	59.3	62.2	63.5	64.3	62.8	58.7	55.1	52.2		
		MCWB	48.6	47.4	48.1	50.6	53.5	57.1	58.9	59.6	56.5	54.7	50.7	48.2		
	2%	DB	50.3	50.4	51.3	53.6	56.6	59.0	60.9	61.7	59.5	56.1	52.6	49.8		
		MCWB	47.5	46.2	47.3	48.7	52.4	55.2	57.6	58.2	55.9	53.0	49.8	46.6		
	5%	DB	48.9	48.8	49.7	51.8	54.9	57.1	59.4	60.0	57.8	54.5	51.2	48.1		
		MCWB	46.2	45.3	46.3	47.9	51.6	54.0	56.8	57.4	55.2	52.0	48.3	45.4		
	10%	DB	47.6	47.4	48.2	50.3	53.5	55.6	58.1	58.6	56.5	53.1	49.9	46.9		
		MCWB	44.9	44.5	45.2	47.1	50.7	53.1	56.0	56.7	54.5	51.0	47.4	44.4		
	0.4%	WB	50.2	49.1	50.4	51.9	54.9	57.9	60.2	61.2	58.4	55.9	52.4	50.1		
		MCDB	51.3	51.5	52.2	55.9	58.0	61.1	62.3	63.0	60.4	57.5	53.4	51.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	48.6	47.5	48.5	50.3	53.5	56.2	58.7	59.4	57.0	54.3	50.7	47.7		
		MCDB	50.3	49.8	50.9	52.8	56.1	58.6	60.6	60.9	58.5	55.8	52.1	49.7		
	5%	WB	47.1	46.3	47.0	49.1	52.4	55.0	57.6	58.3	55.9	53.0	49.3	46.1		
		MCDB	49.1	48.4	49.5	51.4	54.8	57.1	59.4	59.7	57.4	54.3	50.7	48.1		
	10%	WB	45.8	45.0	45.9	47.8	51.4	54.0	56.6	57.3	55.0	51.9	48.0	45.0		
		MCDB	47.8	47.2	48.4	50.2	53.5	56.0	58.4	58.7	56.4	53.4	49.4	47.1		
	5% DB	MDBR	4.3	5.1	5.6	6.1	6.2	6.0	6.2	6.8	6.3	4.9	4.4	4.1		
		MCDBR	4.8	6.1	6.7	8.1	8.3	8.1	8.2	8.6	8.4	6.4	5.3	4.7		
		MCWBR	2.7	3.8	4.1	5.1	5.5	5.3	5.5	5.7	5.2	4.0	3.8	3.4		
		MCWBR	4.0	5.4	6.3	8.4	8.2	8.0	8.2	8.5	7.6	5.4	4.8	4.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	2.9	3.8	4.3	5.4	5.6	5.5	5.8	5.9	5.4	4.3	4.2	3.7		
		MCWBR	2.9	3.8	4.3	5.4	5.6	5.5	5.8	5.9	5.4	4.3	4.2	3.7		
	Clear-Sky Solar Irradiance	taub	0.321	0.329	0.350	0.369	0.376	0.373	0.367	0.363	0.357	0.344	0.329	0.314		
		taud	2.427	2.479	2.433	2.388	2.403	2.442	2.503	2.524	2.527	2.501	2.409	2.388		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	224	256	270	277	279	280	280	276	266	246	216	205		
		Edh at Noon	19	23	30	34	35	34	32	30	27	23	19	17		
(44) All-Sky Solar Radiation	RadStd	RadAvg	230	505	763	1190	1533	1602	1672	1461	1020	548	266	186		
		RadStd	32	83	113	99	174	171	212	128	97	92	48	30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.44	N/A	N/A	-301	-499	+205	N/A
(47) Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page