

HERBERT ISLAND, BC, Canada

WMO: 714850

Lat: 50.940N

Lon: 127.632W

Elev: 13

StdP: 101.17

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.9	0.7	-9.5	1.7	1.3	-5.7	2.3	2.3	25.5	5.2	23.7	6.0	7.3	90	0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.8	16.5	14.2	15.6	13.8	14.8	13.4	15.0	16.0	14.4	15.3	13.9	14.8	6.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	10.4	15.3	13.9	9.9	14.7	13.4	9.6	14.3	41.9	16.1	40.3	15.4	38.9	14.9	18.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.8	20.5	18.1	DB	-2.4	19.7	2.5	2.2	-4.3	21.3	-5.7	22.6	-7.2	23.8	-9.0	25.4	(4)
(5)			WB	-5.1	15.9	2.8	0.7	-7.1	16.4	-8.8	16.9	-10.3	17.2	-12.4	17.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	5.7	5.6	6.4	8.0	9.9	11.4	12.7	13.1	11.8	9.6	7.2	5.5
	DBStd	3.30	2.40	2.33	2.10	1.73	1.66	1.37	1.24	1.20	1.37	1.67	2.16	2.21
	HDD10.0	708	132	123	114	62	21	3	0	0	2	27	85	139
	HDD18.3	3429	390	357	371	309	261	207	176	163	196	270	333	397
	CDD10.0	322	1	0	1	3	19	46	83	95	56	15	2	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.1	9.8	8.4	8.0	6.6	5.3	4.8	4.9	4.8	5.2	7.5	9.3	10.2
Precipitation	PrecAvg	2029	242	150	176	130	86	77	65	92	135	275	305	281
	PrecMax	2658	415	354	305	247	139	141	186	181	284	469	492	574
	PrecMin	1511	99	8	48	36	30	26	11	14	10	96	172	120
	PrecStd	271	80	67	57	41	29	29	46	44	65	94	88	89
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	11.2	12.3	14.1	15.2	16.8	17.5	17.9	17.1	14.8	12.8	11.2
		MCWB	9.2	8.6	9.0	10.3	11.9	13.9	15.0	15.3	13.6	12.6	10.4	9.0
	2%	DB	10.2	10.2	10.7	12.0	13.7	15.0	16.1	16.5	15.3	13.4	11.5	9.9
		MCWB	8.6	7.9	8.5	9.3	11.3	12.9	14.2	14.5	13.3	11.6	9.9	8.1
	5%	DB	9.4	9.3	9.8	11.0	12.7	13.9	15.2	15.5	14.3	12.5	10.6	9.0
		MCWB	7.9	7.4	7.9	8.9	10.9	12.2	13.8	14.1	12.9	11.1	9.1	7.5
	10%	DB	8.7	8.5	9.0	10.2	11.9	13.1	14.5	14.8	13.6	11.7	9.9	8.3
		MCWB	7.2	6.9	7.4	8.4	10.4	11.7	13.3	13.7	12.5	10.6	8.6	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	9.5	10.2	11.1	12.7	14.4	15.7	16.2	14.6	13.3	11.3	10.1
		MCDB	10.7	10.8	11.2	13.3	14.4	16.2	16.8	17.2	15.8	14.2	11.9	10.8
	2%	WB	9.2	8.6	9.1	10.1	11.9	13.5	14.8	15.2	13.9	12.4	10.4	8.7
		MCDB	10.2	9.9	10.5	11.5	13.4	14.8	15.9	16.1	14.7	13.2	11.2	9.8
	5%	WB	8.4	7.9	8.3	9.5	11.3	12.8	14.2	14.6	13.3	11.7	9.6	7.8
		MCDB	9.5	9.1	9.7	10.8	12.7	14.0	15.2	15.4	14.1	12.4	10.4	9.0
	10%	WB	7.7	7.2	7.7	8.8	10.8	12.2	13.7	14.1	12.8	11.1	8.9	7.2
		MCDB	8.8	8.4	9.1	10.1	12.0	13.3	14.6	14.8	13.6	11.9	9.7	8.4
Mean Daily Temperature Range	5% DB	MDBR	2.4	2.8	3.1	3.4	3.5	3.3	3.5	3.8	3.5	2.7	2.4	2.3
		MCDBR	2.7	3.4	3.7	4.5	4.6	4.5	4.6	4.8	4.7	3.6	2.9	2.6
		MCWBR	1.5	2.1	2.3	2.9	3.0	2.9	3.1	3.1	2.9	2.2	2.1	1.9
	5% WB	MCDBR	2.2	3.0	3.5	4.7	4.6	4.5	4.6	4.7	4.2	3.0	2.7	2.6
		MCWBR	1.6	2.1	2.4	3.0	3.1	3.1	3.2	3.3	3.0	2.4	2.3	2.1
Clear-Sky Solar Irradiance	taub	0.321	0.329	0.350	0.369	0.376	0.373	0.367	0.363	0.357	0.344	0.329	0.314	
	taud	2.427	2.479	2.433	2.388	2.403	2.442	2.503	2.524	2.527	2.501	2.409	2.388	
	Ebn at Noon	705	808	852	873	880	884	884	871	838	777	681	645	
	Edh at Noon	61	74	93	108	111	108	100	94	84	72	61	55	
All-Sky Solar Radiation	RadAvg	0.72	1.59	2.40	3.75	4.83	5.05	5.27	4.61	3.21	1.73	0.84	0.58	
	RadStd	0.10	0.26	0.36	0.31	0.55	0.54	0.67	0.40	0.30	0.29	0.15	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (14 neighbors)	N/A	N/A	N/A	+0.80	N/A	N/A	-167	-277	+114	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page