

SCOTT, SK, Canada

WMO: 714890

Lat: 52.3597N

Lon: 108.8347W

Elev: 2164

StdP: 13.58

Time Zone: -6.00 (W06)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.4	-21.0	-32.7	0.9	-26.3	-26.7	1.3	-20.9	25.5	15.1	22.4	12.2	5.1	290	0.694

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	85.1	63.5	81.4	62.3	78.0	61.0	67.4	78.7	65.4	76.3	63.4	73.9	10.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	95.3	72.2	61.5	88.4	70.1	59.4	82.0	67.9	33.2	78.7	31.5	76.3	29.9	73.9	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	19.9	17.6	-34.2	91.5	5.6	4.8	-38.3	95.0	-41.6	97.8	-44.7	100.5	-48.8	104.0
			-34.4	71.7	5.6	2.7	-38.4	73.7	-41.7	75.3	-44.9	76.8	-48.9	78.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.1	7.3	8.7	20.4	38.0	50.5	58.3	63.5	61.6	52.2	38.4	22.9	9.9
	DBStd	23.12	15.10	13.74	13.78	10.18	8.14	6.00	5.52	6.25	8.06	8.95	11.75	14.19
	HDD50	6368	1325	1156	917	372	96	7	0	2	67	371	813	1242
	HDD65	10639	1790	1576	1382	810	453	213	94	140	388	824	1262	1707
	CDD50	1306	0	0	0	13	110	257	419	362	133	12	0	0
	CDD65	102	0	0	0	0	2	12	48	35	5	0	0	0
	CDH74	1781	0	0	0	6	105	242	623	603	197	5	0	0
	CDH80	466	0	0	0	0	14	55	164	177	56	0	0	0
	WSAvg	8.3	7.8	7.5	8.9	9.7	9.6	8.5	7.6	7.5	8.1	8.5	8.0	7.3
	PrecAvg	15.3	0.7	0.5	0.8	1.0	1.5	2.7	2.6	1.9	1.3	0.6	0.7	0.8
Precipitation	PrecMax	19.4	2.2	1.2	1.7	3.0	4.4	9.9	6.3	3.9	3.5	2.0	1.5	1.6
	PrecMin	11.8	0.1	0.1	0.1	0.0	0.2	0.5	0.4	0.1	0.0	0.0	0.0	0.3
	PrecStd	1.7	0.5	0.3	0.4	0.7	0.8	1.7	1.3	1.0	0.9	0.5	0.4	0.4
	PrecStd	1.7	0.5	0.3	0.4	0.7	0.8	1.7	1.3	1.0	0.9	0.5	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.6	38.8	54.5	73.3	82.0	86.0	89.4	90.9	86.5	72.4	54.0	41.8
		MCWB	35.9	35.0	43.8	51.9	56.8	62.0	67.3	63.9	60.8	54.7	44.2	36.6
	2%	DB	36.0	35.1	46.1	66.4	76.9	80.2	84.5	84.8	79.6	63.9	46.6	37.5
		MCWB	33.1	32.5	39.8	49.1	54.8	60.4	66.2	62.7	58.2	49.7	40.4	34.0
	5%	DB	32.7	31.7	41.0	60.7	72.4	76.0	80.5	80.5	74.0	58.2	41.7	33.4
		MCWB	30.5	29.9	36.6	45.4	53.4	59.1	64.5	62.5	56.4	46.9	37.1	31.1
	10%	DB	28.4	28.1	37.1	55.5	67.9	72.4	76.9	76.6	68.4	53.0	37.6	28.9
		MCWB	26.9	26.6	34.3	43.1	51.3	57.2	63.2	60.9	53.9	44.5	34.6	27.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.0	35.6	45.0	53.7	60.0	66.8	71.8	68.4	63.0	55.7	45.3	37.1
		MCDB	38.9	38.5	52.8	69.9	75.6	78.9	83.9	79.9	79.3	69.7	52.2	40.5
	2%	WB	33.3	32.6	40.0	49.9	56.6	63.4	68.7	66.3	59.5	51.2	40.9	34.1
		MCDB	35.7	34.7	45.5	64.6	72.0	75.1	80.1	78.3	75.8	60.8	46.6	37.1
	5%	WB	30.4	29.9	36.8	46.9	54.6	61.1	66.6	64.3	57.2	47.8	37.5	31.0
		MCDB	32.6	31.6	40.5	58.5	69.6	72.2	77.1	76.0	71.4	56.4	40.7	33.4
	10%	WB	26.9	26.6	34.3	44.2	52.5	59.0	64.6	62.3	54.8	45.1	34.7	27.2
		MCDB	28.3	28.0	37.0	53.9	65.7	69.3	74.3	73.6	67.1	52.7	37.5	28.8
Mean Daily Temperature Range	5% DB	MDBR	17.1	17.7	17.4	21.4	24.2	21.3	22.2	23.7	24.1	20.5	16.0	16.2
		MCDBR	18.8	19.4	20.6	31.4	31.6	29.0	28.4	31.5	35.4	30.3	21.2	20.0
		MCWBR	16.6	17.4	14.9	16.7	14.5	12.7	13.4	13.6	16.3	17.6	15.1	17.2
	5% WB	MCDBR	18.8	19.1	19.7	29.3	27.7	24.1	25.3	26.1	31.5	28.0	19.7	19.5
		MCWBR	16.9	17.4	14.8	16.6	13.6	11.8	13.3	12.9	15.2	17.1	14.7	17.0
Clear-Sky Solar Irradiance	taub		0.262	0.259	0.288	0.341	0.363	0.376	0.373	0.383	0.323	0.284	0.257	0.230
	taud		2.257	2.332	2.401	2.327	2.312	2.319	2.355	2.301	2.441	2.530	2.451	2.371
	Ebn at Noon		235	278	290	284	281	278	277	266	273	267	243	236
	Edh at Noon		20	25	29	36	38	38	36	36	28	21	16	15
All-Sky Solar Radiation	RadAvg		348	683	1142	1509	1852	1901	2006	1624	1165	688	347	254
	RadStd		35	49	93	144	140	146	108	135	120	102	42	27

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-1.33	-1.57	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page