

SCOTT, SK, Canada

WMO: 714890

Lat: 52.3597N

Lon: 108.8347W

Elev: 660

StdP: 93.65

Time Zone: -6.00 (W06)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -32.5	(c) -29.5	(d) -36.0	(e) 0.1	(f) -32.4	(g) -32.6	(h) 0.2	(i) -29.4	(j) 11.4	(k) -9.4	(l) 10.0	(m) -11.0	(n) 2.3	(o) 290	(p) 0.694

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.3	(c) 29.5	(d) 17.5	(e) 27.4	(f) 16.8	(g) 25.6	(h) 16.1	(i) 19.7	(j) 26.0	(k) 18.5	(l) 24.6	(m) 17.4	(n) 23.3	(o) 4.8	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.5	13.6	22.3	16.4	12.6	21.2	15.2	11.7	19.9	59.3	25.9	55.3	24.6	51.7	23.3	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.2	(b) 8.9	(c) 7.9	(e) -36.8	(f) 33.1	(g) 3.1	(h) 2.7	(i) -39.1	(j) 35.0	(k) -40.9	(l) 36.6	(m) -42.6	(n) 38.1	(o) -44.9	(p) 40.0		
(4) 10.2	(5) 8.9	(6) 7.9	(7) -36.9	(8) 22.1	(9) 3.1	(10) 1.5	(11) -39.1	(12) 23.2	(13) -41.0	(14) 24.1	(15) -42.7	(16) 24.9	(17) -45.0	(18) 26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.3	-13.7	-12.9	-6.4	3.3	10.3	14.6	17.5	16.5	11.2	3.6	-5.0	-12.3	(6)
(7)		DBStd	12.84	8.39	7.63	7.66	5.66	4.52	3.34	3.07	3.47	4.48	4.97	6.53	7.88	(7)
(8)		HDD10.0	3538	736	642	509	207	53	4	0	1	37	206	452	690	(8)
(9)		HDD18.3	5911	994	876	768	450	252	118	52	78	216	458	701	948	(9)
(10)		CDD10.0	726	0	0	0	7	61	143	233	201	74	7	0	0	(10)
(11)		CDD18.3	57	0	0	0	0	1	7	27	19	3	0	0	0	(11)
(12)		CDH23.3	989	0	0	0	3	58	134	346	335	109	3	0	0	(12)
(13)		CDH26.7	259	0	0	0	0	8	31	91	98	31	0	0	0	(13)
(14)	Wind	WSAvg	3.7	3.5	3.4	4.0	4.4	4.3	3.8	3.4	3.3	3.6	3.8	3.6	3.3	(14)
(15)	Precipitation	PrecAvg	388	19	13	20	25	37	69	66	47	33	15	17	21	(15)
(16)		PrecMax	493	56	31	42	77	112	251	161	98	90	51	38	41	(16)
(17)		PrecMin	300	3	2	2	0	5	12	9	3	1	0	1	7	(17)
(18)		PrecStd	42	12	7	11	19	20	42	34	26	24	12	11	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	3.8	12.5	23.0	27.8	30.0	31.9	32.7	30.3	22.4	12.2	5.5	(19)
(20)			MCWB	2.2	1.7	6.6	11.1	13.8	16.7	19.6	17.7	16.0	12.6	6.8	2.6	(20)
(21)		2%	DB	2.2	1.7	7.8	19.1	25.0	26.8	29.2	29.3	26.4	17.7	8.1	3.0	(21)
(22)			MCWB	0.6	0.3	4.3	9.5	12.6	15.8	19.0	17.1	14.6	9.8	4.6	1.1	(22)
(23)		5%	DB	0.4	-0.2	5.0	15.9	22.5	24.5	27.0	26.9	23.3	14.5	5.4	0.8	(23)
(24)			MCWB	-0.8	-1.2	2.6	7.5	11.9	15.1	18.1	16.9	13.6	8.3	2.8	-0.5	(24)
(25)		10%	DB	-2.0	-2.2	2.9	13.0	20.0	22.4	25.0	24.8	20.2	11.7	3.1	-1.7	(25)
(26)			MCWB	-2.9	-3.0	1.3	6.2	10.7	14.0	17.4	16.1	12.2	7.0	1.4	-2.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	2.0	7.2	12.1	15.5	19.3	22.1	20.2	17.2	13.2	7.4	2.9	(27)
(28)			MCDWB	3.8	3.6	11.5	21.1	24.2	26.1	28.8	26.6	26.3	20.9	11.2	4.7	(28)
(29)		2%	WB	0.7	0.4	4.5	9.9	13.7	17.4	20.4	19.0	15.3	10.7	4.9	1.2	(29)
(30)			MCDWB	2.1	1.5	7.5	18.1	22.2	24.0	26.7	25.7	24.3	16.0	8.1	2.8	(30)
(31)		5%	WB	-0.9	-1.2	2.7	8.3	12.5	16.1	19.2	17.9	14.0	8.8	3.1	-0.6	(31)
(32)			MCDWB	0.4	-0.2	4.7	14.7	20.9	22.3	25.1	24.5	21.9	13.6	4.8	0.8	(32)
(33)		10%	WB	-2.9	-3.0	1.3	6.8	11.4	15.0	18.1	16.8	12.7	7.3	1.5	-2.7	(33)
(34)			MCDWB	-2.0	-2.2	2.8	12.1	18.7	20.7	23.5	23.1	19.5	11.5	3.1	-1.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	9.8	9.6	11.9	13.5	11.8	12.3	13.2	13.4	11.4	8.9	9.0	(35)
(36)			MCDBR	10.4	10.8	11.4	17.5	17.6	16.1	15.8	17.5	19.7	16.8	11.8	11.1	(36)
(37)			MCWBR	9.2	9.7	8.3	9.3	8.0	7.1	7.5	7.5	9.1	9.8	8.4	9.6	(37)
(38)		5% WB	MCDWR	10.4	10.6	10.9	16.3	15.4	13.4	14.1	14.5	17.5	15.6	10.9	10.9	(38)
(39)			MCWBR	9.4	9.6	8.2	9.2	7.5	6.5	7.4	7.2	8.5	9.5	8.1	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.262	0.259	0.288	0.341	0.363	0.376	0.373	0.383	0.323	0.284	0.257	0.230	(40)	
(41)		taud	2.257	2.332	2.401	2.327	2.312	2.319	2.355	2.301	2.441	2.530	2.451	2.371	(41)	
(42)		Ebn at Noon	740	875	914	894	887	876	872	840	862	841	766	744	(42)	
(43)		Edh at Noon	63	79	92	113	120	121	115	115	88	65	52	47	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.10	2.15	3.60	4.76	5.84	5.99	6.32	5.12	3.67	2.17	1.09	0.80	(44)	
(45)		RadStd	0.11	0.16	0.29	0.45	0.44	0.46	0.34	0.43	0.38	0.32	0.13	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-0.74	-0.87	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page