

FORT GOOD HOPE, NT, Canada

WMO: 714910

Lat: 66.242N

Lon: 128.644W

Elev: 268

StdP: 14.55

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-43.5	-38.4	-50.3	0.3	-41.8	-45.5	0.4	-37.0	17.6	5.0	14.6	5.1	0.8	90	0.717

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	83.3	62.5	79.3	60.9	75.8	59.3	64.4	78.7	62.6	75.6	61.0	72.9	7.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.4	76.3	67.8	57.5	71.3	66.2	55.7	66.7	65.0	29.7	78.9	28.4	76.2	27.2	72.9	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.9	13.5	11.7	DB	-46.0	88.4	4.5	3.6	-49.3	91.0	-51.9	93.1	-54.5	95.1	-57.8	97.7
			WB	-44.9	67.4	4.1	2.1	-47.9	68.9	-50.3	70.1	-52.6	71.2	-55.6	72.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	-13.9	-9.7	-1.3	21.2	42.8	59.4	62.8	55.9	43.4	24.7	0.1	-10.9	
	DBStd	30.26	15.26	13.78	13.03	12.04	10.33	7.61	6.72	7.54	7.79	9.72	12.02	13.51	
	HDD50	10811	1982	1671	1589	865	268	11	3	28	224	785	1497	1888	
	HDD65	15409	2447	2091	2054	1315	689	200	120	297	647	1249	1947	2353	
	CDD50	975	0	0	0	0	45	293	401	210	26	0	0	0	
	CDD65	99	0	0	0	0	0	32	53	14	0	0	0	0	
	CDH74	1167	0	0	0	0	30	393	572	171	1	0	0	0	
	CDH80	286	0	0	0	0	4	102	146	34	0	0	0	0	
Wind	WSAvg	4.5	3.0	3.4	4.4	5.2	5.8	5.8	5.4	5.2	5.0	4.3	3.4	3.0	
Precipitation	PrecAvg	13.0	0.7	0.7	0.6	0.5	0.7	1.5	2.0	2.0	1.6	1.1	0.9	0.7	
	PrecMax	17.7	1.7	2.0	1.3	1.4	2.1	2.4	4.1	3.5	2.8	1.8	1.8	1.5	
	PrecMin	9.2	0.2	0.2	0.1	0.0	0.1	0.4	0.8	0.9	1.0	0.5	0.4	0.2	
	PrecStd	1.7	0.4	0.4	0.3	0.3	0.4	0.6	0.8	0.7	0.4	0.3	0.4	0.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.4	27.9	40.5	58.7	78.2	88.1	89.6	84.4	70.3	52.5	32.5	26.7	
		MCWB	27.9	25.5	33.4	45.0	57.1	63.7	65.4	63.5	55.3	44.8	31.6	24.9	
	2%	DB	19.4	20.3	30.2	50.5	71.4	82.8	84.0	78.8	65.1	44.5	26.1	18.2	
		MCWB	18.3	18.9	26.2	40.9	54.1	61.1	63.1	62.3	52.6	40.3	25.1	17.5	
	5%	DB	12.7	14.4	23.1	45.1	66.2	78.3	80.0	74.3	61.4	40.2	21.0	12.8	
		MCWB	11.8	13.2	20.2	37.2	51.2	59.1	61.6	59.8	50.8	37.4	20.1	12.1	
	10%	DB	6.5	9.5	17.5	40.1	60.6	74.4	76.6	69.7	56.6	36.6	16.3	7.9	
		MCWB	5.8	8.6	15.3	34.2	48.1	57.3	60.4	57.9	48.9	34.6	15.5	7.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	26.0	35.6	44.1	57.9	65.7	67.2	66.4	56.8	45.8	32.0	25.0
			MCDB	30.8	27.9	40.0	55.6	76.3	83.8	83.0	79.0	67.3	50.7	33.1	26.7
2%		WB	18.0	19.2	27.3	40.5	54.4	62.9	64.8	63.5	53.8	40.8	25.8	17.7	
		MCDB	18.8	20.6	31.0	49.0	69.8	78.6	79.1	76.4	62.4	43.6	26.7	18.2	
5%		WB	11.9	13.7	20.5	37.2	51.6	60.8	63.2	61.1	51.5	37.7	20.6	12.3	
		MCDB	12.6	14.8	23.3	44.0	65.1	75.0	76.0	72.3	59.0	40.2	21.4	13.0	
10%		WB	5.9	9.0	15.4	34.2	48.7	58.7	61.8	58.9	49.4	34.9	15.8	7.6	
		MCDB	6.5	10.0	17.6	39.5	59.8	72.2	73.7	67.5	55.7	36.7	16.6	8.1	
Mean Daily Temperature Range		5% DB	MDBR	12.9	15.3	21.5	23.9	21.3	20.6	20.1	18.6	16.1	11.6	12.8	12.7
			MCDBR	19.8	19.3	28.1	27.5	29.5	26.2	26.4	26.6	25.3	15.1	14.5	16.5
	MCWBR		18.8	18.1	23.7	19.3	15.4	10.4	10.4	11.7	14.0	10.8	13.9	15.7	
	5% WB	MCDBR	19.6	19.0	27.0	26.2	28.4	23.1	22.9	23.3	22.6	13.7	14.2	16.4	
		MCWBR	18.8	18.1	22.6	18.1	15.2	9.6	10.0	11.1	12.9	10.3	13.8	15.9	
Clear-Sky Solar Irradiance	taub	0.152	0.224	0.254	0.306	0.337	0.345	0.366	0.342	0.299	0.251	0.159	0.156		
	taud	1.943	2.211	2.249	2.192	2.385	2.447	2.405	2.484	2.557	2.376	1.950	1.943		
	Ebn at Noon	103	214	262	271	274	274	263	259	249	202	89	15		
	Edh at Noon	5	15	24	34	31	30	31	26	19	13	4	1		
All-Sky Solar Radiation	RadAvg	31	234	796	1507	1804	1912	1613	1168	675	245	55	4		
	RadStd	3	15	35	64	147	138	111	108	66	24	5	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.60	N/A	N/A	N/A	N/A	N/A	-581	-637	N/A	N/A
(47) Regional (4 neighbors)		+1.26	+2.50	+2.39	N/A	N/A	N/A	-396	-365	N/A	N/A

Nomenclature: See separate page