

DUBAWNT LAKE, NU, Canada

WMO: 714999

Lat: 63.230N

Lon: 101.760W

Elev: 779

StdP: 14.29

Time Zone: -6.00 (NAC)

Period: 93-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -39.9	(c) -36.9	(d) -44.8	(e) 0.4	(f) -39.8	(g) -41.7	(h) 0.5	(i) -36.7	(j) 38.5	(k) -11.7	(l) 36.1	(m) -12.5	(n) 9.9	(o) 320	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	67.8	58.3	63.2	55.8	59.9	53.8	59.8	66.2	56.9	61.8	54.7	59.1	12.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.0	71.2	61.1	54.3	64.6	59.1	52.2	59.7	56.8	26.6	67.2	24.7	61.9	23.3	59.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 34.7	(b) 29.3	(c) 26.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 34.7	(b) 29.3	(c) 26.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	-20.6	-16.5	-11.3	5.2	22.5	41.2	50.5	51.1	41.9	23.2	3.7	-14.2		
	DBStd	28.03	12.28	11.43	12.78	12.49	10.47	6.27	6.49	6.12	8.00	10.05	11.39	13.40		
	HDD50	13024	2188	1863	1900	1345	851	271	73	61	262	830	1390	1990		
	HDD65	18292	2653	2283	2365	1795	1316	715	452	431	692	1295	1840	2455		
	CDD50	208	0	0	0	0	0	6	88	94	20	0	0	0		
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH74	14	0	0	0	0	0	0	6	4	4	0	0	0		
	CDH80	2	0	0	0	0	0	0	0	0	2	0	0	0		
	WSAvg	12.5	12.7	12.2	12.8	11.8	11.8	9.9	10.4	12.1	15.5	16.3	13.0	11.7		
	PrecAvg	11.9	0.4	0.4	0.6	0.5	0.7	1.1	1.9	2.2	1.8	1.2	0.7	0.5		
(15) Precipitation	PrecMax	17.0	0.8	0.9	1.6	1.5	1.5	2.7	3.7	3.7	2.9	1.9	1.6	0.9		
	PrecMin	8.1	0.1	0.1	0.1	0.2	0.2	0.4	0.8	0.9	0.5	0.4	0.2	0.2		
	PrecStd	1.7	0.2	0.2	0.3	0.3	0.4	0.6	0.7	0.7	0.7	0.3	0.3	0.2		
	PrecStd	1.7	0.2	0.2	0.3	0.3	0.4	0.6	0.7	0.7	0.7	0.3	0.3	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	17.0	29.8	35.1	45.8	65.4	74.4	73.3	62.0	45.4	31.8	19.0		
		MCWB	16.3	16.4	28.9	32.9	41.9	54.2	62.0	59.5	53.2	42.5	31.0	18.5		
	2%	DB	11.0	11.5	18.9	32.8	40.4	58.2	69.5	67.1	57.3	42.1	27.8	15.0		
		MCWB	10.4	10.8	18.4	31.3	37.7	49.8	59.1	57.4	51.4	40.0	27.2	14.3		
	5%	DB	5.0	7.7	12.1	29.6	37.3	54.4	65.0	62.3	54.3	39.2	24.0	11.9		
		MCWB	4.5	7.2	11.4	28.3	35.2	47.6	57.1	55.4	50.7	37.9	23.1	11.3		
	10%	DB	-1.1	2.6	7.5	25.5	35.1	50.8	61.7	59.4	51.9	36.8	21.3	6.3		
		MCWB	-1.8	2.2	6.8	24.5	33.5	45.7	55.2	54.3	49.0	35.6	20.6	5.6		
	0.4%	WB	16.4	16.7	28.5	33.3	42.2	55.1	65.5	61.1	55.6	43.1	31.3	18.7		
		MCDB	16.7	17.2	29.6	34.4	45.4	62.2	69.9	69.5	59.9	44.7	31.6	19.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	10.4	11.1	18.3	31.4	38.1	50.5	61.8	58.6	52.9	40.3	27.3	14.3		
		MCDB	11.0	11.6	18.8	32.7	39.9	56.5	66.6	64.3	56.0	41.7	27.8	14.8		
	5%	WB	4.5	7.3	11.5	28.3	35.5	48.1	58.2	56.6	51.1	37.9	23.1	11.4		
		MCDB	5.0	7.9	12.1	29.5	36.9	53.4	63.6	61.1	54.0	39.0	23.8	11.9		
	10%	WB	-1.8	2.1	6.8	24.7	33.6	45.9	55.4	54.8	49.3	35.7	20.5	5.8		
		MCDB	-1.2	2.6	7.4	25.7	35.1	50.5	60.1	58.9	51.9	37.1	21.2	6.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	14.1	14.5	16.3	11.9	14.3	15.7	10.7	8.8	8.6	11.7	11.9		
		MCDBR	18.2	20.0	18.1	17.5	11.9	21.3	20.7	16.2	12.7	7.9	14.3	16.6		
		MCWBR	17.9	19.6	17.8	16.4	9.6	13.6	11.6	8.5	7.4	6.8	14.1	16.4		
		MCDBR	18.3	20.2	18.2	17.8	11.6	20.1	17.7	14.8	12.6	7.4	14.4	16.9		
	5% WB	MCWBR	18.0	19.9	18.0	16.9	9.6	13.4	10.6	8.9	7.9	6.6	14.2	16.6		
		MCWBR	18.0	19.9	18.0	16.9	9.6	13.4	10.6	8.9	7.9	6.6	14.2	16.6		
(40) Clear-Sky Solar Irradiance	taub		0.176	0.236	0.252	0.303	0.318	0.341	0.349	0.326	0.301	0.256	0.178	0.147		
	taud		1.975	2.159	2.249	2.167	2.311	2.450	2.448	2.487	2.544	2.312	1.980	1.920		
	Ebn at Noon		154	229	274	278	284	279	273	271	258	220	146	97		
	Edh at Noon		10	19	27	36	35	31	30	27	21	16	9	4		
	RadAvg		71	317	886	1621	1977	1803	1687	1232	716	267	102	31		
(45) All-Sky Solar Radiation	RadStd		4	16	49	84	132	124	120	104	92	41	10	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page