

GLENEVIS AGCM, AB, Canada

WMO: 715000

Lat: 53.8325N

Lon: 114.5389W

Elev: 670

StdP: 93.53

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-29.1	-26.1	-32.6	0.2	-28.5	-29.6	0.3	-25.9	11.3	0.5	10.1	-2.0	1.7	200	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	27.2	17.0	25.7	16.2	24.1	15.6	18.7	24.8	17.5	23.6	16.5	22.4	2.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.3	12.6	21.9	15.0	11.6	20.2	14.0	10.8	19.2	55.7	24.6	51.9	23.8	48.8	22.6	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.4	7.1	-32.7	30.4	2.7	1.8	-34.7	31.7	-36.3	32.7	-37.8	33.8	-39.8	35.1		
(5)			-32.9	20.7	2.7	1.4	-34.8	21.7	-36.4	22.5	-37.9	23.3	-39.9	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-7.9	-9.0	-3.3	4.2	10.8	14.4	16.7	15.9	11.2	4.8	-3.3	-10.0	(6)
(7)		DBStd	11.42	8.88	8.79	7.72	5.04	4.48	3.13	2.77	3.14	4.50	4.90	6.95	7.97	(7)
(8)		HDD10.0	2962	556	532	413	183	44	4	0	1	39	173	399	619	(8)
(9)		HDD18.3	5344	814	766	671	424	234	122	65	86	216	421	648	877	(9)
(10)		CDD10.0	694	0	0	0	9	70	137	209	185	74	11	1	0	(10)
(11)		CDD18.3	34	0	0	0	0	2	4	16	11	1	0	0	0	(11)
(12)		CDH23.3	500	0	0	0	2	48	66	194	134	55	2	0	0	(12)
(13)		CDH26.7	72	0	0	0	0	5	7	32	19	9	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.1	3.0	2.9	3.6	3.3	2.9	2.7	2.5	2.7	3.1	2.7	2.9	(14)
(15)	Precipitation	PrecAvg	491	25	16	19	31	55	87	94	63	39	24	21	17	(15)
(16)		PrecMax	652	75	30	36	55	110	175	208	138	87	76	61	47	(16)
(17)		PrecMin	321	2	1	3	5	18	25	46	31	9	5	4	5	(17)
(18)		PrecStd	79	17	8	8	15	23	34	39	21	22	17	15	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	10.6	14.1	22.8	27.2	27.4	29.4	28.9	28.0	22.0	14.1	7.7	(19)
(20)			MCWB	3.9	4.8	6.1	11.2	13.7	16.1	18.2	17.8	16.3	12.1	7.4	2.7	(20)
(21)		2%	DB	7.5	6.7	10.6	18.4	24.5	25.2	27.2	26.5	24.8	16.9	9.3	5.0	(21)
(22)			MCWB	2.9	2.2	4.3	8.8	12.8	15.6	17.9	17.7	15.2	9.5	4.6	1.1	(22)
(23)		5%	DB	5.8	4.8	8.1	15.1	21.9	23.4	25.5	24.7	22.2	14.4	6.8	3.2	(23)
(24)			MCWB	2.1	1.2	2.9	6.6	11.5	14.5	16.7	16.9	14.0	8.0	3.3	0.0	(24)
(25)		10%	DB	3.8	2.9	5.9	12.4	19.7	21.5	23.8	23.0	19.2	12.1	4.7	0.9	(25)
(26)			MCWB	0.7	-0.1	1.7	5.4	10.3	13.8	16.2	16.0	12.7	6.7	1.8	-1.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	4.6	6.5	11.1	14.6	17.9	20.4	20.1	17.4	12.4	7.8	3.1	(27)
(28)			MCDWB	8.2	10.1	12.9	22.5	24.4	25.0	26.4	26.0	25.5	20.9	13.5	7.0	(28)
(29)		2%	WB	3.2	2.7	4.7	8.9	13.5	16.5	18.9	18.8	15.9	10.2	5.2	1.3	(29)
(30)			MCDWB	7.1	6.1	10.2	17.6	22.2	22.9	25.0	24.8	23.6	16.0	8.8	4.4	(30)
(31)		5%	WB	2.1	1.4	3.2	7.2	12.3	15.4	17.7	17.6	14.4	8.5	3.5	0.0	(31)
(32)			MCDWB	5.5	4.5	7.6	14.0	20.4	21.6	24.0	23.0	21.1	13.5	6.4	2.9	(32)
(33)		10%	WB	0.8	0.0	1.8	5.7	11.1	14.5	16.6	16.5	13.1	7.1	2.1	-1.6	(33)
(34)			MCDWB	3.7	2.8	5.6	11.4	18.6	20.3	22.5	21.9	18.5	11.3	4.4	0.6	(34)
(35)	Mean Daily Temperature Range	MDBR	8.8	9.3	9.9	10.3	12.1	11.3	11.4	11.4	11.6	9.0	7.6	8.1	(35)	
(36)		5% DB	MCDBR	8.2	10.1	12.0	15.1	15.9	14.1	14.3	14.6	16.9	12.7	9.6	9.5	(36)
(37)			MCWBR	5.5	7.0	6.9	7.8	7.1	6.3	6.5	6.9	8.4	6.9	6.2	7.1	(37)
(38)			MCDBR	8.3	9.7	11.7	14.0	14.8	12.6	13.3	13.3	16.0	12.3	9.1	9.8	(38)
(39)		5% WB	MCWBR	5.9	7.0	6.8	7.5	6.9	6.2	6.6	7.0	8.1	6.9	6.3	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.248	0.265	0.296	0.333	0.349	0.357	0.359	0.362	0.315	0.284	0.256	0.240	(40)	
(41)		taud	2.340	2.364	2.373	2.374	2.372	2.363	2.413	2.355	2.490	2.555	2.454	2.307	(41)	
(42)		Ebn at Noon	747	852	894	899	898	891	882	857	865	828	740	675	(42)	
(43)		Edh at Noon	54	74	92	106	112	115	107	107	82	62	48	45	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.92	1.93	3.38	4.62	5.55	5.88	5.97	4.95	3.43	1.96	0.96	0.66	(44)	
(45)		RadStd	0.07	0.15	0.24	0.41	0.42	0.41	0.37	0.35	0.35	0.21	0.09	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page