

PELLEY ISLAND, NT, Canada

WMO: 715020

Lat: 69.623N

Lon: 135.436W

Elev: 56

StdP: 14.67

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.8	-30.8	-43.8	0.4	-30.4	-40.2	0.5	-29.0	46.9	3.7	41.2	-1.7	9.0	110	1.094

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	65.6	59.2	61.4	56.3	57.7	53.8	59.7	65.2	57.0	61.1	54.1	57.5	13.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.0	69.5	62.7	54.3	62.9	59.7	51.9	57.5	56.9	26.3	64.8	24.5	61.3	22.8	57.5	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.0	29.8	26.6	-36.1	75.1	1.6	4.5	-37.3	78.4	-38.3	81.1	-39.2	83.6	-40.4	86.9		
(5)			-35.7	63.0	2.9	3.0	-37.8	65.1	-39.5	66.9	-41.1	68.6	-43.2	70.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	-12.5	-10.6	-9.0	6.6	24.4	37.5	48.1	46.0	37.6	22.9	3.5	-6.7		
	DBStd	24.10	12.05	11.89	11.10	11.19	8.33	6.42	7.83	7.24	6.42	8.28	10.31	10.63		
	HDD50	12610	1936	1698	1829	1303	794	382	132	169	374	841	1394	1758		
	HDD65	17960	2401	2118	2294	1753	1259	825	526	590	821	1306	1844	2223		
	CDD50	129	0	0	0	0	0	7	73	45	4	0	0	0		
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH74	11	0	0	0	0	0	1	9	1	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	13.2	13.4	14.1	12.5	12.4	13.1	11.9	13.2	13.5	14.2	14.4	13.1	12.9		
	PrecAvg	11.4	0.4	0.4	0.4	0.3	0.5	1.2	2.0	2.3	1.5	1.1	0.6	0.5		
(15) Precipitation	PrecMax	14.3	1.0	0.8	0.9	0.9	1.2	2.6	4.8	3.6	2.6	1.9	1.4	1.1		
	PrecMin	9.1	0.0	0.0	0.1	0.1	0.1	0.4	0.7	1.0	0.8	0.4	0.1	0.1		
	PrecStd	1.3	0.3	0.2	0.2	0.2	0.2	0.6	0.7	0.7	0.4	0.4	0.3	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	24.0	25.3	36.1	47.1	66.8	74.3	68.5	58.8	39.6	30.6	23.7		
		MCWB	24.5	23.4	24.2	34.3	42.0	56.5	62.0	60.9	52.0	37.9	29.6	22.4		
	2%	DB	18.2	16.6	17.9	32.3	39.9	58.3	67.7	63.3	53.0	36.1	26.4	16.6		
		MCWB	17.4	15.8	17.2	30.9	36.9	52.6	60.5	57.4	49.0	34.9	25.6	15.8		
	5%	DB	10.5	11.8	12.6	27.9	36.8	50.7	63.4	59.7	49.1	33.9	22.7	12.3		
		MCWB	9.8	11.2	11.8	26.9	34.7	46.5	58.3	55.2	46.6	32.8	21.8	11.4		
	10%	DB	3.9	6.6	6.8	23.3	34.5	45.9	59.4	56.0	46.3	32.0	18.6	8.3		
		MCWB	3.3	5.9	5.8	22.3	32.9	42.7	55.6	52.8	44.5	31.1	17.9	7.5		
	0.4%	WB	24.5	23.7	24.5	34.6	42.2	58.0	64.1	61.8	52.6	38.2	29.9	22.8		
		MCDB	25.4	24.1	25.5	36.0	46.9	66.1	70.7	67.1	57.4	39.3	30.9	23.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	17.2	15.8	17.7	31.2	37.3	52.5	61.2	58.4	49.5	35.1	25.5	16.2		
		MCDB	17.8	16.4	18.3	32.5	39.8	58.5	67.2	62.7	52.8	35.9	26.2	16.8		
	5%	WB	9.6	11.2	12.3	27.1	35.1	47.1	58.5	55.7	46.9	32.9	21.9	11.7		
		MCDB	10.3	11.7	13.0	28.1	36.8	50.8	63.3	59.2	49.1	33.7	22.6	12.4		
	10%	WB	3.3	6.1	6.6	22.7	33.3	43.1	55.9	53.2	44.7	31.2	18.1	8.0		
		MCDB	3.8	6.6	7.3	23.5	34.6	46.0	59.5	55.8	46.5	31.9	18.8	8.6		
	5% DB	MDBR	9.9	10.9	11.6	13.4	9.7	9.3	10.6	8.6	6.3	6.1	9.6	9.7		
		MCDBR	16.9	17.5	15.3	15.2	12.3	20.0	18.3	15.0	11.6	5.6	11.4	15.0		
		MCWBR	16.5	17.0	15.0	14.2	9.8	14.5	12.6	10.5	8.0	5.2	11.6	15.0		
		MCWBR	16.3	17.1	15.0	15.0	11.8	19.9	17.4	14.2	11.2	5.5	11.6	15.0		
(40) Clear-Sky Solar Irradiance	taub		0.161	0.206	0.240	0.303	0.342	0.342	0.363	0.335	0.294	0.232	N/A	N/A		
		taud	1.883	2.043	2.182	2.068	2.083	2.299	2.416	2.523	2.552	2.189	N/A	N/A		
	Ebn at Noon		10	176	251	261	263	269	259	255	238	162	0	0		
		Edh at Noon	1	13	23	36	41	34	30	24	17	11	0	0		
(44) All-Sky Solar Radiation	RadAvg		4	125	642	1361	1913	2061	1627	1006	516	155	0	0		
	RadStd		0	7	31	75	120	148	128	89	48	20	0	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (10 neighbors)		+1.69	+2.70	+3.40	N/A	N/A	N/A	-634	-643	N/A	N/A	

Nomenclature: See separate page