

DELINE, NT, Canada

WMO: 715030

Lat: 65.2086N

Lon: 123.4333W

Elev: 698

StdP: 14.33

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.7	-33.4	-45.6	0.4	-37.1	-41.0	0.5	-33.2	23.4	-2.3	21.0	-5.1	3.1	320	0.834

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	76.0	60.1	71.8	58.1	68.3	56.4	61.3	73.0	59.4	69.4	57.5	66.2	9.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	70.0	64.6	54.7	65.3	63.2	52.7	60.7	62.0	27.7	72.9	26.3	69.5	25.1	66.3	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	18.5	16.5	-42.4	82.6	3.4	3.2	-44.8	84.9	-46.8	86.7	-48.7	88.5	-51.1	90.8
			-42.5	65.2	3.5	2.7	-45.1	67.1	-47.2	68.6	-49.2	70.1	-51.7	72.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.6	-11.3	-8.6	-1.6	17.9	37.5	50.9	56.1	52.0	41.6	26.4	4.2	-7.4		
	DBStd	26.82	13.42	11.96	13.67	12.22	9.81	7.66	6.08	7.16	7.53	7.98	11.12	12.43		
	HDD50	10809	1900	1641	1600	964	400	80	14	61	266	731	1373	1779		
	HDD65	15840	2365	2061	2065	1413	853	425	284	409	702	1196	1823	2244		
	CDD50	457	0	0	0	0	12	108	202	121	14	0	0	0		
	CDD65	13	0	0	0	0	0	2	7	4	0	0	0	0		
	CDH74	194	0	0	0	0	0	45	100	49	0	0	0	0		
	CDH80	23	0	0	0	0	0	5	14	4	0	0	0	0		
	WSAvg	7.5	7.5	7.4	7.8	8.0	7.9	7.2	6.9	7.4	7.7	7.2	7.2	7.4		
	PrecAvg	11.5	0.6	0.6	0.4	0.4	0.7	1.4	1.8	1.9	1.4	1.0	0.7	0.6		
	PrecMax	15.0	1.1	2.9	1.3	1.4	2.2	2.5	2.9	3.1	2.4	1.5	1.5	1.0		
(15) Precipitation	PrecMin	8.4	0.2	0.2	0.1	0.1	0.1	0.5	0.7	0.8	0.8	0.6	0.4	0.2		
	PrecStd	1.7	0.2	0.5	0.2	0.3	0.4	0.6	0.6	0.6	0.4	0.2	0.2	0.2		
	DB	31.4	27.4	39.2	51.4	69.3	79.2	82.0	79.2	66.8	49.9	31.5	26.2			
	MCWB	28.4	25.4	33.4	42.1	53.0	59.5	62.1	62.1	53.1	44.1	30.1	24.7			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	22.1	18.6	31.4	44.7	62.6	73.7	76.5	73.9	61.7	43.0	26.0	19.9			
	2% MCWB	20.7	17.0	27.9	37.4	49.4	57.5	60.9	60.0	50.9	39.3	25.0	19.0			
	5% DB	13.7	13.9	24.6	40.1	57.8	69.5	72.7	68.6	57.8	39.3	22.6	15.6			
	5% MCWB	12.9	12.8	22.1	34.5	46.5	55.4	59.1	57.6	49.7	36.8	21.8	14.8			
	10% DB	6.4	8.8	18.6	35.8	52.8	65.7	69.1	64.4	53.9	36.4	19.9	11.7			
	10% MCWB	5.6	7.9	16.7	31.9	43.4	53.5	57.8	55.1	47.5	34.4	19.1	11.1			
	WB	28.6	25.6	34.2	42.2	53.5	61.5	64.0	63.7	55.5	45.4	30.7	24.8			
	MCDB	30.8	27.6	38.5	50.6	68.0	75.3	76.2	76.4	61.7	48.8	31.8	26.4			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	20.8	17.1	27.7	37.8	49.9	58.5	62.1	60.4	52.2	39.8	25.2	19.1			
	2% MCDB	22.1	18.5	31.3	44.0	61.4	70.5	73.8	71.6	59.7	42.4	26.0	19.8			
	5% WB	12.8	13.0	22.1	34.9	46.8	56.3	60.4	58.1	50.0	36.9	21.9	14.9			
	5% MCDB	13.6	14.1	24.5	39.7	56.9	67.5	70.9	66.8	56.9	39.1	22.6	15.5			
	10% WB	5.7	7.9	16.7	32.1	43.8	54.3	58.6	56.0	47.8	34.3	19.0	11.1			
	10% MCDB	6.4	8.7	18.5	35.7	52.2	64.8	67.2	63.2	53.5	35.8	19.7	11.8			
	MDBR	13.2	16.1	19.7	19.8	17.5	20.5	20.2	17.1	15.0	10.3	13.3	12.8			
	5% DB	18.7	21.5	23.7	20.4	25.8	26.6	27.0	24.4	22.1	13.9	13.8	15.1			
(36) Mean Daily Temperature Range	MCWBR	17.8	20.7	20.4	14.6	15.1	14.6	14.2	13.5	13.1	10.6	13.7	14.8			
	MCDBR	18.7	21.9	22.7	18.9	24.8	24.9	24.0	22.3	20.7	13.4	14.1	14.9			
	MCWBR	17.8	20.8	19.4	13.6	14.9	14.7	13.6	12.9	12.6	10.1	13.7	14.7			
	MCDBR	18.7	21.9	22.7	18.9	24.8	24.9	24.0	22.3	20.7	13.4	14.1	14.9			
(40) Clear-Sky Solar Irradiance	taub	0.150	0.235	0.250	0.299	0.344	0.348	0.378	0.340	0.300	0.252	0.158	0.150			
	taud	1.943	2.182	2.258	2.222	2.358	2.414	2.380	2.481	2.550	2.387	1.945	1.950			
	Ebn at Noon	131	215	268	276	273	274	261	262	252	211	116	41			
	Edh at Noon	6	17	25	34	33	32	32	26	20	14	6	2			
(44) All-Sky Solar Radiation	RadAvg	44	272	836	1539	1833	1940	1663	1217	706	244	59	11			
	RadStd	4	14	42	71	121	140	106	98	55	26	6	1			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+2.00	+3.31	+4.07	N/A	N/A	N/A	-457	-680	N/A	N/A
(47) Regional (2 neighbors)		+1.21	+2.34	+2.32	N/A	N/A	N/A	-396	-378	N/A	N/A

Nomenclature: See separate page