

DELINE, NT, Canada

WMO: 715030

Lat: 65.2086N

Lon: 123.4333W

Elev: 213

StdP: 98.79

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -38.7	(c) -36.3	(d) -43.1	(e) 0.1	(f) -38.4	(g) -40.6	(h) 0.1	(i) -36.2	(j) 10.5	(k) -19.1	(l) 9.4	(m) -20.6	(n) 1.4	(o) 320	(p) 0.834

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	24.5	15.6	22.1	14.5	20.2	13.5	16.3	22.8	15.2	20.8	14.2	19.0	4.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	10.0	18.1	12.6	9.3	17.4	11.5	8.7	16.6	46.5	22.7	43.3	20.9	40.4	19.0	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.3	(b) 8.3	(c) 7.4	(e) -41.3	(f) 28.1	(g) 1.9	(h) 1.8	(i) -42.7	(j) 29.4	(k) -43.8	(l) 30.4	(m) -44.8	(n) 31.4	(o) -46.2	(p) 32.7		
(a) 9.3	(b) 8.3	(c) 7.4	(e) -41.4	(f) 18.4	(g) 2.0	(h) 1.5	(i) -42.8	(j) 19.5	(k) -44.0	(l) 20.3	(m) -45.1	(n) 21.2	(o) -46.5	(p) 22.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.8	-24.1	-22.6	-18.7	-7.8	3.0	10.5	13.4	11.1	5.3	-3.1	-15.4	-21.9		
	DBStd	14.90	7.45	6.65	7.60	6.79	5.45	4.26	3.38	3.98	4.18	4.43	6.18	6.91		
	HDD10.0	6005	1056	912	889	536	222	44	8	34	148	406	763	988		
	HDD18.3	8800	1314	1145	1147	785	474	236	158	227	390	664	1013	1247		
	CDD10.0	254	0	0	0	0	7	60	112	67	8	0	0	0		
	CDD18.3	7	0	0	0	0	0	1	4	2	0	0	0	0		
	CDH23.3	108	0	0	0	0	0	25	56	27	0	0	0	0		
	CDH26.7	13	0	0	0	0	0	3	8	2	0	0	0	0		
(14) Wind	WSAvg	3.3	3.4	3.3	3.5	3.6	3.5	3.2	3.1	3.3	3.4	3.2	3.2	3.3		
(15) Precipitation	PrecAvg	291	15	15	11	11	18	35	45	48	35	25	19	14		
	PrecMax	380	29	74	32	36	56	64	74	79	61	37	37	26		
	PrecMin	213	4	5	2	2	3	13	19	20	21	14	10	6		
	PrecStd	42	6	12	6	7	10	14	14	15	9	6	6	5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.3	-2.6	4.0	10.8	20.7	26.2	27.8	26.2	19.3	10.0	-0.3	-3.2		
		MCWB	-2.0	-3.7	0.8	5.6	11.6	15.3	16.7	16.7	11.7	6.7	-1.0	-4.0		
	2%	DB	-5.5	-7.5	-0.4	7.1	17.0	23.2	24.7	23.3	16.5	6.1	-3.3	-6.7		
		MCWB	-6.3	-8.3	-2.3	3.0	9.7	14.2	16.0	15.5	10.5	4.1	-3.9	-7.2		
	5%	DB	-10.2	-10.0	-4.1	4.5	14.3	20.9	22.6	20.3	14.3	4.1	-5.2	-9.1		
		MCWB	-10.6	-10.7	-5.5	1.4	8.1	13.0	15.0	14.2	9.8	2.7	-5.7	-9.5		
	10%	DB	-14.2	-12.9	-7.4	2.1	11.6	18.7	20.6	18.0	12.2	2.4	-6.7	-11.3		
		MCWB	-14.7	-13.4	-8.5	-0.1	6.3	11.9	14.3	12.9	8.6	1.3	-7.2	-11.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.9	-3.5	1.2	5.7	12.0	16.4	17.8	17.6	13.1	7.5	-0.7	-4.0		
		MCDB	-0.7	-2.4	3.6	10.3	20.0	24.0	24.6	24.7	16.5	9.3	-0.1	-3.1		
	2%	WB	-6.2	-8.3	-2.4	3.2	9.9	14.7	16.7	15.8	11.2	4.4	-3.8	-7.2		
		MCDB	-5.5	-7.5	-0.4	6.7	16.3	21.4	23.2	22.0	15.4	5.8	-3.3	-6.8		
	5%	WB	-10.6	-10.6	-5.5	1.6	8.2	13.5	15.8	14.5	10.0	2.7	-5.6	-9.5		
		MCDB	-10.2	-9.9	-4.2	4.3	13.8	19.7	21.6	19.3	13.8	3.9	-5.2	-9.1		
	10%	WB	-14.6	-13.4	-8.5	0.0	6.6	12.4	14.8	13.4	8.8	1.3	-7.2	-11.6		
		MCDB	-14.2	-12.9	-7.5	2.1	11.2	18.2	19.6	17.3	11.9	2.1	-6.8	-11.2		
(35) Mean Daily Temperature Range	MDBR		7.3	8.9	11.0	11.0	9.7	11.4	11.2	9.5	8.3	5.7	7.4	7.1		
	5% DB	MCDBR	10.4	12.0	13.2	11.3	14.4	14.8	15.0	13.6	12.3	7.7	7.7	8.4		
		MCWBR	9.9	11.5	11.3	8.1	8.4	8.1	7.9	7.5	7.3	5.9	7.6	8.2		
	5% WB	MCDBR	10.4	12.1	12.6	10.5	13.8	13.8	13.3	12.4	11.5	7.4	7.8	8.3		
		MCWBR	9.9	11.6	10.8	7.6	8.3	8.2	7.6	7.2	7.0	5.6	7.6	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.150	0.235	0.250	0.299	0.344	0.348	0.378	0.340	0.300	0.252	0.158	0.150		
	taud		1.943	2.182	2.258	2.222	2.358	2.414	2.380	2.481	2.550	2.387	1.945	1.950		
	Ebn at Noon		414	677	846	870	861	865	822	827	795	665	365	130		
	Edh at Noon		20	53	79	106	103	100	101	83	62	43	19	6		
(44) All-Sky Solar Radiation	RadAvg		0.14	0.86	2.64	4.85	5.78	6.12	5.24	3.84	2.23	0.77	0.18	0.04		
	RadStd		0.01	0.04	0.13	0.22	0.38	0.44	0.33	0.31	0.17	0.08	0.02	0.00		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.11	+1.84	+2.26	N/A	N/A	N/A	-254	-378	N/A	N/A
(47) Regional (2 neighbors)		+0.67	+1.30	+1.29	N/A	N/A	N/A	-220	-210	N/A	N/A

Nomenclature: See separate page