

HAINES JUNCTION, YT, CanadaWMO: **715050**Lat: **60.773N**Lon: **137.580W**Elev: **1953**StdP: **13.69**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.8	-35.1	-48.9	0.3	-39.7	-42.4	0.5	-33.8	16.4	14.2	14.2	18.4	1.4	80	0.716

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	76.7	56.4	72.8	54.8	69.3	53.2	58.4	73.0	56.4	69.4	54.6	66.5	6.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.3	62.5	60.3	50.1	57.7	59.3	48.3	53.8	57.8	26.1	73.7	24.8	69.7	23.6	66.7	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.0	13.3	11.5	DB	-46.1	81.5	5.3	4.2	-49.9	84.5	-53.0	86.9	-56.0	89.3	-59.8	92.3	
			WB	-44.7	60.9	4.0	2.3	-47.6	62.5	-49.9	63.9	-52.2	65.2	-55.1	66.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.6	-0.2	8.3	18.1	33.3	44.3	52.5	55.7	52.7	44.1	31.4	10.4	2.6	
	DBStd	23.14	20.16	15.74	13.35	7.53	5.65	5.62	4.68	5.25	5.55	8.99	15.17	18.03	
	HDD50	7904	1557	1167	988	502	195	35	7	31	189	577	1187	1469	
	HDD65	12943	2022	1587	1453	952	642	376	289	383	626	1042	1637	1934	
	CDD50	441	0	0	0	0	18	111	185	114	12	1	0	0	
	CDD65	3	0	0	0	0	0	2	1	0	0	0	0	0	
	CDH74	235	0	0	0	0	8	69	82	76	0	0	0	0	
	CDH80	31	0	0	0	0	0	14	7	10	0	0	0	0	
Wind	WSAvg	3.8	2.7	2.9	4.0	4.5	5.5	5.2	4.9	4.1	3.7	3.1	2.8	2.6	
Precipitation	PrecAvg	13.1	1.3	0.8	0.4	0.4	0.7	1.2	1.5	1.2	1.4	1.5	1.3	1.2	
	PrecMax	17.0	4.1	1.9	1.0	1.4	1.7	2.3	3.5	3.1	2.6	3.4	2.6	2.6	
	PrecMin	9.2	0.3	0.1	0.0	0.0	0.0	0.2	0.2	0.2	0.1	0.6	0.2	0.3	
	PrecStd	2.5	0.9	0.5	0.3	0.4	0.5	0.6	0.8	0.7	0.7	0.8	0.7	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.7	43.2	49.1	62.2	74.5	81.7	80.6	81.0	67.3	57.4	43.9	44.7	
		MCWB	36.0	35.5	38.8	46.4	51.3	58.4	58.7	59.8	51.9	46.0	37.4	38.6	
	2%	DB	39.0	39.2	43.9	54.9	69.0	75.0	76.1	75.1	62.6	51.3	38.8	38.8	
		MCWB	33.7	33.0	35.4	41.4	49.7	54.2	56.9	57.2	49.9	42.4	34.0	34.7	
	5%	DB	35.0	35.9	40.8	49.9	63.6	70.9	72.5	70.1	59.5	47.4	35.2	34.8	
		MCWB	31.0	31.1	33.1	38.4	47.2	52.9	55.5	54.5	48.2	40.2	32.1	31.5	
	10%	DB	29.8	31.9	37.5	46.8	59.1	67.0	68.8	66.0	56.9	44.1	31.3	29.5	
		MCWB	27.3	28.3	31.1	36.8	45.0	51.5	54.1	52.9	46.7	38.3	28.9	27.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.0	36.5	39.7	47.1	53.5	59.4	60.9	61.3	53.9	47.6	38.1	39.3
			MCDB	42.7	42.2	47.7	62.0	70.4	77.4	74.9	78.1	62.6	55.4	42.9	43.7
2%		WB	34.3	33.9	36.1	41.9	50.3	56.3	58.7	58.1	51.2	43.7	34.7	34.9	
		MCDB	38.3	38.2	43.1	53.2	67.0	71.4	72.0	73.4	60.2	49.6	38.2	38.1	
5%		WB	31.4	31.3	33.6	39.3	48.1	54.2	56.7	55.6	49.3	41.1	32.1	31.6	
		MCDB	35.1	35.6	40.2	48.6	62.1	67.9	69.1	68.1	57.8	46.1	35.2	34.6	
10%		WB	27.2	27.9	31.3	37.3	45.8	52.3	55.1	53.6	47.6	38.6	28.8	27.0	
		MCDB	30.2	31.8	37.1	45.8	57.8	64.8	66.7	63.9	55.4	43.5	31.2	29.5	
Mean Daily Temperature Range	5% DB	MDBR	17.5	24.3	26.2	23.0	24.3	24.6	23.6	24.4	22.8	18.4	17.0	17.3	
		MCDBR	20.9	23.1	24.6	27.9	34.6	31.6	30.6	33.4	28.3	22.5	20.0	21.0	
		MCWBR	16.4	17.8	17.1	16.2	17.8	14.9	14.5	17.4	17.0	14.8	16.1	16.9	
	5% WB	MCDBR	19.7	21.8	22.9	25.4	31.2	27.5	26.9	29.3	25.4	19.8	19.1	21.0	
		MCWBR	15.6	17.0	15.9	15.2	16.4	13.6	13.4	15.4	15.6	13.7	15.5	17.0	
Clear-Sky Solar Irradiance	taub	0.255	0.266	0.279	0.357	0.379	0.385	0.380	0.370	0.318	0.287	0.230	0.194		
	taud	1.974	2.167	2.192	1.978	2.154	2.263	2.319	2.350	2.460	2.295	2.034	1.942		
	Ebn at Noon	142	230	268	260	266	267	266	259	256	219	155	121		
	Edh at Noon	15	22	30	46	42	38	36	32	24	19	13	9		
All-Sky Solar Radiation	RadAvg	109	372	903	1510	1827	1809	1662	1305	813	393	141	60		
	RadStd	8	30	58	73	94	99	93	94	65	34	12	4		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+3.04	+2.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	+2.84	+3.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page