

HAINES JUNCTION, YT, CanadaWMO: **715050**Lat: **60.773N**Lon: **137.580W**Elev: **595**StdP: **94.37**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.0	-37.3	-44.9	0.0	-39.8	-41.4	0.1	-36.6	7.3	-9.9	6.3	-7.5	0.6	80	0.716

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	24.8	13.5	22.7	12.7	20.7	11.8	14.7	22.8	13.5	20.8	12.6	19.2	3.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
11.3	8.9	15.7	10.1	8.2	15.1	9.1	7.7	14.3	42.8	23.2	39.7	20.9	37.1	19.3	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.7	5.9	5.2	-43.4	27.5	2.9	2.3	-45.5	29.2	-47.2	30.5	-48.9	31.8	-51.0	33.5		
(5)			-42.6	16.0	2.2	1.3	-44.2	17.0	-45.5	17.7	-46.8	18.4	-48.4	19.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.4	-17.9	-13.2	-7.7	0.7	6.8	11.4	13.2	11.5	6.7	-0.3	-12.0	-16.3
	DBStd	12.86	11.20	8.75	7.42	4.18	3.14	3.12	2.60	2.92	3.09	4.99	8.43	10.01
	HDD10.0	4391	865	648	549	279	108	19	4	17	105	321	659	816
	HDD18.3	7191	1123	882	807	529	357	209	161	213	348	579	909	1074
	CDD10.0	245	0	0	0	0	10	62	103	63	7	1	0	0
	CDD18.3	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDH23.3	131	0	0	0	0	4	38	46	42	0	0	0	0
	CDH26.7	17	0	0	0	0	0	8	4	6	0	0	0	0
Wind	WSAvg	1.7	1.2	1.3	1.8	2.0	2.4	2.3	2.2	1.9	1.7	1.4	1.2	1.2
Precipitation	PrecAvg	334	32	20	10	10	17	30	37	31	35	38	32	30
	PrecMax	432	105	49	25	35	44	59	89	80	67	87	65	65
	PrecMin	233	8	3	0	0	0	5	6	5	2	14	6	7
	PrecStd	63	22	13	7	9	12	15	21	17	19	20	19	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	6.2	9.5	16.8	23.6	27.6	27.0	27.2	19.6	14.1	6.6	7.1
		MCWB	2.2	1.9	3.8	8.0	10.7	14.7	14.8	15.5	11.1	7.8	3.0	3.7
	2%	DB	3.9	4.0	6.6	12.7	20.6	23.9	24.5	24.0	17.0	10.7	3.8	3.8
		MCWB	1.0	0.5	1.9	5.2	9.8	12.3	13.9	14.0	9.9	5.8	1.1	1.5
	5%	DB	1.6	2.1	4.9	10.0	17.6	21.6	22.5	21.2	15.3	8.6	1.8	1.6
		MCWB	-0.5	-0.5	0.6	3.5	8.5	11.6	13.1	12.5	9.0	4.6	0.1	-0.3
	10%	DB	-1.2	-0.1	3.1	8.2	15.0	19.4	20.4	18.9	13.8	6.7	-0.4	-1.4
		MCWB	-2.6	-2.1	-0.5	2.7	7.2	10.9	12.3	11.6	8.2	3.5	-1.7	-2.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	2.5	4.3	8.4	11.9	15.2	16.1	16.3	12.2	8.7	3.4	4.1
		MCDB	6.0	5.7	8.7	16.6	21.3	25.2	23.8	25.6	17.0	13.0	6.0	6.5
	2%	WB	1.3	1.1	2.3	5.5	10.2	13.5	14.8	14.5	10.6	6.5	1.5	1.6
		MCDB	3.5	3.4	6.2	11.8	19.4	21.9	22.2	23.0	15.7	9.8	3.4	3.4
	5%	WB	-0.3	-0.4	0.9	4.0	8.9	12.3	13.7	13.1	9.6	5.0	0.1	-0.2
		MCDB	1.7	2.0	4.5	9.2	16.7	20.0	20.6	20.1	14.4	7.8	1.8	1.5
	10%	WB	-2.6	-2.3	-0.4	2.9	7.7	11.3	12.8	12.0	8.7	3.7	-1.8	-2.8
		MCDB	-1.0	-0.1	2.8	7.7	14.3	18.2	19.3	17.7	13.0	6.4	-0.5	-1.4
Mean Daily Temperature Range	5% DB	MDBR	9.7	13.5	14.5	12.8	13.5	13.7	13.1	13.6	12.7	10.2	9.4	9.6
		MCDBR	11.6	12.9	13.7	15.5	19.2	17.6	17.0	18.5	15.7	12.5	11.1	11.7
		MCWBR	9.1	9.9	9.5	9.0	9.9	8.3	8.1	9.7	9.5	8.2	8.9	9.4
	5% WB	MCDBR	11.0	12.1	12.7	14.1	17.3	15.3	15.0	16.3	14.1	11.0	10.6	11.7
		MCWBR	8.7	9.4	8.8	8.5	9.1	7.6	7.5	8.6	8.7	7.6	8.6	9.4
Clear-Sky Solar Irradiance	taub	0.255	0.266	0.279	0.357	0.379	0.385	0.380	0.370	0.318	0.287	0.230	0.194	
	taud	1.974	2.167	2.192	1.978	2.154	2.263	2.319	2.350	2.460	2.295	2.034	1.942	
	Ebn at Noon	448	724	846	821	838	842	837	815	807	691	490	382	
	Edh at Noon	46	70	95	145	132	121	112	100	75	61	40	27	
All-Sky Solar Radiation	RadAvg	0.34	1.17	2.85	4.76	5.76	5.70	5.24	4.11	2.56	1.24	0.45	0.19	
	RadStd	0.02	0.10	0.18	0.23	0.30	0.31	0.29	0.30	0.21	0.11	0.04	0.01	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+1.69	+1.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	+1.58	+1.90	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page