

INDIAN HEAD, SK, Canada

WMO: 715150

Lat: 50.550N

Lon: 103.650W

Elev: 579

StdP: 94.56

Time Zone: -6.00 (W06)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.7	-30.1	-36.1	0.1	-32.6	-33.3	0.2	-30.1	14.5	-6.9	13.3	-8.6	3.9	290	0.748

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	29.9	19.0	28.0	18.3	26.2	17.4	21.6	26.4	20.2	25.2	19.0	24.0	5.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.8	24.3	18.4	14.3	22.8	17.1	13.1	21.5	66.0	26.4	60.7	25.2	56.4	23.9	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	11.1	9.9	DB	-37.0	33.6	2.7	2.1	-39.0	35.2	-40.6	36.4	-42.1	37.6	-44.0	39.1	(4)
(5)			WB	-37.1	24.3	2.7	1.9	-39.1	25.6	-40.6	26.7	-42.2	27.8	-44.1	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.4	-14.5	-13.1	-6.6	3.0	10.2	15.2	17.7	17.0	12.0	4.1	-4.9	-12.3	(6)	
	DBStd	13.25	8.74	7.99	7.99	6.09	4.93	3.59	3.05	3.57	4.66	5.29	7.13	8.18	(7)	
	HDD10.0	3566	759	646	513	218	59	3	0	1	31	194	448	693	(8)	
	HDD18.3	5893	1018	879	772	459	256	104	49	69	195	442	698	951	(9)	
	CDD10.0	790	0	0	0	8	64	161	238	218	91	11	0	0	(10)	
	CDD18.3	76	0	0	0	0	3	12	29	28	5	0	0	0	(11)	
	CDH23.3	1207	0	0	0	4	79	169	365	444	140	6	0	0	(12)	
	CDH26.7	314	0	0	0	0	16	37	81	142	39	1	0	0	(13)	
(14) Wind	WSAvg	4.8	5.1	4.8	5.0	5.1	5.3	4.7	3.9	3.9	4.6	4.9	4.9	4.9	(14)	
(15) Precipitation	PrecAvg	444	22	18	25	28	56	69	66	51	44	27	18	24	(15)	
	PrecMax	618	49	58	84	102	129	190	180	169	97	74	45	50	(16)	
	PrecMin	238	4	3	3	2	5	11	10	3	5	0	3	6	(17)	
	PrecStd	86	11	12	19	22	34	41	44	41	27	22	11	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.8	4.1	12.9	23.2	28.7	30.4	31.2	33.0	30.5	23.7	14.5	5.6	(19)	
		MCWB	2.0	2.2	7.7	11.3	15.1	18.9	21.5	19.1	17.0	13.1	7.8	2.3	(20)	
	2%	DB	2.1	1.9	9.0	19.3	25.6	27.2	28.9	30.3	27.4	19.0	9.3	2.8	(21)	
		MCWB	0.7	0.6	4.9	9.8	13.2	17.1	20.6	18.7	16.1	10.9	5.2	1.1	(22)	
	5%	DB	0.2	0.2	5.5	16.3	22.8	25.1	27.0	27.9	24.3	15.4	6.4	0.8	(23)	
		MCWB	-0.7	-0.6	3.2	8.2	12.1	16.3	20.1	18.2	14.8	9.0	3.4	-0.3	(24)	
	10%	DB	-2.2	-1.8	2.9	13.4	20.1	23.1	25.3	25.7	21.3	12.3	4.0	-1.4	(25)	
		MCWB	-2.9	-2.5	1.5	6.9	10.9	15.4	19.0	17.3	13.4	7.6	2.1	-2.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	2.6	7.9	12.5	16.7	21.9	24.4	22.2	19.1	14.1	8.3	2.6	(27)	
		MCDB	3.6	4.0	11.9	20.6	23.7	26.8	28.5	27.5	26.3	20.4	14.0	4.8	(28)	
	2%	WB	0.8	0.7	5.4	10.6	14.5	19.2	22.5	20.5	17.2	11.5	5.5	1.2	(29)	
		MCDB	2.0	1.7	8.6	17.8	21.8	24.0	26.7	26.8	24.8	18.2	8.8	2.6	(30)	
	5%	WB	-0.8	-0.6	3.2	9.1	13.2	17.7	21.0	19.4	15.6	9.6	3.7	-0.3	(31)	
		MCDB	0.1	0.2	5.3	15.1	20.2	22.5	25.6	25.6	22.5	14.3	6.0	0.9	(32)	
	10%	WB	-2.9	-2.4	1.6	7.5	12.0	16.4	19.7	18.2	14.0	8.0	2.1	-2.2	(33)	
		MCDB	-2.3	-1.8	2.9	12.5	18.6	21.1	24.1	23.9	20.2	12.0	3.9	-1.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	9.9	10.0	12.3	13.8	11.9	12.8	14.3	13.8	11.4	9.5	9.0	(35)	
		MCDBR	10.0	8.9	11.4	17.7	18.0	15.7	15.4	17.9	18.8	16.8	12.9	10.1	(36)	
	5% WB	MCWBR	9.2	7.9	8.1	9.6	8.3	7.7	8.6	8.1	8.6	9.4	8.9	8.7	(37)	
		MCWBR	10.2	8.7	10.8	16.2	15.0	12.6	13.9	15.4	16.7	15.8	12.2	10.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.247	0.268	0.273	0.332	0.343	0.353	0.365	0.378	0.327	0.282	0.251	0.241	(40)	
		taud	2.311	2.278	2.453	2.379	2.402	2.410	2.392	2.341	2.466	2.555	2.492	2.354	(41)	
	Ebn at Noon	Ebn at Noon	804	875	946	912	913	903	885	853	869	863	812	761	(42)	
		Edh at Noon	64	87	89	109	111	111	112	112	88	67	54	53	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.27	2.31	3.66	4.87	5.82	5.98	6.47	5.14	3.87	2.26	1.23	0.90	(44)	
	RadStd	RadStd	0.11	0.21	0.28	0.32	0.50	0.44	0.37	0.40	0.33	0.28	0.18	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page