

ENCHANT AGDM, AB, Canada

WMO: 715180

Lat: 50.1720N

Lon: 112.4366W

Elev: 812

StdP: 91.95

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-28.7	-25.6	-31.8	0.2	-28.7	-28.6	0.3	-25.5	15.1	6.3	13.1	4.5	2.4	230	0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	31.2	17.3	29.3	16.6	27.6	16.1	19.4	27.2	18.3	26.2	17.3	25.2	4.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.6	13.1	23.4	15.4	12.0	21.7	14.2	11.2	20.4	58.9	27.0	55.0	26.0	51.7	25.3	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.6	10.0	DB	-34.4	34.6	2.8	1.9	-36.3	36.0	-38.0	37.1	-39.5	38.2	-41.5	39.5	(4)
(5)			WB	-34.5	22.0	2.7	1.6	-36.4	23.2	-38.0	24.2	-39.6	25.1	-41.5	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	-6.6	-7.2	-0.7	5.5	11.7	15.6	18.7	17.5	12.8	5.9	-1.4	-7.5	(6)	
	DBStd	11.27	8.87	8.45	7.64	5.06	4.35	3.09	2.77	3.15	4.50	5.13	7.63	8.48	(7)	
	HDD10.0	2562	516	482	333	146	33	1	0	1	23	144	343	541	(8)	
	HDD18.3	4798	773	714	591	384	211	93	29	54	172	386	591	799	(9)	
	CDD10.0	892	0	0	1	12	84	168	269	232	107	17	2	0	(10)	
	CDD18.3	86	0	0	0	0	3	10	41	27	6	0	0	0	(11)	
	CDH23.3	1798	0	0	0	12	126	211	672	560	211	7	0	0	(12)	
	CDH26.7	562	0	0	0	2	28	52	222	194	64	1	0	0	(13)	
(14) Wind	WSAvg	4.2	4.7	4.0	4.7	4.8	4.5	4.2	3.4	3.3	3.8	4.4	4.7	4.4	(14)	
(15) Precipitation	PrecAvg	338	13	9	15	27	48	72	37	37	28	19	14	12	(15)	
	PrecMax	529	32	21	62	60	98	204	91	85	116	56	41	27	(16)	
	PrecMin	165	2	1	0	10	8	20	1	2	0	4	1	1	(17)	
	PrecStd	69	6	6	12	13	23	42	23	20	25	13	10	6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	13.1	17.9	24.9	29.6	31.4	33.4	33.2	31.3	24.1	18.3	11.6	(19)	
		MCWB	6.4	5.9	8.2	11.4	14.0	17.9	18.9	17.0	15.4	12.4	9.2	5.6	(20)	
	2%	DB	8.8	9.2	15.4	21.0	26.9	27.9	31.2	30.9	28.6	20.6	14.0	8.6	(21)	
		MCWB	4.2	4.0	7.3	9.6	13.5	16.1	18.7	16.7	14.8	10.9	7.4	4.0	(22)	
	5%	DB	6.8	6.2	12.7	18.0	24.1	25.7	29.1	28.9	25.8	17.8	11.4	6.3	(23)	
		MCWB	3.0	2.3	5.8	8.3	12.4	15.4	18.0	16.4	13.6	9.5	5.8	2.5	(24)	
	10%	DB	4.7	4.0	9.9	15.0	21.4	23.6	27.2	26.6	22.7	15.0	8.9	4.3	(25)	
		MCWB	1.8	1.0	4.4	6.9	11.2	14.2	17.2	16.0	12.7	8.0	4.1	1.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	6.2	9.2	11.7	15.1	19.3	21.9	19.7	16.8	13.2	10.0	6.6	(27)	
		MCDB	11.1	10.8	16.3	22.8	26.8	27.3	29.2	28.7	27.8	21.6	17.2	10.9	(28)	
	2%	WB	4.6	4.0	7.8	10.1	13.9	17.7	20.2	18.3	15.4	11.4	7.6	4.2	(29)	
		MCDB	8.5	9.0	14.5	19.7	24.9	25.4	27.9	27.0	26.2	19.3	13.2	8.0	(30)	
	5%	WB	3.3	2.5	6.2	8.6	12.8	16.2	19.0	17.4	14.2	9.9	6.0	2.7	(31)	
		MCDB	6.4	5.9	12.0	16.7	22.4	23.7	26.5	26.2	24.6	16.7	10.9	6.1	(32)	
	10%	WB	1.9	1.1	4.5	7.2	11.8	15.0	18.0	16.5	13.0	8.6	4.4	1.3	(33)	
		MCDB	4.5	3.9	9.6	14.1	20.1	21.9	25.7	25.0	21.4	14.5	8.5	4.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	11.7	12.0	13.4	13.9	12.9	15.1	15.6	15.1	13.7	11.7	10.8	(35)	
		MCDBR	11.6	14.2	16.2	19.7	19.2	17.2	18.7	20.5	21.4	18.1	14.6	11.7	(36)	
	5% WB	MCWBR	8.0	9.4	9.3	9.9	8.0	7.2	8.2	8.3	9.1	9.4	8.9	7.8	(37)	
		MCDWR	11.2	13.6	15.6	17.9	16.9	15.3	16.8	17.7	19.8	17.4	14.2	11.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.260	0.269	0.292	0.331	0.347	0.343	0.344	0.362	0.320	0.288	0.262	0.245	(40)	
		taud	2.449	2.481	2.465	2.360	2.364	2.425	2.437	2.365	2.458	2.524	2.494	2.446	(41)	
	Edn at Noon	Edn at Noon	808	893	924	914	909	914	906	871	879	855	800	776	(42)	
		Edh at Noon	58	73	89	111	116	110	107	110	89	69	55	50	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.23	2.22	3.52	4.84	5.77	6.35	6.94	5.54	3.93	2.43	1.34	0.94	(44)	
	RadStd	RadStd	0.10	0.20	0.27	0.33	0.43	0.42	0.35	0.35	0.35	0.26	0.12	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (77 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page