

JEAN COTE AGCM, AB, Canada

WMO: 715410

Lat: 55.9128N

Lon: 117.1197W

Elev: 638

StdP: 93.89

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-30.3	-27.7	-33.9	0.2	-30.3	-31.1	0.2	-27.6	11.4	1.2	10.1	-0.7	2.7	210	0.677

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	27.7	16.3	25.7	15.6	24.1	15.1	18.2	24.5	17.2	23.6	16.2	22.1	3.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	12.1	20.9	14.7	11.3	19.8	13.7	10.6	18.5	54.0	24.2	50.8	23.8	47.8	22.1	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.4	7.5	-34.2	30.1	2.5	1.5	-36.0	31.2	-37.4	32.1	-38.8	33.0	-40.6	34.1		
(5)			-34.3	19.7	2.4	1.6	-36.1	20.9	-37.5	21.8	-38.9	22.7	-40.6	23.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-10.9	-11.2	-5.4	2.9	10.7	14.5	16.4	15.5	10.6	3.5	-5.9	-11.9	(6)
(7)		DBStd	12.13	8.60	8.25	7.78	5.10	4.56	3.39	2.83	3.48	4.53	4.87	6.51	7.54	(7)
(8)		HDD10.0	3401	649	592	478	218	47	5	0	3	46	209	476	678	(8)
(9)		HDD18.3	5821	907	826	736	462	237	122	74	100	233	461	726	937	(9)
(10)		CDD10.0	655	0	0	0	6	69	139	197	173	64	7	0	0	(10)
(11)		CDD18.3	34	0	0	0	0	2	6	13	12	1	0	0	0	(11)
(12)		CDH23.3	531	0	0	0	4	48	96	178	168	37	0	0	0	(12)
(13)		CDH26.7	94	0	0	0	1	9	14	29	38	4	0	0	0	(13)
(14)	Wind	WSAvg	3.6	4.0	3.7	3.6	3.9	4.0	3.5	3.0	3.1	3.4	3.8	3.7	3.7	(14)
(15)	Precipitation	PrecAvg	458	30	21	19	18	43	71	69	58	38	26	30	27	(15)
(16)		PrecMax	664	84	42	40	36	108	141	104	120	117	56	64	61	(16)
(17)		PrecMin	274	9	7	3	2	13	31	15	20	2	9	9	5	(17)
(18)		PrecStd	95	21	9	10	10	27	31	30	28	26	12	18	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	5.8	10.1	22.2	28.0	28.7	29.6	30.4	26.9	20.9	10.9	4.5	(19)
(20)			MCWB	2.7	2.5	5.4	10.6	13.2	16.2	18.5	17.8	15.9	11.9	6.7	1.6	(20)
(21)		2%	DB	4.5	3.7	7.8	16.9	24.2	25.8	27.1	27.4	24.0	15.8	6.6	2.5	(21)
(22)			MCWB	2.0	1.4	3.5	7.5	11.5	14.7	16.6	16.9	14.3	9.3	3.7	0.4	(22)
(23)		5%	DB	3.1	2.0	5.7	13.4	21.8	24.0	25.3	25.0	21.3	12.8	4.4	0.9	(23)
(24)			MCWB	1.2	0.1	2.1	6.1	10.6	14.2	16.4	15.9	13.4	7.2	2.1	-1.1	(24)
(25)		10%	DB	1.3	0.0	4.0	10.7	19.8	22.1	23.6	23.0	18.4	10.6	2.3	-1.2	(25)
(26)			MCWB	-0.4	-1.5	1.0	4.6	9.7	13.3	15.7	15.4	11.7	6.1	0.6	-2.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	2.8	5.7	11.0	14.2	17.9	20.0	19.2	16.8	12.6	6.7	1.9	(27)
(28)			MCDWB	5.2	5.5	9.8	21.9	24.3	25.7	26.8	26.6	25.4	19.0	10.3	4.0	(28)
(29)		2%	WB	2.2	1.6	3.8	8.3	12.7	16.4	18.6	18.0	15.1	9.8	4.1	0.5	(29)
(30)			MCDWB	4.2	3.5	7.4	16.2	21.1	23.2	24.4	24.8	22.0	15.2	6.4	2.4	(30)
(31)		5%	WB	1.3	0.2	2.3	6.3	11.5	15.2	17.5	17.1	13.7	7.9	2.2	-0.9	(31)
(32)			MCDWB	3.1	2.0	5.3	12.4	20.0	21.6	23.2	23.6	20.0	11.7	3.9	0.9	(32)
(33)		10%	WB	-0.4	-1.6	1.2	4.9	10.5	14.0	16.5	16.1	12.4	6.5	0.7	-2.7	(33)
(34)			MCDWB	1.2	0.0	3.8	10.2	18.2	20.5	22.1	21.7	17.8	10.1	2.1	-1.3	(34)
(35)	Mean Daily Temperature Range	MDBR	8.0	8.3	9.3	10.3	12.8	11.3	11.8	12.2	11.5	8.9	7.3	7.3	(35)	
(36)		5% DB	MCDBR	8.0	8.4	10.0	14.6	16.0	14.5	14.7	14.9	15.6	12.4	9.0	8.9	(36)
(37)			MCWBR	6.5	6.7	6.6	7.8	6.8	6.1	6.8	6.4	7.2	7.1	6.5	7.7	(37)
(38)			5% WB	MCDBR	7.7	8.0	9.6	13.7	14.6	12.6	13.1	13.7	14.6	11.8	8.5	9.1
(39)		MCWBR		6.3	6.5	6.5	7.8	6.6	5.9	6.9	6.6	7.2	7.1	6.4	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.235	0.245	0.284	0.326	0.339	0.347	0.349	0.346	0.307	0.281	0.241	0.227	(40)	
(41)		taud	2.301	2.353	2.346	2.377	2.407	2.407	2.427	2.414	2.532	2.563	2.431	2.223	(41)	
(42)		Ebn at Noon	715	857	893	897	902	896	887	866	863	809	715	618	(42)	
(43)		Edh at Noon	49	69	91	103	107	109	104	99	76	58	43	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.73	1.72	3.28	4.70	5.61	6.01	5.87	4.77	3.25	1.74	0.78	0.50	(44)	
(45)		RadStd	0.07	0.15	0.27	0.30	0.42	0.47	0.38	0.39	0.26	0.21	0.06	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+57	N/A

Nomenclature: See separate page