

LA CRETE AGCM, AB, Canada

WMO: 715420

Lat: 58.1719N

Lon: 116.3428W

Elev: 1060

StdP: 14.14

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-27.9	-23.5	-34.8	0.8	-27.8	-29.9	1.1	-23.3	23.8	20.1	20.9	18.5	3.2	250	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	83.6	62.4	80.3	61.3	77.4	59.9	65.4	77.7	63.8	76.0	62.3	74.0	7.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.7	82.6	70.4	59.1	77.7	68.3	57.5	73.3	67.1	30.8	77.7	29.6	76.1	28.5	74.2	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 21.0	18.7	16.6		-34.7	89.1	4.3	4.6	-37.8	92.3	-40.3	95.0	-42.7	97.6	-45.8	100.9	
(5)			DB	-34.9	69.0	4.3	2.4	-38.0	70.8	-40.5	72.2	-42.9	73.5	-46.0	75.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.8	3.0	4.7	17.1	35.9	52.7	60.5	64.1	61.1	51.1	36.4	15.1	1.8	(6)
	DBStd	25.69	14.31	13.61	14.76	10.82	8.81	6.57	4.87	6.19	7.82	8.78	12.95	14.65	(7)
	HDD50	7319	1457	1269	1019	436	74	8	0	4	78	431	1047	1496	(8)
	HDD65	11503	1922	1689	1484	874	388	159	75	149	418	887	1497	1961	(9)
	CDD50	1402	0	0	0	12	158	323	439	349	112	9	0	0	(10)
	CDD65	110	0	0	0	0	7	24	48	29	2	0	0	0	(11)
	CDH74	1516	0	0	0	7	165	314	573	393	63	1	0	0	(12)
	CDH80	319	0	0	0	0	32	62	128	88	9	0	0	0	(13)
	WSAvg	7.2	7.3	6.9	7.4	8.4	8.3	7.3	6.3	6.5	6.8	7.2	7.0	6.7	(14)
	PrecAvg	16.1	0.7	0.6	0.7	0.6	1.4	2.6	3.2	2.1	1.5	1.0	0.8	0.7	(15)
(16) Precipitation	PrecMax	21.7	1.7	1.1	1.4	1.5	2.6	5.6	6.2	4.0	3.6	2.0	1.5	1.7	(16)
	PrecMin	12.6	0.2	0.2	0.1	0.2	0.3	0.8	2.0	0.5	0.4	0.3	0.3	0.3	(17)
	PrecStd	2.4	0.3	0.2	0.3	0.3	0.5	0.9	1.0	0.7	0.6	0.4	0.4	0.3	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	45.4	51.7	73.3	84.4	85.6	88.7	87.1	80.7	68.2	50.8	42.5	(19)
		MCWB	37.3	37.5	40.9	52.8	57.4	62.0	64.5	63.8	61.7	52.5	42.7	35.4	(20)
	2%	DB	39.3	37.8	46.6	62.1	78.4	81.1	83.4	82.2	74.8	59.2	43.0	36.2	(21)
		MCWB	34.1	33.4	37.9	45.9	54.6	60.4	63.7	63.1	59.3	46.7	36.6	31.8	(22)
	5%	DB	33.8	31.0	41.9	57.1	74.5	77.5	79.9	78.2	69.4	53.7	38.3	30.4	(23)
		MCWB	29.9	27.5	35.0	43.0	52.5	59.4	62.7	61.5	55.8	44.2	33.2	27.5	(24)
	10%	DB	25.3	24.0	37.8	52.4	70.3	74.1	76.9	74.9	65.0	49.5	33.3	22.3	(25)
		MCWB	23.9	21.7	32.5	41.3	51.2	57.6	61.2	59.9	52.9	41.9	30.4	21.0	(26)
	0.4%	WB	37.5	37.7	41.2	53.2	58.5	66.1	68.2	67.5	63.4	55.3	43.2	35.2	(27)
		MCDB	42.8	43.7	51.3	72.7	78.3	78.6	81.4	81.3	77.8	67.2	50.8	40.7	(28)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.5	33.7	38.2	46.9	56.1	63.4	65.7	64.9	60.1	48.4	37.0	31.9	(29)
		MCDB	39.3	38.1	45.5	60.6	75.0	74.6	77.9	77.3	72.4	57.4	42.5	36.3	(30)
	5%	WB	29.9	27.8	35.6	43.8	53.9	61.5	64.3	63.0	57.2	44.9	33.8	27.2	(31)
		MCDB	33.3	31.0	41.6	54.9	71.4	73.0	76.6	75.0	66.4	52.2	37.8	29.8	(32)
	10%	WB	23.7	21.8	32.5	41.5	51.8	59.9	62.8	61.3	54.6	42.2	30.6	21.0	(33)
		MCDB	25.4	24.0	37.5	51.9	67.8	71.1	74.9	72.4	63.1	48.5	33.4	22.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.3	16.3	18.8	19.8	23.7	20.5	21.5	21.7	21.3	14.3	12.7	14.0	(35)
		MCDBR	22.1	23.3	20.5	26.8	30.2	26.6	26.9	27.7	29.0	23.0	17.8	23.3	(36)
		MCWBR	18.0	19.1	14.0	14.0	13.0	10.9	12.0	11.9	14.7	13.7	13.4	19.5	(37)
	5% WB	MCDBR	22.2	23.0	19.7	25.4	27.4	22.6	25.7	25.6	26.9	21.9	17.0	22.3	(38)
		MCWBR	18.9	19.0	13.5	14.0	12.3	10.7	12.5	12.2	14.2	13.8	13.4	19.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.222	0.246	0.270	0.330	0.342	0.360	0.366	0.349	0.310	0.283	0.235	0.205	(40)
	taud		2.250	2.318	2.320	2.354	2.423	2.401	2.397	2.437	2.547	2.561	2.352	2.137	(41)
	Ebn at Noon		212	260	283	279	283	278	273	271	268	246	206	175	(42)
	Edh at Noon		14	21	28	33	33	34	34	30	23	17	12	11	(43)
(44) All-Sky Solar Radiation	RadAvg		183	480	1003	1537	1806	1888	1788	1455	987	488	195	112	(44)
	RadStd		14	34	65	74	135	149	87	101	71	61	20	9	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	+3.38	+4.41	N/A	N/A	N/A	N/A	N/A	N/A	+99	N/A

Nomenclature: See separate page