

RYCROFT AGCM, AB, Canada

WMO: 715460

Lat: 55.7769N

Lon: 118.6681W

Elev: 575

StdP: 94.61

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -33.5	(c) -30.4	(d) -37.2	(e) 0.1	(f) -33.4	(g) -33.9	(h) 0.2	(i) -30.3	(j) 13.4	(k) 3.1	(l) 12.3	(m) 2.8	(n) 2.0	(o) 200	(p) 0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 13.0	(c) 28.1	(d) 16.0	(e) 26.3	(f) 15.5	(g) 24.6	(h) 14.9	(i) 18.0	(j) 24.7	(k) 17.0	(l) 23.9	(m) 16.1	(n) 22.5	(o) 3.8	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.6	11.9	20.5	14.5	11.0	19.3	13.5	10.3	18.2	53.1	24.4	50.0	24.3	47.1	22.4	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.9	(b) 9.3	(c) 8.1	(e) -37.1	(f) 31.1	(g) 2.4	(h) 1.8	(i) -38.8	(j) 32.4	(k) -40.2	(l) 33.5	(m) -41.6	(n) 34.5	(o) -43.3	(p) 35.8		
(4) 10.9	(5) 9.3	(6) 8.1	(7) -37.2	(8) 19.7	(9) 2.4	(10) 1.8	(11) -38.9	(12) 21.0	(13) -40.3	(14) 22.0	(15) -41.7	(16) 23.0	(17) -43.4	(18) 24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.4	-10.7	-11.3	-5.8	3.3	10.7	14.7	16.4	15.4	10.7	3.6	-6.8	-12.2	(6)
(7)		DBStd	12.45	9.33	9.18	8.13	5.13	4.34	3.02	2.38	3.28	4.34	5.09	7.82	8.42	(7)
(8)		HDD10.0	3419	642	596	489	206	44	3	0	2	43	203	503	689	(8)
(9)		HDD18.3	5836	900	829	747	451	237	116	69	99	231	456	753	948	(9)
(10)		CDD10.0	650	0	0	0	4	66	143	198	171	63	6	0	0	(10)
(11)		CDD18.3	25	0	0	0	0	1	6	8	9	1	0	0	0	(11)
(12)		CDH23.3	668	0	0	0	4	59	124	216	212	52	1	0	0	(12)
(13)		CDH26.7	130	0	0	0	1	9	22	37	53	8	0	0	0	(13)
(14)	Wind	WSAvg	3.3	3.3	3.1	3.1	3.9	4.0	3.7	3.0	2.9	3.2	3.5	3.0	3.1	(14)
(15)	Precipitation	PrecAvg	470	33	20	23	25	46	76	73	54	39	30	30	24	(15)
(16)		PrecMax	642	102	52	46	49	88	138	133	139	108	88	91	96	(16)
(17)		PrecMin	307	9	4	10	6	17	17	29	17	8	6	5	1	(17)
(18)		PrecStd	92	19	10	10	12	20	35	29	29	21	18	19	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	7.9	11.5	22.2	27.7	29.3	30.1	30.9	27.5	21.4	10.0	6.3	(19)
(20)			MCWB	3.6	4.3	6.2	10.8	13.1	16.3	17.7	17.0	14.7	11.8	5.5	2.6	(20)
(21)		2%	DB	5.9	5.2	8.5	17.6	24.8	26.3	27.3	28.1	24.7	16.2	6.9	4.4	(21)
(22)			MCWB	2.8	2.2	4.2	7.8	11.8	15.0	16.4	16.7	14.2	9.1	3.7	1.5	(22)
(23)		5%	DB	4.8	3.6	6.3	14.0	22.2	24.5	25.7	25.5	21.9	13.6	5.2	2.6	(23)
(24)			MCWB	2.1	1.1	2.6	6.2	10.7	14.3	16.2	15.9	12.7	7.5	2.3	0.1	(24)
(25)		10%	DB	3.1	1.9	4.4	11.5	20.1	22.5	24.0	23.5	19.2	11.6	3.5	0.6	(25)
(26)			MCWB	0.8	-0.1	1.5	5.1	10.0	13.5	15.5	15.3	11.7	6.4	1.2	-1.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	4.3	7.1	11.2	14.5	18.1	20.1	19.2	16.6	12.5	6.1	3.1	(27)
(28)			MCD B	6.9	7.4	11.3	22.5	25.1	25.8	26.0	26.4	25.2	19.9	8.7	5.8	(28)
(29)		2%	WB	3.0	2.3	4.5	8.8	12.7	16.4	18.2	17.9	14.8	9.8	4.0	1.6	(29)
(30)			MCD B	5.6	4.7	8.1	16.6	22.1	24.0	24.4	24.7	21.7	14.8	6.6	4.1	(30)
(31)		5%	WB	2.2	1.3	2.8	6.7	11.6	15.3	17.2	17.0	13.5	8.2	2.4	0.2	(31)
(32)			MCD B	4.7	3.4	5.9	13.1	20.4	22.3	23.5	24.0	20.9	12.8	4.7	2.6	(32)
(33)		10%	WB	0.9	-0.2	1.6	5.4	10.6	14.3	16.3	15.9	12.3	6.8	1.4	-1.7	(33)
(34)			MCD B	3.0	1.8	4.3	11.0	18.7	20.7	22.3	22.2	18.3	10.8	3.4	0.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.3	10.3	10.7	11.4	14.2	12.1	13.0	13.5	13.1	10.2	9.1	8.9	(35)
(36)			MCDBR	9.7	10.3	11.2	16.6	18.3	16.3	17.1	17.5	17.5	14.0	10.3	11.2	(36)
(37)			MCWBR	7.5	7.9	7.8	8.7	8.2	7.0	7.9	7.9	8.2	8.0	7.7	9.2	(37)
(38)		5% WB	MCD BR	9.4	10.0	11.1	15.4	16.4	14.1	15.1	15.7	16.4	13.5	10.0	11.3	(38)
(39)			MCWBR	7.5	7.7	7.9	8.5	7.6	6.6	7.9	8.0	8.2	8.2	7.9	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.250	0.251	0.307	0.325	0.347	0.354	0.355	0.354	0.312	0.287	0.245	0.228	(40)	
(41)		taud	2.244	2.344	2.247	2.376	2.386	2.385	2.402	2.396	2.517	2.541	2.405	2.226	(41)	
(42)		Ebn at Noon	683	847	859	898	895	889	880	858	857	800	707	621	(42)	
(43)		Edh at Noon	53	71	101	104	109	111	107	101	78	59	45	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.71	1.66	3.15	4.70	5.60	6.09	5.92	4.81	3.29	1.75	0.78	0.50	(44)	
(45)		RadStd	0.07	0.13	0.25	0.26	0.38	0.48	0.37	0.43	0.29	0.20	0.07	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	(47) Regional (19 neighbors)	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(46) Station Only	(47) Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page