

OUTLOOK, SK, Canada

WMO: 715510

Lat: 51.480N

Lon: 107.050W

Elev: 541

StdP: 94.99

Time Zone: -6.00 (W06)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.2	-27.7	-33.7	0.2	-30.1	-30.9	0.2	-27.6	11.8	-5.5	10.7	-4.3	3.2	280	0.675

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	30.6	18.6	28.6	17.9	26.7	17.1	20.7	27.2	19.5	25.9	18.4	24.4	4.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	14.3	23.4	17.2	13.2	22.3	16.1	12.2	21.1	62.2	27.1	57.9	25.8	54.3	24.3	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.3	8.3	DB	-34.4	34.0	3.0	2.0	-36.6	35.4	-38.3	36.5	-40.0	37.6	-42.2	39.1	(4)
(5)			WB	-34.5	23.1	3.0	1.4	-36.7	24.1	-38.4	24.9	-40.1	25.7	-42.3	26.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.9	-12.1	-11.1	-4.4	4.7	11.4	16.0	18.9	17.8	12.9	5.1	-3.3	-10.2	(6)
(7)		DBStd	12.74	8.56	7.80	7.95	5.63	4.55	3.39	2.96	3.45	4.61	5.11	6.91	8.29	(7)
(8)		HDD10.0	3147	684	592	447	170	38	2	0	0	22	164	399	628	(8)
(9)		HDD18.3	5379	942	825	706	408	218	86	29	51	171	409	649	886	(9)
(10)		CDD10.0	917	0	0	0	12	82	180	276	243	110	14	1	0	(10)
(11)		CDD18.3	107	0	0	0	0	3	14	46	36	8	0	0	0	(11)
(12)		CDH23.3	1463	0	0	0	8	91	207	521	477	156	4	0	0	(12)
(13)		CDH26.7	423	0	0	0	2	17	49	150	158	48	0	0	0	(13)
(14)	Wind	WSAvg	4.0	4.0	3.9	4.3	4.6	4.5	4.0	3.6	3.4	3.8	4.0	4.0	3.9	(14)
(15)	Precipitation	PrecAvg	364	14	10	14	27	46	74	59	50	32	22	13	13	(15)
(16)		PrecMax	501	38	26	38	66	133	169	128	112	100	61	41	30	(16)
(17)		PrecMin	187	1	1	1	5	6	18	8	7	1	6	0	0	(17)
(18)		PrecStd	78	8	6	10	17	33	36	33	25	25	13	10	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	6.1	14.6	23.8	28.9	31.4	33.2	33.4	31.3	23.5	15.7	8.3	(19)
(20)			MCWB	3.7	2.8	8.4	12.1	15.1	18.2	20.6	18.9	17.0	13.5	9.0	4.2	(20)
(21)		2%	DB	4.1	3.5	11.1	20.1	25.9	27.8	30.2	30.5	27.6	19.2	10.7	5.1	(21)
(22)			MCWB	2.0	1.5	6.2	10.2	14.0	17.0	19.7	18.4	15.7	11.0	6.0	2.4	(22)
(23)		5%	DB	2.2	1.8	7.9	17.1	23.4	25.7	28.1	28.1	24.5	15.8	7.5	3.0	(23)
(24)			MCWB	0.6	0.3	4.3	8.9	12.8	15.8	19.2	17.8	14.5	9.4	4.2	1.1	(24)
(25)		10%	DB	-0.2	-0.2	4.9	14.2	20.9	23.6	26.2	25.9	21.5	12.9	5.0	0.7	(25)
(26)			MCWB	-1.4	-1.2	2.5	7.6	11.6	15.0	18.3	17.0	13.2	7.9	2.7	-0.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.9	3.3	8.9	12.8	16.8	20.7	22.9	21.0	18.2	14.0	9.2	4.5	(27)
(28)			MCDWB	6.2	5.5	14.2	21.2	24.3	27.3	29.0	28.9	27.5	21.7	14.9	7.1	(28)
(29)		2%	WB	2.2	1.7	6.5	11.0	14.9	18.4	21.4	19.7	16.6	11.7	6.4	2.6	(29)
(30)			MCDWB	3.9	3.2	10.5	18.2	23.2	24.3	27.6	27.3	25.3	17.6	10.3	4.9	(30)
(31)		5%	WB	0.7	0.4	4.4	9.5	13.6	17.1	20.2	18.7	15.2	9.9	4.5	1.1	(31)
(32)			MCDWB	2.2	1.7	7.7	16.1	21.5	23.0	26.1	26.0	22.5	14.6	7.2	3.1	(32)
(33)		10%	WB	-1.3	-1.3	2.6	8.0	12.4	16.1	19.1	17.6	13.9	8.4	2.9	-0.7	(33)
(34)			MCDWB	-0.2	-0.2	4.8	13.5	19.7	22.0	24.9	24.3	20.6	12.6	4.8	0.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.2	9.1	9.3	11.6	13.3	11.4	12.2	13.0	12.6	10.7	8.4	8.2	(35)
(36)			MCDBR	10.1	10.5	12.6	17.2	17.4	15.5	15.6	17.2	18.3	15.6	11.8	10.1	(36)
(37)			MCWBR	8.6	8.9	8.2	9.0	8.0	6.6	7.1	7.2	8.0	8.6	7.8	8.0	(37)
(38)		5% WB	MCDBR	10.0	9.9	12.2	15.6	15.4	12.6	13.8	14.9	16.2	14.4	11.1	9.9	(38)
(39)			MCWBR	8.6	8.5	8.2	8.7	7.4	6.2	7.1	6.8	7.5	8.4	7.6	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.260	0.256	0.275	0.341	0.355	0.365	0.371	0.377	0.328	0.283	0.255	0.223	(40)	
(41)		taud	2.287	2.343	2.464	2.343	2.352	2.374	2.370	2.333	2.447	2.551	2.484	2.402	(41)	
(42)		Ebn at Noon	765	889	938	898	898	889	876	851	862	852	789	780	(42)	
(43)		Edh at Noon	64	80	87	112	116	115	114	112	89	66	53	47	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.13	2.13	3.52	4.77	5.89	5.99	6.44	5.18	3.79	2.26	1.15	0.82	(44)	
(45)		RadStd	0.11	0.15	0.28	0.43	0.44	0.45	0.35	0.37	0.34	0.31	0.13	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	-0.70	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page