

LINDBERGH AGDM, AB, Canada

WMO: 715670

Lat: 53.9428N

Lon: 110.5789W

Elev: 2067

StdP: 13.63

Time Zone: -7.00 (NAM)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-28.3	-22.1	-34.6	0.8	-27.9	-27.9	1.2	-21.7	21.2	24.9	18.6	21.0	2.9	270	0.683

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.0	81.3	63.2	77.9	62.2	74.9	60.7	66.8	77.0	64.6	74.5	62.6	71.8	8.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.1	93.2	72.5	60.7	85.6	69.0	58.8	79.8	66.7	32.6	76.9	30.8	75.1	29.2	71.9	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.3	17.9	15.7	DB	-37.3	86.8	4.8	3.3	-40.8	89.2	-43.6	91.2	-46.3	93.0	-49.8	95.5
			WB	-37.5	71.2	4.8	2.1	-40.9	72.7	-43.8	73.9	-46.5	75.1	-50.0	76.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.9	8.7	7.2	21.1	36.8	50.0	57.3	61.6	58.2	50.0	37.6	20.7	7.7
	DBStd	22.60	15.26	14.18	13.05	9.45	7.58	5.43	4.72	5.46	7.78	8.10	12.68	14.62
	HDD50	6569	1281	1199	897	404	95	9	0	6	93	393	880	1312
	HDD65	11029	1746	1619	1362	847	466	235	128	218	451	850	1330	1777
	CDD50	1049	0	0	0	7	95	228	358	260	93	8	0	0
	CDD65	35	0	0	0	0	1	5	21	7	1	0	0	0
	CDH74	838	0	0	0	2	69	126	353	191	95	2	0	0
	CDH80	146	0	0	0	0	8	13	77	28	20	0	0	0
(14) Wind	WSAvg	7.0	6.7	6.6	7.5	8.4	7.9	7.2	6.6	6.0	6.7	7.5	7.1	6.2
(15) Precipitation	PrecAvg	16.4	0.7	0.5	0.6	1.1	1.7	2.9	3.1	2.3	1.4	0.7	0.6	0.7
	PrecMax	23.8	1.7	1.1	1.7	3.6	4.0	5.2	6.5	5.8	3.8	1.5	2.1	1.3
	PrecMin	8.8	0.2	0.2	0.2	0.1	0.2	0.6	0.9	0.4	0.1	0.1	0.1	0.3
	PrecStd	3.5	0.4	0.2	0.4	0.8	1.0	1.2	1.5	1.0	0.9	0.4	0.5	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.1	41.1	51.1	70.7	80.7	81.8	86.8	83.6	83.5	68.9	52.0	42.0
		MCWB	36.2	36.1	42.1	50.0	56.7	61.4	66.7	64.8	60.9	53.1	42.5	36.2
	2%	DB	38.6	36.7	44.8	63.6	75.2	77.7	81.8	78.8	75.9	59.7	44.7	36.5
		MCWB	34.3	32.6	37.4	46.5	54.5	60.1	65.8	64.3	58.8	48.0	38.5	32.4
	5%	DB	35.2	32.7	41.1	58.2	70.8	74.1	77.8	75.6	70.8	55.1	39.5	31.9
		MCWB	32.1	30.0	35.7	44.1	52.7	58.7	64.4	63.1	56.8	45.1	35.2	29.1
	10%	DB	30.4	29.0	37.8	53.0	66.9	70.5	74.3	72.2	65.3	50.8	35.9	27.8
		MCWB	28.0	26.7	33.3	41.5	50.5	57.0	62.6	60.9	54.1	43.1	32.8	25.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.2	36.6	42.4	50.9	58.9	64.6	70.7	69.3	63.1	54.3	43.3	36.6
		MCDB	41.7	40.8	49.5	68.8	75.3	76.9	80.5	77.8	78.3	67.2	50.6	41.0
	2%	WB	34.4	33.0	38.1	47.4	56.0	62.3	67.7	66.3	60.2	49.5	39.4	32.5
		MCDB	38.2	35.9	43.8	62.0	70.2	73.0	78.4	75.9	72.9	56.7	44.5	36.0
	5%	WB	32.0	30.2	35.8	44.6	54.2	60.6	65.6	63.8	57.5	46.4	35.6	29.4
		MCDB	35.3	32.9	40.5	56.8	67.6	70.3	75.7	72.9	68.3	54.0	38.6	31.8
	10%	WB	28.0	26.5	33.8	42.3	52.1	58.7	63.7	61.7	55.0	43.5	33.0	25.8
		MCDB	30.2	28.9	37.5	52.0	64.4	67.3	72.9	70.5	64.4	50.4	35.6	27.7
(35) Mean Daily Temperature Range	5% DB	MDBR	18.1	20.3	18.9	20.1	24.0	21.0	22.0	22.9	23.2	18.1	14.7	16.2
		MCDBR	19.8	22.4	21.2	29.7	31.4	28.3	28.8	30.2	33.7	26.4	18.1	19.1
		MCWBR	16.1	18.9	15.2	15.9	14.2	13.3	15.2	16.9	17.8	15.7	12.8	16.0
	5% WB	MCDBR	19.8	22.1	19.7	28.0	27.4	23.6	25.7	27.0	31.1	25.2	17.0	18.8
		MCWBR	16.3	18.6	14.1	15.6	13.2	12.5	14.5	16.0	17.4	15.7	12.6	16.1
(40) Clear-Sky Solar Irradiance	taub		0.244	0.283	0.280	0.327	0.345	0.363	0.360	0.369	0.308	0.275	0.248	0.216
	taud		2.305	2.213	2.383	2.386	2.385	2.349	2.398	2.340	2.509	2.577	2.454	2.345
	Ebn at Noon		237	257	290	287	286	281	279	269	277	267	238	230
	Edh at Noon		17	27	29	33	35	37	35	35	25	19	15	13
(44) All-Sky Solar Radiation	RadAvg		292	625	1107	1482	1827	1867	1913	1559	1096	622	293	211
	RadStd		31	48	83	126	140	133	104	119	119	94	35	21

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46) N/A
(47)	Regional (51 neighbors)	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(47) N/A

Nomenclature: See separate page