

FANNY ISLAND, BC, Canada

WMO: 715680

Lat: 50.4536N

Lon: 125.9930W

Elev: 17

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	26.8	30.0	11.2	9.8	31.6	18.5	14.0	32.4	36.8	42.0	31.7	42.5	11.7	50	0.769

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	67.5	57.1	64.1	56.9	61.8	56.1	59.3	64.3	58.0	62.3	56.9	60.6	10.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.0	69.3	60.8	55.8	66.4	59.7	54.8	64.0	58.8	25.9	65.0	25.1	62.4	24.4	60.8	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.0	29.6	27.2	DB	22.3	78.2	4.7	4.3	18.9	81.3	16.1	83.8	13.5	86.2	10.1	89.3	
			WB	19.9	62.8	4.8	1.5	16.5	63.9	13.7	64.8	11.0	65.7	7.6	66.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	40.2	41.0	42.9	46.8	51.3	54.4	56.8	57.3	54.6	49.4	43.7	39.7
	DBStd	7.39	5.05	4.12	4.05	3.61	3.66	3.13	2.57	2.32	2.83	3.33	4.69	4.53
	HDD50	1479	305	252	221	108	26	1	0	0	1	50	195	320
	HDD65	6127	769	672	684	545	424	319	254	240	312	483	640	785
	CDD50	827	0	0	2	12	67	133	211	226	139	32	5	0
	CDD65	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDH74	24	0	0	0	0	2	8	5	7	2	0	0	0
	CDH80	5	0	0	0	0	0	2	1	2	0	0	0	0
	WSAvg	12.7	10.8	10.5	11.2	12.0	14.4	15.5	17.6	16.0	12.0	10.4	10.7	11.0
	PrecAvg	82.3	10.8	6.5	6.7	5.8	4.0	3.6	2.5	2.9	4.2	10.0	12.6	11.8
(15) Precipitation	PrecMax	102.3	17.1	16.8	12.0	13.1	8.5	7.6	5.1	6.5	10.8	15.4	20.2	17.3
	PrecMin	62.1	5.6	0.1	0.7	1.6	1.7	1.5	0.3	0.2	0.8	2.1	5.6	5.9
	PrecStd	10.4	3.3	3.7	2.6	3.1	1.6	1.6	1.4	1.9	2.3	4.0	4.2	2.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	51.9	55.0	65.2	70.2	73.2	70.8	70.7	69.8	61.3	55.5	51.9
		MCWB	49.7	47.0	49.0	51.5	54.4	57.8	60.0	59.4	58.8	55.6	52.6	49.2
	2%	DB	49.9	49.6	52.0	57.2	62.8	64.7	65.1	65.0	63.5	57.8	53.4	48.8
		MCWB	47.4	45.7	47.0	49.1	52.9	56.3	58.4	57.9	57.1	54.0	50.9	46.3
	5%	DB	48.1	47.8	50.0	53.9	58.4	60.9	62.4	62.7	60.6	55.6	51.7	46.6
		MCWB	45.8	44.5	45.9	47.8	52.0	54.7	57.0	57.4	55.8	52.4	49.5	44.2
	10%	DB	46.4	46.4	48.4	51.6	56.0	58.5	60.5	60.8	58.4	53.8	49.8	45.4
		MCWB	44.2	43.5	45.0	46.7	51.0	53.8	56.0	56.4	54.7	50.9	47.5	43.2
	0.4%	WB	50.0	48.5	51.0	53.1	56.2	59.1	60.9	61.1	60.3	56.9	52.3	49.6
		MCDB	52.0	50.4	53.9	61.6	63.7	67.9	67.2	67.6	66.2	60.4	53.9	51.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	48.0	46.4	48.1	50.4	54.4	56.6	59.2	59.1	58.1	54.7	50.6	46.6
		MCDB	49.9	48.9	50.7	55.2	60.5	61.7	64.1	63.2	62.6	57.3	52.3	48.6
	5%	WB	46.0	44.9	46.5	48.7	52.8	55.4	57.8	57.8	56.6	52.8	49.1	44.6
		MCDB	48.0	47.1	49.2	52.6	57.8	60.3	61.8	61.5	59.9	55.1	50.7	46.3
	10%	WB	44.2	43.8	45.2	47.4	51.3	54.2	56.5	56.7	55.2	51.3	47.4	43.4
		MCDB	46.2	46.1	48.1	50.9	55.3	58.3	59.9	60.1	57.8	53.6	49.2	45.2
	5% DB	MDBR	5.1	6.4	7.1	8.3	8.5	8.0	8.1	8.0	7.8	6.0	5.4	4.6
		MCDBR	5.5	8.4	9.4	13.3	14.1	13.3	11.9	11.7	12.6	8.7	5.4	5.0
		MCWBR	4.3	5.6	6.0	6.9	6.9	6.5	6.5	6.4	6.7	5.6	4.7	4.2
		MCDBR	5.3	6.4	7.7	11.0	12.1	12.0	11.8	10.8	11.5	7.7	5.1	5.0
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.2	4.7	5.6	6.4	6.6	6.6	7.0	6.3	6.7	5.4	4.6	4.3
(40) Clear-Sky Solar Irradiance	taub		0.313	0.317	0.346	0.364	0.378	0.378	0.365	0.366	0.342	0.370	0.321	0.308
	taud		2.408	2.483	2.414	2.375	2.379	2.417	2.492	2.501	2.560	2.357	2.457	2.380
	Ebn at Noon		228	262	272	279	279	279	281	276	272	234	224	210
	Edh at Noon		20	23	30	35	36	35	32	30	26	27	19	18
(44) All-Sky Solar Radiation	RadAvg		237	508	764	1191	1562	1656	1796	1559	1077	574	277	189
	RadStd		36	91	110	119	174	186	217	134	100	102	54	30

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page