

TALOYOAK, NU, Canada

WMO: 715800

Lat: 69.550N

Lon: 93.580W

Elev: 27

StdP: 101.00

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-42.7	-41.4	-45.2	0.0	-40.5	-43.5	0.1	-39.0	15.6	-29.4	13.7	-28.5	2.8	160	1.101

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	16.4	11.2	14.6	10.3	12.8	9.4	11.8	15.4	10.7	13.9	9.6	12.6	4.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	7.6	12.8	8.6	7.0	11.9	7.5	6.4	11.0	33.8	15.5	31.0	13.9	28.5	12.6	16.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.8	10.4	DB	-44.6	19.9	2.0	1.7	-46.1	21.1	-47.3	22.1	-48.4	23.0	-49.9	24.2	(4)
(5)			WB	-41.2	14.7	2.8	1.3	-43.2	15.6	-44.8	16.4	-46.4	17.1	-48.4	18.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-13.7	-32.1	-33.4	-29.7	-20.7	-8.8	2.3	8.4	7.0	0.2	-9.5	-21.0	-28.1	(6)
(7)		DBStd	15.86	5.59	5.78	6.31	5.91	5.35	3.84	2.88	3.15	3.27	5.72	6.48	6.24	(7)
(8)		HDD10.0	8667	1306	1215	1231	921	584	232	68	104	293	603	929	1181	(8)
(9)		HDD18.3	11679	1564	1448	1489	1171	842	481	308	353	543	862	1179	1439	(9)
(10)		CDD10.0	29	0	0	0	0	0	1	18	10	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.8	4.4	4.3	4.3	4.6	4.9	4.8	4.7	5.0	5.4	5.3	4.9	4.5	(14)
(15)	Precipitation	PrecAvg	172	7	7	7	8	13	19	23	28	24	22	11	8	(15)
(16)		PrecMax	244	15	20	13	22	33	49	61	56	47	45	27	30	(16)
(17)		PrecMin	134	1	1	0	0	2	4	2	3	2	8	1	0	(17)
(18)		PrecStd	28	3	4	4	6	8	11	15	13	13	9	6	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-14.1	-15.3	-8.8	-4.3	2.4	15.3	19.6	17.6	9.2	0.9	-3.8	-10.4	(19)
(20)			MCWB	-14.5	-15.8	-9.2	-4.8	1.1	10.7	13.1	11.9	6.6	0.4	-4.4	-11.0	(20)
(21)		2%	DB	-18.2	-17.5	-13.2	-6.7	1.1	12.2	17.3	15.4	7.3	0.0	-6.2	-12.3	(21)
(22)			MCWB	-18.6	-17.9	-13.6	-7.3	0.3	8.6	11.7	11.0	5.7	-0.3	-6.6	-12.7	(22)
(23)		5%	DB	-20.6	-20.6	-16.6	-8.7	0.2	9.9	15.6	13.7	6.0	-0.9	-8.7	-15.8	(23)
(24)			MCWB	-21.0	-21.0	-17.0	-9.2	-0.5	7.1	10.7	10.1	4.7	-1.4	-9.1	-16.2	(24)
(25)		10%	DB	-23.1	-24.1	-19.9	-11.1	-1.2	7.7	14.0	12.1	4.7	-2.0	-11.2	-18.5	(25)
(26)			MCWB	-23.4	-24.4	-20.3	-11.7	-2.0	5.6	9.9	9.3	3.7	-2.5	-11.7	-18.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-14.2	-15.2	-9.0	-4.7	1.4	11.1	14.2	13.2	7.1	0.6	-4.1	-10.8	(27)
(28)			MADB	-14.1	-14.9	-8.4	-4.3	2.1	14.8	18.1	16.0	8.6	0.8	-3.7	-10.5	(28)
(29)		2%	WB	-18.2	-17.3	-13.4	-7.3	0.4	8.9	12.3	11.6	5.9	-0.2	-6.6	-12.6	(29)
(30)			MADB	-17.8	-16.9	-13.0	-6.8	1.0	12.0	16.4	14.4	7.0	0.0	-6.1	-12.2	(30)
(31)		5%	WB	-20.4	-19.9	-16.6	-9.2	-0.4	7.2	11.1	10.6	4.9	-1.3	-9.1	-16.0	(31)
(32)			MADB	-20.1	-19.6	-16.2	-8.7	0.2	9.7	14.9	13.1	5.8	-1.0	-8.7	-15.6	(32)
(33)		10%	WB	-22.7	-22.9	-19.6	-11.6	-1.9	5.6	10.1	9.5	3.7	-2.4	-11.6	-18.6	(33)
(34)			MADB	-22.4	-22.6	-19.3	-11.1	-1.2	7.6	13.6	11.8	4.6	-1.9	-11.1	-18.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.2	7.1	8.3	6.7	5.2	7.7	6.1	4.1	5.4	6.5	6.3	(35)
(36)			MCDBR	9.2	8.9	8.9	8.2	5.1	8.6	10.5	8.2	5.9	4.0	7.1	8.2	(36)
(37)			MCWBR	8.9	8.7	8.6	8.0	4.7	5.8	6.4	5.1	4.5	4.1	7.1	8.1	(37)
(38)		5% WB	MCDBR	9.1	8.6	9.0	8.1	4.9	8.4	10.2	7.6	5.8	4.2	7.2	8.2	(38)
(39)			MCWBR	8.9	8.3	8.8	8.0	4.5	5.8	6.7	5.2	4.7	4.3	7.2	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.150	0.205	0.251	0.306	0.321	0.331	0.352	0.324	0.294	0.228	0.160	N/A	(40)	
(41)		taud	1.885	2.033	2.175	2.069	2.151	2.365	2.402	2.496	2.458	2.077	1.889	N/A	(41)	
(42)		Ebn at Noon	43	558	775	818	855	862	828	816	738	493	25	0	(42)	
(43)		Edh at Noon	3	41	73	114	119	100	94	76	59	38	3	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.01	0.39	1.92	4.35	6.30	6.14	5.20	3.47	1.65	0.47	0.06	0.00	(44)	
(45)		RadStd	0.00	0.03	0.07	0.16	0.30	0.45	0.42	0.26	0.13	0.06	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.71	+0.89	N/A	N/A	N/A	N/A	-301	-292	N/A	N/A

Nomenclature: See separate page