

ALGONQUIN PARK EAST GATE, ON, Canada

WMO: 715810

Lat: 45.536N

Lon: 78.262W

Elev: 1302

StdP: 14.02

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.0	-17.0	-29.0	1.1	-22.5	-22.8	1.6	-16.6	9.2	22.5	7.8	20.7	0.3	0	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.8	84.4	67.1	81.5	65.7	78.8	64.1	70.7	79.4	69.0	76.9	67.4	74.6	4.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.1	108.5	74.0	66.4	102.0	72.7	64.6	95.8	71.2	35.4	79.1	34.0	76.9	32.6	74.5	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.8	7.3	6.5	-33.2	89.6	4.6	2.6	-36.5	91.5	-39.2	93.1	-41.8	94.5	-45.1	96.4
			-33.3	74.2	4.6	2.0	-36.7	75.6	-39.4	76.8	-41.9	78.0	-45.3	79.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.5	11.6	12.9	23.1	37.6	51.5	60.3	64.8	62.6	55.1	43.5	30.9	18.2	(6)
	DBStd	21.21	14.17	12.04	12.54	8.37	8.59	6.54	5.49	5.46	7.65	8.17	9.58	12.31	(7)
	HDD50	5365	1191	1038	835	381	84	4	0	35	238	574	985		(8)
	HDD65	9469	1656	1458	1299	823	427	172	71	112	310	667	1024	1450	(9)
	CDD50	1527	0	0	1	8	132	312	460	391	186	37	0	0	(10)
	CDD65	157	0	0	0	0	10	30	67	38	12	0	0	0	(11)
	CDH74	2000	0	0	1	10	195	397	802	445	141	9	0	0	(12)
	CDH80	415	0	0	0	1	46	79	191	79	19	0	0	0	(13)
	WSAvg	2.3	2.3	2.5	2.7	2.8	2.5	2.2	2.0	1.9	1.8	2.2	2.2	2.2	(14)
	PrecAvg	37.5	3.1	2.3	2.5	2.6	3.1	3.2	3.3	3.0	3.7	3.6	3.5	3.1	(15)
(16) Precipitation	PrecMax	43.3	5.2	4.2	6.2	5.0	4.8	5.2	5.4	5.1	6.5	5.7	6.4	5.0	(16)
	PrecMin	32.4	1.7	0.8	0.5	0.8	1.3	0.9	1.1	0.9	1.3	0.6	2.1	1.2	(17)
	PrecStd	3.1	1.1	0.9	1.3	1.1	0.9	1.1	1.2	0.9	1.2	1.4	1.1	0.9	(18)
	PrecStd	3.1	1.1	0.9	1.3	1.1	0.9	1.1	1.2	0.9	1.2	1.4	1.1	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	44.8	60.0	74.3	85.5	85.8	89.2	86.8	82.7	74.8	59.8	48.8	(19)
		MCWB	47.1	41.1	50.3	56.4	65.5	68.6	68.7	69.2	68.6	62.0	52.5	46.8	(20)
	2%	DB	39.1	38.3	50.7	65.4	79.4	82.5	84.9	81.8	78.1	68.0	53.1	41.5	(21)
		MCWB	37.3	36.1	42.0	49.7	61.6	66.1	67.4	66.2	66.3	58.0	48.0	40.2	(22)
	5%	DB	34.5	34.0	45.5	59.4	74.4	78.8	81.6	78.9	74.2	62.4	48.9	36.5	(23)
		MCWB	33.4	31.7	38.5	47.5	57.5	63.6	65.9	64.7	63.3	56.1	45.3	35.0	(24)
	10%	DB	31.8	31.5	40.5	53.4	69.6	75.0	78.5	75.9	70.4	58.0	44.7	33.3	(25)
		MCWB	30.6	29.8	35.0	42.6	56.1	61.9	64.3	63.4	62.1	53.0	41.7	32.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.0	42.6	51.6	58.8	68.7	72.0	73.5	71.9	70.8	65.1	54.6	47.8	(27)
		MCDB	47.8	43.6	55.5	68.4	81.4	81.0	82.7	80.0	78.2	69.9	58.1	48.8	(28)
	2%	WB	37.8	36.1	43.9	53.8	65.0	69.4	70.8	69.7	68.5	60.7	49.2	40.3	(29)
		MCDB	39.0	38.7	49.0	62.4	74.3	78.2	79.6	77.1	75.6	66.3	52.0	41.4	(30)
	5%	WB	33.7	32.5	39.1	47.9	62.0	67.1	68.9	67.8	65.9	56.9	45.6	35.2	(31)
		MCDB	34.4	33.7	43.5	56.3	69.5	74.1	76.9	74.2	71.2	61.6	48.3	36.4	(32)
	10%	WB	30.6	29.6	35.7	44.7	58.3	64.6	67.2	65.8	63.3	53.1	41.8	32.4	(33)
		MCDB	31.7	31.3	39.8	51.6	65.7	71.1	74.8	72.7	68.7	57.0	44.5	33.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.5	23.0	24.3	22.4	25.7	23.1	23.8	23.1	23.8	18.2	16.4	16.7	(35)
		MCDBR	17.3	20.8	27.7	35.4	34.5	29.2	28.4	27.6	28.3	27.8	23.3	14.6	(36)
		MCWBR	16.4	18.2	19.2	21.0	17.4	14.4	13.5	14.3	16.9	18.3	18.3	13.6	(37)
	5% WB	MCDBR	16.8	18.7	24.3	30.1	25.7	23.3	23.1	21.7	22.8	23.7	21.1	14.2	(38)
		MCWBR	16.4	17.3	18.1	20.0	14.7	13.1	12.6	12.9	15.0	17.1	17.8	13.4	(39)
(40) Clear-Sky Solar Irradiance	taub		0.269	0.279	0.300	0.337	0.352	0.390	0.391	0.380	0.357	0.334	0.297	0.267	(40)
	taud		2.366	2.330	2.430	2.431	2.434	2.342	2.351	2.380	2.436	2.491	2.531	2.419	(41)
	Ebn at Noon		269	288	297	293	291	279	276	275	273	265	259	258	(42)
	Edh at Noon		23	30	31	34	35	39	38	36	31	25	20	20	(43)
(44) All-Sky Solar Radiation	RadAvg		414	702	1150	1429	1646	1801	1809	1567	1220	720	418	306	(44)
	RadStd		53	87	113	122	154	144	135	92	116	76	50	36	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	-2.20	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page