

BELLA BELLA, BC, CanadaWMO: **715820**Lat: **52.181N**Lon: **128.154W**Elev: **43**StdP: **100.81**Time Zone: **-8.00 (NAP)**Period: **07-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.9	-5.7	-18.5	0.7	-4.0	-13.8	1.1	-2.0	10.4	6.2	9.2	6.1	1.4	120	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.4	24.8	17.4	22.6	16.3	20.7	15.6	17.9	23.4	16.9	21.3	16.0	19.5	3.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.2	18.7	15.1	10.8	18.1	14.5	10.4	17.3	50.4	23.6	47.5	21.5	44.9	19.6	20.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.2	6.8	5.7	DB	-11.4	29.6	2.1	1.9	-12.8	31.0	-14.0	32.1	-15.2	33.2	-16.7	34.6	
			WB	-12.0	19.5	2.1	0.6	-13.5	19.9	-14.7	20.3	-15.9	20.6	-17.3	21.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	3.6	3.1	4.3	6.9	10.6	12.6	15.0	15.3	13.1	8.9	5.4	2.1
	DBStd	5.35	3.42	3.33	2.77	2.20	2.59	2.18	2.18	1.93	2.33	2.35	3.12	3.49
	HDD10.0	1129	199	193	177	98	24	2	0	0	3	49	141	244
	HDD18.3	3619	457	427	434	344	241	173	107	96	157	292	389	502
	CDD10.0	558	0	0	1	3	42	80	154	165	97	15	1	0
	CDD18.3	7	0	0	0	0	0	1	3	2	1	0	0	0
	CDH23.3	151	0	0	1	0	7	25	61	49	8	0	0	0
	CDH26.7	34	0	0	0	0	1	7	13	12	1	0	0	0
(14) Wind	WSAvg	2.2	2.5	2.3	2.5	2.3	2.0	1.9	1.8	1.7	1.9	2.2	2.7	2.6
(15) Precipitation	PrecAvg	2659	275	189	247	200	153	139	119	162	217	350	352	293
	PrecMax	3297	415	365	549	342	365	238	359	305	427	490	535	502
	PrecMin	1931	92	56	120	77	61	69	21	25	22	158	202	65
	PrecStd	321	83	85	101	57	65	51	81	65	103	91	96	96
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	12.4	15.4	19.0	24.3	27.2	28.3	28.2	24.3	17.9	13.0	10.4
		MCWB	8.7	7.6	9.7	10.5	14.5	15.9	18.3	18.3	16.7	13.0	10.9	8.2
	2%	DB	10.0	10.3	11.7	15.1	21.1	21.6	24.8	24.1	21.3	15.6	11.4	9.0
		MCWB	7.9	7.4	8.2	8.6	13.2	15.3	18.1	17.6	15.9	12.0	10.1	7.6
	5%	DB	8.8	9.0	10.1	13.0	18.0	19.0	22.2	22.0	19.3	14.2	10.5	7.9
		MCWB	7.3	7.1	7.2	8.4	12.5	14.2	16.6	16.7	15.0	11.7	9.5	6.8
	10%	DB	7.7	7.8	8.6	11.3	15.9	17.0	20.0	20.1	17.2	13.1	9.7	6.8
		MCWB	6.5	6.3	6.8	8.0	11.4	13.1	15.3	15.8	14.0	10.9	8.8	5.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	9.6	10.7	12.4	15.2	17.3	19.4	18.9	18.1	14.7	11.8	9.0
		MCDB	10.4	10.4	13.5	16.7	22.7	23.3	26.6	25.7	22.9	15.8	12.2	9.6
	2%	WB	8.5	8.4	9.3	10.4	13.8	15.7	17.9	17.9	16.7	13.5	10.4	7.9
		MCDB	9.4	9.2	10.6	12.2	19.2	20.6	23.7	23.4	20.1	14.7	10.9	8.8
	5%	WB	7.7	7.4	8.2	9.2	12.8	14.5	16.6	17.0	15.5	12.3	9.7	7.0
		MCDB	8.4	8.5	9.1	11.4	17.2	18.1	21.4	21.1	17.9	13.4	10.3	7.8
	10%	WB	6.8	6.5	7.3	8.4	11.8	13.6	15.7	16.2	14.7	11.2	8.9	6.0
		MCDB	7.5	7.6	8.3	10.5	15.0	16.4	19.2	19.2	16.5	12.5	9.7	6.7
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.6	6.7	7.7	8.6	7.3	8.1	8.4	7.6	6.8	5.3	5.4
		MCDBR	6.3	8.7	9.5	12.4	13.6	12.4	13.9	13.0	11.7	9.4	4.8	5.5
	5% WB	MCWBR	4.4	5.9	5.9	7.0	7.4	6.9	7.5	7.2	7.0	6.0	4.0	4.4
		MCWBR	4.9	6.7	7.4	9.2	11.5	10.3	12.1	11.3	9.8	6.8	4.5	5.1
(40) Clear-Sky Solar Irradiance	taub	0.312	0.320	0.348	0.367	0.371	0.374	0.361	0.364	0.348	0.342	0.320	0.301	(40)
		2.411	2.491	2.414	2.384	2.417	2.443	2.519	2.523	2.556	2.494	2.415	2.396	(41)
	Edn at Noon	692	808	845	870	882	880	886	865	841	766	672	637	(42)
		58	71	93	107	109	107	98	93	80	70	58	50	(43)
(44) All-Sky Solar Radiation	RadAvg	0.63	1.49	2.38	3.79	4.88	5.16	5.07	4.38	3.00	1.64	0.76	0.52	(44)
	RadStd	0.09	0.26	0.37	0.29	0.54	0.49	0.67	0.44	0.32	0.27	0.12	0.09	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page