

EDMUNDSTON, NB, Canada

WMO: 715900

Lat: 47.4167N

Lon: 68.3244W

Elev: 154

StdP: 99.49

Time Zone: -4.00 (NAA)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.7	-27.5	-34.1	0.2	-30.6	-30.7	0.2	-26.9	7.3	-7.8	6.5	-8.7	0.7	330	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	29.1	19.9	27.2	19.0	25.6	18.3	21.5	26.3	20.5	25.1	19.6	23.9	2.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	14.9	23.8	18.9	14.0	22.8	18.0	13.2	21.8	63.4	26.3	59.9	25.2	56.6	24.0	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.7	5.1	DB	-35.4	31.9	3.0	1.3	-37.6	32.8	-39.3	33.6	-41.0	34.3	-43.1	35.3	(4)
(5)			WB	-35.4	23.4	2.9	0.9	-37.5	24.0	-39.2	24.6	-40.8	25.1	-42.9	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.6	-12.8	-11.6	-5.8	2.6	10.2	14.8	18.1	17.0	12.2	6.2	-0.4	-8.0		
	DBStd	11.86	7.72	6.85	6.60	4.33	3.93	3.45	2.94	3.07	4.07	4.16	5.03	6.44		
	HDD10.0	3094	707	603	490	222	46	2	0	1	23	132	311	558		
	HDD18.3	5436	965	837	748	471	255	116	40	63	188	376	561	816		
	CDD10.0	770	0	0	0	2	51	146	252	216	89	14	1	0		
	CDD18.3	69	0	0	0	0	2	9	33	21	4	0	0	0		
	CDH23.3	981	0	0	0	2	62	171	421	261	59	6	0	0		
	CDH26.7	213	0	0	0	0	17	37	98	50	10	1	0	0		
(14) Wind	WSAvg	2.0	2.1	2.3	2.5	2.4	2.2	1.8	1.6	1.5	1.6	1.8	2.0	1.9		
(15) Precipitation	PrecAvg	1225	107	92	97	82	89	80	106	116	105	106	109	149		
	PrecMax	1648	183	173	184	177	162	133	156	263	187	177	173	255		
	PrecMin	960	26	38	15	19	40	32	55	36	32	42	60	42		
	PrecStd	194	37	40	40	38	33	22	32	61	45	39	29	52		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	5.6	12.4	21.0	29.3	30.3	31.2	30.3	28.0	23.2	15.6	8.0		
		MCWB	5.3	3.3	5.7	11.4	17.7	19.5	21.1	20.8	20.3	15.3	13.9	6.7		
	2%	DB	3.5	3.0	7.8	16.7	24.6	27.3	29.3	28.0	24.8	18.5	11.7	4.4		
		MCWB	2.5	0.7	3.1	8.7	15.0	18.3	20.3	19.5	17.9	13.6	9.5	3.4		
	5%	DB	1.5	1.3	5.5	13.3	21.6	25.2	27.4	26.2	22.7	15.9	9.2	2.7		
		MCWB	0.5	-0.2	2.0	7.1	12.9	17.5	19.4	18.8	17.0	12.6	7.2	1.5		
	10%	DB	-0.6	-0.3	3.4	10.4	18.9	23.1	25.7	24.4	20.5	13.8	7.0	1.2		
		MCWB	-1.6	-1.6	0.7	5.5	11.9	16.1	18.6	18.0	16.0	11.0	5.5	0.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	4.0	7.6	13.2	19.5	22.0	23.5	22.1	21.2	17.4	13.7	6.9		
		MCDB	6.1	4.9	10.7	18.4	25.5	27.6	28.3	28.0	26.3	20.6	14.8	7.7		
	2%	WB	2.7	1.2	4.0	9.8	16.6	20.1	21.8	20.9	19.6	15.1	10.0	3.6		
		MCDB	3.5	2.3	6.6	14.5	21.9	24.7	26.2	25.8	23.4	17.3	11.1	4.1		
	5%	WB	0.6	0.0	2.3	7.9	14.5	18.7	20.8	20.0	18.2	13.1	7.3	1.8		
		MCDB	1.3	1.3	5.1	12.3	19.0	23.0	25.2	24.5	21.2	15.6	8.5	2.5		
	10%	WB	-1.7	-1.7	0.9	6.1	12.8	17.2	19.8	19.0	16.6	11.2	5.4	0.3		
		MCDB	-0.6	-0.3	3.2	10.2	17.7	21.5	24.3	22.7	20.0	13.5	7.1	1.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	13.8	13.4	12.0	13.3	13.2	13.5	13.6	13.6	11.1	8.7	9.8		
		MCDBR	11.1	12.3	15.1	18.5	19.4	17.6	16.4	16.4	16.8	15.9	11.8	8.9		
	5% WB	MCWBR	10.6	10.6	11.0	11.3	10.4	9.7	8.6	9.0	10.5	11.1	9.7	8.2		
		MCWBR	11.0	10.1	12.6	16.0	15.2	14.1	13.6	13.5	13.8	13.4	10.1	8.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.256	0.269	0.304	0.350	0.353	0.374	0.404	0.381	0.357	0.323	0.291	0.268		
		taud	2.331	2.285	2.249	2.336	2.425	2.366	2.300	2.368	2.432	2.521	2.518	2.380		
	Ebn at Noon	Ebn at Noon	840	903	916	902	911	889	855	862	852	835	799	779		
		Edh at Noon	71	93	114	116	111	118	125	112	96	75	61	61		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.35	2.25	3.47	4.46	5.03	5.45	5.43	4.74	3.69	2.17	1.20	0.92		
	RadStd	RadStd	0.17	0.27	0.25	0.37	0.52	0.36	0.51	0.31	0.27	0.20	0.14	0.09		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page