

GJOA HAVEN, NU, Canada

WMO: 715970

Lat: 68.636N

Lon: 95.850W

Elev: 154

StdP: 14.61

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-43.5	-41.1	-50.6	0.3	-42.3	-48.8	0.3	-41.2	36.6	-23.2	33.5	-23.7	9.1	30	1.148

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	59.8	52.3	56.6	50.6	53.8	48.9	53.3	58.4	51.2	55.7	49.3	53.3	11.0	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
50.4	54.5	54.9	48.4	50.5	52.9	46.4	46.9	51.4	22.2	58.8	21.0	55.9	20.0	53.4	63.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.4	28.9	25.6	DB	-46.4	66.7	3.2	4.2	-48.7	69.7	-50.6	72.1	-52.4	74.5	-54.7	77.5	(4)
(5)			WB	-46.3	58.0	2.9	2.1	-48.4	59.5	-50.0	60.7	-51.7	61.9	-53.7	63.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-24.7	-27.4	-20.8	-4.5	16.0	35.2	46.4	44.0	33.0	17.6	-4.7	-17.4	(6)	
	DBStd	28.01	10.27	9.76	11.27	10.56	9.63	6.41	5.11	5.67	6.00	9.67	11.44	11.55	(7)	
	HDD50	15392	2314	2166	2196	1635	1054	445	135	201	509	1005	1641	2091	(8)	
	HDD65	20826	2779	2586	2661	2085	1519	893	576	651	959	1470	2091	2556	(9)	
	CDD50	40	0	0	0	0	0	1	24	15	0	0	0	0	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	13.0	12.3	12.4	12.4	13.1	13.1	12.8	12.0	12.9	14.5	14.7	13.4	11.9	(14)	
	PrecAvg	8.0	0.4	0.4	0.6	0.5	0.6	0.6	0.7	1.1	0.9	1.1	0.5	0.4	(15)	
(16) Precipitation	PrecMax	11.1	1.2	1.3	2.4	1.7	1.2	1.5	1.9	2.4	1.8	2.3	1.1	0.8	(16)	
	PrecMin	4.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.4	0.2	0.3	0.1	0.0	(17)	
	PrecStd	1.9	0.3	0.4	0.6	0.5	0.4	0.4	0.5	0.7	0.4	0.6	0.3	0.2	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	4.1	12.3	25.5	36.4	58.8	66.9	62.7	49.5	34.6	25.9	22.2	(19)	
		MCWB	11.0	3.2	11.8	24.8	34.9	51.2	57.3	55.1	46.3	33.9	25.4	21.9	(20)	
	2%	DB	1.9	-0.8	6.7	21.7	33.6	51.8	61.4	58.1	45.9	32.9	20.7	11.1	(21)	
		MCWB	1.1	-1.3	6.1	21.0	32.8	46.1	53.1	52.0	43.3	32.3	20.2	10.6	(22)	
	5%	DB	-4.0	-5.8	2.3	18.1	32.1	47.9	58.3	55.2	43.6	31.6	16.2	5.8	(23)	
		MCWB	-4.7	-6.4	1.6	17.4	31.4	43.9	51.4	50.5	41.8	31.0	15.7	5.2	(24)	
	10%	DB	-8.9	-11.7	-2.7	12.4	29.8	44.2	55.6	52.7	41.5	29.9	11.9	-0.1	(25)	
		MCWB	-9.5	-12.2	-3.4	11.8	28.9	41.2	49.4	49.2	40.1	29.3	11.4	-0.7	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	3.6	11.7	25.1	35.1	51.4	57.9	55.8	46.7	34.1	25.4	21.7	(27)	
		MCDB	11.3	4.1	12.1	25.5	36.0	58.5	65.1	60.7	49.1	34.4	25.7	22.0	(28)	
	2%	WB	1.1	-1.4	6.1	21.1	32.9	46.8	54.4	53.0	43.7	32.5	20.2	10.6	(29)	
		MCDB	1.8	-1.0	6.6	21.5	33.3	51.2	59.9	57.2	45.4	32.7	20.7	11.0	(30)	
	5%	WB	-4.5	-6.3	1.7	17.4	31.4	43.9	51.7	51.3	42.0	31.1	15.7	5.3	(31)	
		MCDB	-4.0	-5.6	2.4	18.1	32.0	47.5	57.6	54.5	43.4	31.5	16.1	5.8	(32)	
	10%	WB	-9.3	-12.0	-3.3	11.8	28.9	41.3	49.9	49.6	40.2	29.3	11.4	-0.7	(33)	
		MCDB	-8.8	-11.6	-2.8	12.3	29.7	44.1	55.1	52.3	41.4	29.8	11.9	-0.2	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	10.9	10.5	12.8	14.6	10.9	8.6	12.8	9.9	6.9	8.5	11.1	10.8	(35)	
		MCDBR	16.5	15.7	15.1	16.3	8.8	14.6	17.4	13.4	10.0	6.0	14.9	14.8	(36)	
		MCWBR	16.2	15.5	15.0	16.2	8.3	10.4	10.9	8.8	8.3	6.2	14.9	14.8	(37)	
	5% WB	MCDBR	16.5	15.6	15.2	16.3	8.6	14.0	16.5	12.4	9.8	6.1	14.8	14.8	(38)	
		MCWBR	16.1	15.4	15.1	16.2	8.3	10.2	11.2	8.8	8.4	6.4	14.8	14.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.150	0.207	0.243	0.316	0.335	0.332	0.351	0.331	0.305	0.237	0.158	N/A	(40)	
	taud		1.875	2.043	2.182	1.988	2.014	2.239	2.342	2.471	2.439	2.141	1.881	N/A	(41)	
	Ebn at Noon		32	188	255	257	266	273	264	258	233	168	22	0	(42)	
	Edh at Noon		2	14	24	40	44	36	32	25	20	13	2	0	(43)	
(44) All-Sky Solar Radiation	RadAvg		7	131	620	1331	1990	2102	1695	1102	531	177	23	0	(44)	
	RadStd		1	17	34	65	126	132	134	95	46	21	2	0	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (4 neighbors)	+1.08	+1.75	N/A	N/A	N/A	N/A	-419	-412	N/A	N/A	(47)

Nomenclature: See separate page