

GJOA HAVEN, NU, Canada

WMO: 715970

Lat: 68.636N

Lon: 95.850W

Elev: 47

StdP: 100.76

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.9	-40.6	-45.9	0.0	-41.3	-44.9	0.0	-40.7	16.3	-30.7	15.0	-30.9	4.1	30	1.148

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	15.4	11.3	13.7	10.3	12.1	9.4	11.8	14.7	10.7	13.2	9.6	11.8	4.9	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.2	7.8	12.7	9.1	7.2	11.6	8.0	6.7	10.8	33.9	14.9	31.0	13.3	28.6	11.9	17.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	12.9	11.4	DB	-43.6	19.3	1.8	2.3	-44.8	20.9	-45.9	22.3	-46.9	23.6	-48.2	25.3	(4)
(5)			WB	-43.5	14.5	1.6	1.1	-44.7	15.3	-45.6	16.0	-46.5	16.6	-47.6	17.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-13.4	-31.5	-33.0	-29.4	-20.3	-8.9	1.8	8.0	6.7	0.6	-8.0	-20.4	-27.5		
	DBStd	15.56	5.70	5.42	6.26	5.87	5.35	3.56	2.84	3.15	3.33	5.37	6.36	6.42		
	HDD10.0	8551	1286	1203	1220	908	586	247	75	112	283	558	912	1162		
	HDD18.3	11570	1544	1437	1478	1158	844	496	320	362	533	817	1162	1420		
	CDD10.0	22	0	0	0	0	0	1	13	8	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	5.8	5.5	5.5	5.5	5.8	5.8	5.7	5.3	5.8	6.5	6.6	6.0	5.3		
	PrecAvg	202	9	9	16	13	15	15	19	28	24	28	12	10		
	PrecMax	283	30	33	60	44	31	37	49	61	45	59	29	21		
	PrecMin	106	1	1	0	1	0	1	2	9	6	8	3	1		
	PrecStd	49	7	9	15	12	10	10	13	17	10	15	7	6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-11.4	-15.5	-11.0	-3.6	2.4	14.9	19.4	17.1	9.7	1.4	-3.4	-5.5		
		MCWB	-11.6	-16.0	-11.2	-4.0	1.6	10.7	14.1	12.8	8.0	1.0	-3.6	-5.6		
	2%	DB	-16.7	-18.2	-14.0	-5.7	0.9	11.0	16.3	14.5	7.7	0.5	-6.3	-11.6		
		MCWB	-17.2	-18.5	-14.4	-6.1	0.4	7.8	11.7	11.1	6.3	0.2	-6.6	-11.9		
	5%	DB	-20.0	-21.0	-16.5	-7.7	0.0	8.8	14.6	12.9	6.4	-0.2	-8.8	-14.6		
		MCWB	-20.4	-21.4	-16.9	-8.1	-0.4	6.6	10.8	10.3	5.4	-0.6	-9.0	-14.9		
	10%	DB	-22.7	-24.3	-19.3	-10.9	-1.2	6.8	13.1	11.5	5.3	-1.2	-11.1	-17.8		
		MCWB	-23.0	-24.6	-19.7	-11.2	-1.7	5.1	9.7	9.6	4.5	-1.5	-11.4	-18.2		
	0.4%	WB	-11.7	-15.8	-11.3	-3.8	1.7	10.8	14.4	13.2	8.2	1.2	-3.6	-5.7		
		MCDB	-11.5	-15.5	-11.1	-3.6	2.2	14.7	18.4	15.9	9.5	1.3	-3.5	-5.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-17.1	-18.6	-14.4	-6.1	0.5	8.2	12.4	11.7	6.5	0.3	-6.5	-11.9		
		MCDB	-16.8	-18.3	-14.1	-5.8	0.7	10.7	15.5	14.0	7.4	0.4	-6.3	-11.7		
	5%	WB	-20.3	-21.3	-16.8	-8.1	-0.3	6.6	11.0	10.7	5.6	-0.5	-9.1	-14.8		
		MCDB	-20.0	-20.9	-16.5	-7.7	0.0	8.6	14.2	12.5	6.3	-0.3	-8.8	-14.5		
	10%	WB	-22.9	-24.5	-19.6	-11.2	-1.7	5.1	9.9	9.8	4.6	-1.5	-11.4	-18.2		
		MCDB	-22.7	-24.2	-19.3	-10.9	-1.3	6.7	12.8	11.3	5.2	-1.2	-11.2	-17.9		
	5% DB	MDBR	6.0	5.8	7.1	8.1	6.0	4.8	7.1	5.5	3.8	4.7	6.1	6.0		
		MCDBR	9.2	8.7	8.4	9.0	4.9	8.1	9.6	7.4	5.6	3.4	8.3	8.2		
		MCWBR	9.0	8.6	8.3	9.0	4.6	5.8	6.1	4.9	4.6	3.5	8.3	8.2		
		MCWBR	9.1	8.6	8.4	9.1	4.8	7.8	9.2	6.9	5.4	3.4	8.2	8.2		
(35) Mean Daily Temperature Range	5% WB	MCWBR	9.0	8.5	8.4	9.0	4.6	5.7	6.2	4.9	4.7	3.5	8.2	8.2		
		MCWBR	9.0	8.5	8.4	9.0	4.6	5.7	6.2	4.9	4.7	3.5	8.2	8.2		
	taub	taub	0.150	0.207	0.243	0.316	0.335	0.332	0.351	0.331	0.305	0.237	0.158	N/A		
		taud	1.875	2.043	2.182	1.988	2.014	2.239	2.342	2.471	2.439	2.141	1.881	N/A		
(42) Clear-Sky Solar Irradiance	Ebn at Noon	Ebn at Noon	101	594	804	809	839	862	831	813	733	531	70	0		
		Edh at Noon	6	45	75	126	139	115	101	79	62	40	5	0		
	RadAvg	RadAvg	0.02	0.41	1.95	4.20	6.27	6.62	5.34	3.47	1.67	0.56	0.07	0.00		
(45) All-Sky Solar Radiation	RadStd	RadStd	0.00	0.06	0.11	0.21	0.40	0.41	0.42	0.30	0.14	0.07	0.01	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+0.60	+0.97	N/A	N/A	N/A	N/A	-233	-229	N/A	N/A

Nomenclature: See separate page