

BAS CARAQUET, NB, Canada

WMO: 715980

Lat: 47.800N

Lon: 64.830W

Elev: 16

StdP: 14.69

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.9	(c) -1.6	(d) -13.4	(e) 2.7	(f) -5.0	(g) -9.2	(h) 3.4	(i) -0.8	(j) 37.9	(k) 14.0	(l) 35.0	(m) 13.6	(n) 14.2	(o) 270	(p) 0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	81.7	69.5	78.4	67.6	75.6	66.1	71.6	79.3	69.6	76.3	67.7	73.6	8.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.9	106.2	76.2	67.0	99.2	73.7	65.2	93.3	71.7	35.5	79.4	33.7	76.3	32.1	73.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 31.2	(b) 27.0	(c) 23.7	(e) -12.4	(f) 88.2	(g) 4.8	(h) 3.0	(i) -15.9	(j) 90.4	(k) -18.7	(l) 92.2	(m) -21.4	(n) 93.9	(o) -24.8	(p) 96.1		
(a) 31.2	(b) 27.0	(c) 23.7	(e) -13.1	(f) 75.5	(g) 4.7	(h) 2.3	(i) -16.5	(j) 77.2	(k) -19.3	(l) 78.5	(m) -21.9	(n) 79.8	(o) -25.4	(p) 81.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.5	16.5	16.6	25.0	35.9	47.9	58.7	66.3	65.3	57.7	46.5	35.6	24.7		
	DBStd	18.94	10.00	9.64	8.57	6.15	6.85	6.97	5.05	4.92	6.04	6.25	7.51	8.07		
	HDD50	4674	1038	936	774	424	125	7	0	0	7	145	435	783		
	HDD65	8746	1503	1356	1239	872	531	212	43	56	231	574	881	1248		
	CDD50	1590	0	0	0	1	60	270	506	475	238	37	3	0		
	CDD65	187	0	0	0	0	1	25	84	66	11	0	0	0		
	CDH74	990	0	0	0	0	24	182	414	308	60	2	0	0		
	CDH80	181	0	0	0	0	2	39	74	56	10	0	0	0		
	WSAvg	10.2	12.8	11.7	11.4	10.3	9.2	8.1	7.3	7.6	8.8	10.4	11.6	12.9		
	PrecAvg	43.9	3.7	3.3	3.4	3.1	3.7	3.6	3.7	3.9	3.5	4.6	4.0	4.3		
(15) Precipitation	PrecMax	53.1	6.0	6.1	6.7	5.4	7.1	6.9	5.9	6.7	7.1	8.9	6.7	9.4		
	PrecMin	33.7	1.3	0.8	1.1	1.3	1.0	1.5	1.2	1.0	1.2	1.3	1.4	1.6		
	PrecStd	5.3	1.2	1.4	1.3	1.1	1.5	1.3	1.1	1.5	1.6	1.7	1.2	1.5		
	PrecStd	5.3	1.2	1.4	1.3	1.1	1.5	1.3	1.1	1.5	1.6	1.7	1.2	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.3	42.7	48.6	61.2	77.8	85.0	86.5	86.0	80.5	69.7	59.5	46.6		
		MCWB	43.9	40.6	42.0	49.9	60.7	67.6	71.4	73.4	68.8	60.7	56.5	45.1		
	2%	DB	38.2	36.9	42.8	53.2	70.1	79.1	81.7	80.6	74.5	63.3	54.0	41.9		
		MCWB	36.6	34.8	38.0	45.5	57.0	65.7	70.2	69.5	65.9	57.3	51.2	40.3		
	5%	DB	33.8	33.5	39.3	48.3	64.4	74.7	78.3	77.3	70.7	59.3	49.8	38.1		
		MCWB	32.4	31.9	35.9	42.5	54.8	63.9	68.3	67.8	63.7	54.7	46.8	36.2		
	10%	DB	30.8	30.8	36.2	44.9	59.4	70.8	75.5	74.3	67.5	56.0	45.8	35.3		
		MCWB	29.6	29.5	33.4	39.8	51.7	61.8	66.5	66.0	61.6	52.0	42.9	33.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.2	41.1	44.3	52.2	64.1	72.1	74.6	74.7	70.9	62.5	57.2	45.6		
		MCDB	45.3	42.4	46.5	58.5	73.6	80.9	81.5	83.0	78.9	68.9	58.8	46.3		
	2%	WB	36.8	35.2	39.1	47.2	59.2	68.3	72.0	71.1	67.2	58.4	51.7	40.8		
		MCDB	38.0	36.5	42.0	51.5	66.8	75.7	79.3	78.4	72.5	62.1	53.3	41.8		
	5%	WB	32.4	32.2	36.2	43.3	55.8	65.5	69.8	69.2	64.7	55.2	47.2	36.6		
		MCDB	33.4	33.2	39.0	47.5	62.7	72.1	76.6	75.5	69.5	58.9	49.1	37.8		
	10%	WB	29.5	29.6	33.7	40.3	52.5	62.8	67.9	67.3	62.3	52.5	43.2	34.0		
		MCDB	30.6	30.9	36.0	44.2	59.0	69.3	73.9	72.8	67.0	55.7	45.2	35.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	14.6	14.0	13.1	16.5	16.8	15.5	15.4	14.9	12.4	10.3	10.4		
		MCDBR	18.6	16.7	17.9	19.5	25.9	23.9	19.8	19.8	19.5	17.7	15.4	13.2		
		MCWBR	18.9	15.2	14.3	13.6	15.8	13.8	11.4	11.7	13.0	13.5	14.5	12.9		
	5% WB	MCDBR	18.4	15.4	16.4	18.3	23.5	20.1	17.6	17.6	17.3	16.4	14.8	12.8		
		MCWBR	18.5	14.7	13.9	14.0	15.7	13.2	11.1	11.1	12.6	13.7	14.8	13.1		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.282	0.318	0.354	0.369	0.386	0.418	0.393	0.360	0.334	0.306	0.286		
	taud		2.390	2.309	2.313	2.382	2.416	2.381	2.336	2.397	2.477	2.520	2.522	2.460		
	Ebn at Noon		255	280	286	285	284	278	267	269	269	259	246	239		
	Edh at Noon		22	29	34	35	36	37	38	35	29	24	19	18		
(44) All-Sky Solar Radiation	RadAvg		399	667	1056	1372	1632	1761	1740	1525	1178	733	395	292		
	RadStd		44	73	81	115	146	135	134	96	99	59	49	31		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	-0.92	-1.10	N/A	N/A	N/A	N/A
Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page