

BAS CARAQUET, NB, CanadaWMO: **715980**Lat: **47.800N**Lon: **64.830W**Elev: **5**StdP: **101.26**Time Zone: **-4.00 (NAA)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.1	-18.6	-25.2	0.4	-20.5	-22.9	0.5	-18.2	16.9	-10.0	15.6	-10.2	6.3	270	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	27.6	20.8	25.8	19.8	24.2	18.9	22.0	26.3	20.9	24.6	19.8	23.1	3.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	15.2	24.5	19.4	14.2	23.2	18.5	13.3	22.1	64.6	26.3	60.4	24.6	56.8	23.1	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	12.1	10.6	-24.7	31.2	2.7	1.7	-26.6	32.5	-28.1	33.4	-29.6	34.4	-31.6	35.6		
(5)			-25.0	24.2	2.6	1.3	-26.9	25.1	-28.5	25.8	-30.0	26.6	-31.9	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.3	-8.6	-8.6	-3.9	2.2	8.8	14.9	19.1	18.5	14.3	8.1	2.0	-4.0
	DBStd	10.52	5.55	5.36	4.76	3.41	3.81	3.87	2.81	2.73	3.36	3.47	4.17	4.48
	HDD10.0	2597	577	520	430	236	69	4	0	0	4	81	242	435
	HDD18.3	4859	835	753	688	484	295	118	24	31	128	319	489	693
	CDD10.0	883	0	0	0	1	33	150	281	264	132	21	2	0
	CDD18.3	104	0	0	0	0	1	14	47	37	6	0	0	0
	CDH23.3	550	0	0	0	0	13	101	230	171	33	1	0	0
CDH26.7	101	0	0	0	0	1	22	41	31	6	0	0	0	
Wind	WSAvg	4.5	5.7	5.2	5.1	4.6	4.1	3.6	3.2	3.4	3.9	4.7	5.2	5.8
Precipitation	PrecAvg	1116	94	83	86	80	94	91	94	98	89	117	101	110
	PrecMax	1349	152	155	171	138	181	176	150	171	180	225	169	239
	PrecMin	855	32	21	28	34	25	39	30	25	30	32	36	41
	PrecStd	135	31	35	34	29	38	34	29	38	40	42	30	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	5.9	9.2	16.2	25.4	29.4	30.3	30.0	26.9	21.0	15.3	8.1
		MCWB	6.6	4.8	5.5	9.9	15.9	19.8	21.9	23.0	20.4	16.0	13.6	7.3
	2%	DB	3.4	2.7	6.0	11.8	21.1	26.2	27.6	27.0	23.6	17.4	12.2	5.5
		MCWB	2.6	1.6	3.4	7.5	13.9	18.7	21.2	20.9	18.8	14.0	10.7	4.6
	5%	DB	1.0	0.8	4.1	9.0	18.0	23.7	25.7	25.2	21.5	15.2	9.9	3.4
		MCWB	0.2	0.0	2.2	5.8	12.7	17.7	20.2	19.9	17.6	12.6	8.2	2.4
	10%	DB	-0.7	-0.6	2.3	7.2	15.2	21.6	24.2	23.5	19.7	13.3	7.7	1.8
		MCWB	-1.4	-1.4	0.8	4.3	10.9	16.5	19.2	18.9	16.5	11.1	6.1	0.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	5.1	6.8	11.2	17.9	22.3	23.7	23.7	21.6	17.0	14.0	7.5
		MCDB	7.4	5.8	8.1	14.7	23.1	27.2	27.5	28.3	26.0	20.5	14.9	8.0
	2%	WB	2.7	1.8	3.9	8.4	15.1	20.2	22.2	21.7	19.6	14.6	10.9	4.9
		MCDB	3.4	2.5	5.5	10.8	19.3	24.3	26.3	25.8	22.5	16.7	11.9	5.4
	5%	WB	0.2	0.1	2.3	6.3	13.2	18.6	21.0	20.7	18.2	12.9	8.4	2.6
		MCDB	0.8	0.7	3.9	8.6	17.0	22.3	24.8	24.2	20.8	14.9	9.5	3.2
	10%	WB	-1.4	-1.3	0.9	4.6	11.4	17.1	19.9	19.6	16.9	11.4	6.2	1.1
		MCDB	-0.8	-0.6	2.2	6.8	15.0	20.7	23.3	22.7	19.5	13.2	7.3	1.8
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.1	7.8	7.3	9.2	9.4	8.6	8.5	8.3	6.9	5.7	5.8
		MCDBR	10.3	9.3	9.9	10.9	14.4	13.3	11.0	11.0	10.9	9.8	8.6	7.3
		MCWBR	10.5	8.4	8.0	7.6	8.8	7.6	6.3	6.5	7.2	7.5	8.1	7.2
	5% WB	MCDBR	10.2	8.6	9.1	10.1	13.0	11.2	9.8	9.8	9.6	9.1	8.2	7.1
		MCWBR	10.3	8.2	7.7	7.8	8.7	7.3	6.2	6.2	7.0	7.6	8.2	7.3
Clear-Sky Solar Irradiance	taub	0.280	0.282	0.318	0.354	0.369	0.386	0.418	0.393	0.360	0.334	0.306	0.286	
	taud	2.390	2.309	2.313	2.382	2.416	2.381	2.336	2.397	2.477	2.520	2.522	2.460	
	Ebn at Noon	804	884	901	898	895	877	842	849	849	818	775	755	
	Edh at Noon	68	91	107	111	112	116	120	109	91	75	61	57	
All-Sky Solar Radiation	RadAvg	1.26	2.10	3.33	4.32	5.15	5.55	5.48	4.81	3.71	2.31	1.25	0.92	
	RadStd	0.14	0.23	0.25	0.36	0.46	0.43	0.42	0.30	0.31	0.18	0.15	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-0.51	-0.61	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page