

KEJIMKUJIK, NS, Canada

WMO: 715990

Lat: 44.403N

Lon: 65.203W

Elev: 410

StdP: 14.48

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.4	4.5	-4.4	4.4	2.7	-0.8	5.3	7.6	17.3	42.5	14.6	32.8	2.9	330	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	84.1	68.9	81.2	67.7	78.4	66.5	72.7	79.3	71.0	76.8	69.3	74.4	5.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.8	115.1	75.3	69.1	108.7	73.7	67.5	102.7	72.2	36.7	79.6	35.2	76.8	33.7	74.5	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.8	11.8	9.8	DB	-4.5	89.6	4.3	2.4	-7.6	91.3	-10.1	92.7	-12.5	94.0	-15.6	95.8	(4)
(5)			WB	-5.1	75.8	4.2	2.4	-8.2	77.5	-10.7	78.9	-13.0	80.2	-16.1	82.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.3	23.5	24.7	31.1	41.3	51.9	60.5	67.4	66.3	59.1	48.3	38.9	29.6	(6)	
	DBStd	17.10	10.15	9.69	8.61	7.17	6.62	6.41	4.75	5.03	6.79	7.31	8.32	9.13	(7)	
	HDD50	3557	823	708	587	275	54	3	0	0	7	122	345	633	(8)	
	HDD65	7423	1288	1128	1050	710	409	163	29	46	201	519	784	1096	(9)	
	CDD50	1855	1	0	2	15	112	319	541	504	279	69	12	1	(10)	
	CDD65	243	0	0	0	0	2	28	105	85	22	1	0	0	(11)	
	CDH74	1826	0	0	3	5	59	284	774	572	127	2	0	0	(12)	
	CDH80	380	0	0	0	2	11	66	168	111	22	0	0	0	(13)	
	WSAvg	4.0	4.1	4.4	4.7	4.6	4.2	3.8	3.5	3.3	3.3	3.8	4.1	4.2	(14)	
	PrecAvg	55.9	5.9	4.4	4.8	4.6	4.1	3.9	3.8	3.7	4.5	5.0	6.1	6.4	(15)	
(16) Precipitation	PrecMax	77.3	15.6	9.4	10.7	8.0	11.6	11.2	8.9	10.9	12.7	10.4	10.7	16.5	(16)	
	PrecMin	38.7	1.0	1.5	1.6	1.1	1.4	0.7	0.7	1.4	1.9	0.6	1.6	1.6	(17)	
	PrecStd	8.5	3.1	2.0	2.0	1.6	2.1	2.5	2.0	2.1	2.6	2.4	2.2	3.4	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.1	53.5	60.5	69.8	80.8	86.8	88.3	87.1	82.8	72.6	63.8	57.7	(19)	
		MCWB	53.9	48.6	50.0	56.5	62.3	69.0	71.3	70.5	69.5	63.3	60.2	56.7	(20)	
	2%	DB	49.8	47.6	53.1	63.0	73.9	81.0	84.2	82.9	77.5	67.8	60.0	53.4	(21)	
		MCWB	48.4	45.1	47.3	52.6	59.1	66.8	69.8	68.3	67.3	61.3	57.6	52.2	(22)	
	5%	DB	43.0	42.7	48.5	58.5	69.5	76.7	81.4	80.1	73.8	64.1	56.5	48.3	(23)	
		MCWB	41.5	40.0	43.8	50.5	56.6	63.6	68.1	67.4	65.4	59.5	54.3	47.3	(24)	
	10%	DB	37.5	38.1	44.3	54.6	65.0	73.3	78.5	77.0	70.7	61.0	52.3	42.7	(25)	
		MCWB	36.0	35.8	39.8	47.8	54.3	61.8	66.9	66.2	64.4	56.9	50.0	41.3	(26)	
	0.4%	WB	55.2	51.3	53.1	60.3	66.6	72.6	74.9	74.5	73.3	66.6	62.0	56.9	(27)	
		MCDB	56.3	52.7	56.2	64.7	74.5	80.9	82.6	80.8	77.6	69.2	63.2	57.6	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	48.3	45.5	48.6	56.7	62.6	70.0	72.9	72.4	70.3	63.6	58.4	52.5	(29)	
		MCDB	49.5	46.5	51.1	60.4	69.2	76.8	79.9	78.5	74.5	65.9	59.5	53.4	(30)	
	5%	WB	41.8	40.2	44.5	52.7	59.8	67.3	71.1	70.6	68.2	60.8	54.6	47.5	(31)	
		MCDB	42.9	41.8	47.5	56.4	65.2	72.8	77.3	75.8	71.9	62.9	56.1	48.2	(32)	
	10%	WB	36.2	36.1	40.1	48.6	56.7	64.7	69.3	68.7	65.9	57.4	50.3	41.6	(33)	
		MCDB	37.4	37.9	43.7	53.3	62.4	70.3	74.7	73.5	69.1	60.3	52.1	42.6	(34)	
	5% DB	MDBR	15.6	16.4	16.9	18.2	20.1	20.1	19.6	19.6	19.6	17.7	14.3	13.9	(35)	
		MCDBR	22.5	20.3	23.5	26.3	28.7	26.8	24.5	23.5	22.8	21.3	19.1	19.6	(36)	
		MCWBR	22.0	17.6	17.7	16.7	15.9	14.4	12.6	11.9	13.8	15.2	17.0	19.4	(37)	
		MCWBR	22.6	18.9	21.7	21.3	22.2	21.0	19.2	17.9	17.2	17.4	18.0	19.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.288	0.290	0.317	0.341	0.362	0.389	0.403	0.386	0.354	0.326	0.310	0.295	(40)	
		taud	2.492	2.517	2.487	2.458	2.434	2.372	2.350	2.393	2.457	2.548	2.550	2.519	(41)	
	Ebn at Noon		268	290	293	293	288	279	274	275	276	272	258	254	(42)	
		Edh at Noon	22	25	30	33	35	38	38	35	30	24	21	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		427	700	1079	1380	1584	1742	1752	1597	1295	831	469	336	(44)	
	RadStd		35	59	83	131	195	170	132	105	87	93	52	30	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	+2.03	N/A	N/A	N/A	N/A	N/A	+198	+59	
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	+0.68	+0.90	N/A	N/A	+103	N/A	

Nomenclature: See separate page