

SHEARWATER JETTY, NS, Canada

WMO: 716015

Lat: 44.628N

Lon: 63.522W

Elev: 18

StdP: 14.69

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.4	11.4	-3.0	4.7	10.8	1.7	6.0	13.5	32.2	26.1	29.9	26.6	12.4	330	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	78.5	67.3	75.7	65.7	73.3	64.8	70.0	74.8	68.6	72.7	67.3	70.9	9.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.5	104.8	71.6	67.2	100.1	70.5	65.8	95.3	69.4	34.0	75.1	32.9	72.5	31.8	71.2	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.5	24.2	21.2	DB	1.8	86.5	5.4	5.5	-2.1	90.5	-5.3	93.7	-8.3	96.8	-12.3	100.8	(4)
(5)			WB	1.2	72.4	5.5	1.5	-2.7	73.5	-5.9	74.3	-9.0	75.2	-13.0	76.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	27.8	27.6	32.9	40.8	49.0	57.8	65.1	66.3	61.4	51.9	42.5	34.1
	DBStd	14.99	9.08	7.83	6.97	5.22	4.89	5.46	4.16	3.70	5.13	6.15	7.17	8.03
	HDD50	2994	689	627	532	278	77	4	0	0	0	51	241	495
	HDD65	6886	1154	1047	995	725	496	222	50	28	130	406	674	959
	CDD50	1737	0	0	2	3	47	239	467	507	343	111	17	1
	CDD65	151	0	0	0	0	0	7	52	69	22	1	0	0
	CDH74	445	0	0	5	0	3	48	176	173	39	1	0	0
	CDH80	53	0	0	3	0	0	7	22	17	4	0	0	0
Wind	WSAvg	9.7	12.0	11.8	11.3	10.4	8.6	7.8	6.9	7.0	8.3	10.1	11.2	11.6
Precipitation	PrecAvg	55.7	5.2	4.5	4.8	4.3	4.4	4.1	4.0	3.8	3.8	5.0	5.5	5.9
	PrecMax	70.7	10.7	9.0	9.6	8.2	8.4	13.7	9.0	12.6	8.9	10.1	10.2	10.0
	PrecMin	38.7	1.7	1.3	1.8	0.7	1.0	1.3	0.5	1.0	1.1	1.3	1.5	2.6
	PrecStd	7.8	1.9	1.9	1.8	1.7	1.8	2.2	1.9	2.4	1.8	2.0	2.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	49.4	54.7	61.3	70.8	79.7	83.0	81.9	77.9	70.2	61.1	55.0
		MCWB	50.4	47.1	46.6	50.2	58.2	66.5	69.2	68.8	67.8	63.0	59.0	53.9
	2%	DB	48.1	45.0	48.3	55.4	64.5	73.8	78.5	78.2	74.0	66.1	58.1	51.8
		MCWB	47.2	43.4	43.6	46.2	55.0	62.2	67.3	67.3	66.3	61.7	55.9	50.8
	5%	DB	44.4	41.5	45.0	51.9	60.3	70.3	75.4	75.5	71.1	63.5	56.0	48.9
		MCWB	42.8	39.7	40.8	45.7	52.4	60.7	65.6	65.9	64.6	60.0	54.0	47.6
	10%	DB	40.6	38.7	42.2	49.0	56.9	66.9	72.8	73.1	68.9	61.2	53.7	46.1
		MCWB	38.7	36.7	38.8	44.5	50.4	59.4	64.9	65.0	63.9	57.9	51.7	44.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	47.3	50.3	53.9	61.6	67.6	71.8	71.8	70.8	66.5	60.1	54.1
		MCDB	51.2	48.6	53.1	57.7	66.7	75.1	79.2	76.9	74.0	68.0	61.1	54.7
	2%	WB	47.0	43.2	44.5	50.0	57.4	64.6	70.0	70.1	68.4	63.5	57.2	51.0
		MCDB	47.9	44.2	46.1	52.4	61.3	69.5	75.9	74.3	70.8	65.4	58.1	51.7
	5%	WB	43.5	39.6	41.8	47.6	54.3	62.6	68.3	68.8	66.8	61.2	54.9	48.1
		MCDB	44.5	40.9	43.9	50.2	57.5	66.5	73.5	72.5	69.1	62.9	55.9	49.0
	10%	WB	39.4	36.7	38.9	45.4	51.6	60.5	66.7	67.5	65.2	58.9	52.3	45.1
		MCDB	40.9	38.1	41.2	48.1	55.2	64.0	71.0	70.8	67.7	61.1	53.9	46.3
Mean Daily Temperature Range	5% DB	MDBR	12.9	12.3	11.6	11.6	12.2	12.9	12.4	12.4	11.9	10.7	10.3	11.1
		MCDBR	16.1	14.5	15.6	16.7	18.5	19.1	17.2	16.3	13.9	12.3	11.8	14.0
		MCWBR	15.9	14.6	12.4	11.1	11.0	10.4	8.1	7.3	8.6	9.2	12.0	15.0
	5% WB	MCDBR	15.6	14.7	14.5	13.7	15.7	15.3	14.5	12.1	10.9	10.5	11.8	14.0
MCWBR		16.4	15.1	13.5	11.3	11.4	10.0	8.4	7.1	8.3	9.8	12.8	15.3	
Clear-Sky Solar Irradiance	taub	0.304	0.298	0.325	0.351	0.371	0.401	0.417	0.397	0.355	0.334	0.317	0.298	
	taud	2.469	2.517	2.472	2.444	2.432	2.376	2.353	2.404	2.496	2.551	2.549	2.533	
	Ebn at Noon	260	286	290	289	285	276	269	271	276	268	254	252	
	Edh at Noon	22	25	30	34	35	38	38	35	30	24	21	19	
All-Sky Solar Radiation	RadAvg	455	740	1119	1367	1570	1707	1696	1584	1291	837	481	359	
	RadStd	35	54	76	112	202	159	124	110	85	87	52	28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)	N/A	N/A	N/A	N/A	+0.67	+0.90	N/A	N/A	+101	+31

Nomenclature: See separate page