

YARMOUTH, NS, Canada

WMO: 716030

Lat: 43.8308N

Lon: 66.0886W

Elev: 141

StdP: 14.62

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.0	11.6	1.6	6.0	11.1	4.1	6.8	13.7	32.0	27.4	29.7	28.7	13.0	320	0.659

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.0	74.5	67.3	72.1	65.8	70.2	64.8	69.3	72.2	67.7	70.3	66.3	68.7	10.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	104.6	70.8	66.7	98.7	69.1	65.3	93.9	67.6	33.6	72.5	32.2	70.5	31.0	68.8	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.4	23.8	21.1	DB	3.4	80.1	3.7	2.4	0.7	81.9	-1.4	83.2	-3.5	84.6	-6.1	86.3	(4)
(5)			WB	2.6	72.7	3.5	1.8	0.1	74.0	-2.0	75.1	-4.0	76.2	-6.6	77.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	27.9	28.0	32.9	41.3	49.8	57.1	63.2	63.5	58.7	50.5	42.1	33.7	(6)	
	DBStd	14.10	8.96	7.99	6.97	5.29	4.60	4.31	3.18	3.36	5.07	6.19	7.14	7.87	(7)	
	HDD50	2992	686	615	530	266	61	3	0	0	3	72	251	505	(8)	
	HDD65	7046	1151	1035	995	712	472	238	72	68	197	451	686	969	(9)	
	CDD50	1470	0	0	0	4	54	217	411	420	263	86	14	1	(10)	
	CDD65	50	0	0	0	0	0	2	18	23	7	0	0	0	(11)	
	CDH74	91	0	0	0	0	0	7	36	39	9	0	0	0	(12)	
	CDH80	3	0	0	0	0	0	0	2	1	0	0	0	0	(13)	
(14) Wind	WSAvg	10.7	12.7	12.7	12.3	11.7	10.2	9.3	8.2	8.0	9.0	10.6	11.4	12.3	(14)	
(15) Precipitation	PrecAvg	51.4	5.2	4.5	4.1	4.2	4.0	3.8	3.4	3.3	3.5	4.4	5.4	6.0	(15)	
	PrecMax	68.8	9.4	8.2	6.9	7.6	7.8	8.3	8.0	8.5	8.3	8.0	9.7	11.2	(16)	
	PrecMin	34.8	1.7	1.1	1.1	0.7	0.9	0.9	0.6	0.3	0.8	2.0	1.6	3.3	(17)	
	PrecStd	6.7	1.8	1.8	1.5	1.5	1.9	1.8	2.1	2.1	1.7	1.7	2.0	1.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.4	49.9	53.3	60.1	67.9	74.1	77.7	78.0	74.9	67.8	61.4	55.2	(19)	
		MCWB	51.6	48.7	48.4	52.2	59.7	65.5	69.0	69.1	68.7	63.3	59.6	54.5	(20)	
	2%	DB	48.1	45.5	49.0	55.7	63.4	70.1	74.3	74.5	71.2	64.8	58.7	52.3	(21)	
		MCWB	47.4	44.4	46.9	50.5	56.6	62.7	67.1	67.4	65.7	61.8	57.4	51.6	(22)	
	5%	DB	44.6	42.3	46.0	52.2	60.2	67.1	71.9	72.1	68.8	62.5	55.9	49.2	(23)	
		MCWB	43.6	41.0	43.3	48.3	54.1	61.2	65.7	66.0	64.6	59.9	54.2	48.2	(24)	
	10%	DB	41.2	39.4	43.0	49.7	57.6	64.6	69.8	70.1	66.8	60.2	53.1	45.7	(25)	
		MCWB	39.4	37.8	40.8	46.2	53.0	59.9	64.7	65.0	63.4	57.7	51.3	44.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.3	49.0	50.4	56.6	62.4	67.7	71.7	72.0	70.4	65.5	60.3	54.8	(27)	
		MCDB	52.0	49.6	52.0	57.7	66.0	72.0	75.2	75.0	73.0	66.4	60.9	55.0	(28)	
	2%	WB	47.6	44.8	47.6	52.1	58.6	64.9	69.0	69.7	67.8	62.8	57.7	51.6	(29)	
		MCDB	47.9	45.2	48.6	53.6	61.3	67.9	72.2	72.4	69.6	64.0	58.5	52.1	(30)	
	5%	WB	43.8	41.3	44.1	49.5	56.2	62.8	67.3	67.8	66.0	60.6	54.7	48.5	(31)	
		MCDB	44.6	42.0	45.4	51.1	58.5	65.4	70.1	70.3	67.7	61.8	55.6	49.1	(32)	
	10%	WB	39.7	38.1	41.0	46.8	53.9	61.0	65.9	66.2	64.2	58.2	51.6	44.5	(33)	
		MCDB	40.8	39.1	42.4	48.8	56.7	63.5	68.5	68.6	66.0	59.7	52.9	45.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	12.0	11.6	12.0	12.8	13.2	13.1	13.0	13.0	12.0	11.4	11.7	(35)	
		MCDBR	17.0	14.4	15.6	16.2	17.2	16.9	16.4	15.7	14.5	13.4	13.4	15.0	(36)	
		MCWBR	18.2	14.3	13.6	11.7	11.5	11.3	10.7	9.9	10.0	10.7	13.4	15.9	(37)	
	5% WB	MCDBR	16.9	14.3	15.1	14.1	14.4	14.5	13.9	13.1	11.8	11.7	13.1	15.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.308	0.308	0.333	0.356	0.382	0.410	0.426	0.407	0.368	0.341	0.325	0.310	(40)	
		taud	2.465	2.495	2.456	2.422	2.395	2.325	2.315	2.360	2.431	2.518	2.524	2.498	(41)	
	Ebn at Noon		260	283	288	288	282	273	267	269	272	267	253	249	(42)	
		Edh at Noon	23	26	31	35	37	40	40	37	32	26	22	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		403	695	1116	1430	1624	1796	1780	1623	1348	867	485	336	(44)	
	RadStd		37	67	82	137	207	178	133	94	85	94	57	35	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.67	N/A	+1.35	+1.10	+1.53	+1.69	N/A	N/A	+153	+23
Regional (16 neighbors)		N/A	N/A	+1.69	N/A	+0.88	+1.08	N/A	N/A	+112	+11

Nomenclature: See separate page