

YARMOUTH, NS, Canada

WMO: 716030

Lat: 43.8308N

Lon: 66.0886W

Elev: 43

StdP: 100.81

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -13.3	(c) -11.3	(d) -16.9	(e) 0.9	(f) -11.6	(g) -15.5	(h) 1.0	(i) -10.2	(j) 14.3	(k) -2.6	(l) 13.3	(m) -1.8	(n) 5.8	(o) 320	(p) 0.659

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.2	(c) 23.6	(d) 19.6	(e) 22.3	(f) 18.8	(g) 21.2	(h) 18.2	(i) 20.7	(j) 22.3	(k) 19.8	(l) 21.3	(m) 19.0	(n) 20.4	(o) 4.5	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 20.2	(b) 14.9	(c) 21.6	(d) 19.3	(e) 14.1	(f) 20.6	(g) 18.5	(h) 13.4	(i) 19.8	(j) 60.2	(k) 22.5	(l) 57.0	(m) 21.4	(n) 54.3	(o) 20.4	(p) 24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.6	9.4	-15.9	26.7	2.0	1.3	-17.4	27.7	-18.6	28.5	-19.7	29.2	-21.2	30.2
			-16.3	22.6	2.0	1.0	-17.7	23.4	-18.9	24.0	-20.0	24.5	-21.4	25.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-2.3	-2.2	0.5	5.1	9.9	14.0	17.4	17.5	14.8	10.3	5.6	1.0
	DBStd	7.83	4.98	4.44	3.87	2.94	2.55	2.39	1.76	1.87	2.82	3.44	3.97	4.37
	HDD10.0	1662	381	342	294	148	34	2	0	0	2	40	139	281
	HDD18.3	3914	639	575	553	396	262	132	40	38	109	251	381	538
	CDD10.0	817	0	0	0	2	30	121	228	233	146	48	8	1
	CDD18.3	28	0	0	0	0	0	1	10	13	4	0	0	0
	CDH23.3	51	0	0	0	0	0	4	20	22	5	0	0	0
	CDH26.7	2	0	0	0	0	0	0	1	1	0	0	0	0
Wind	WSAvg	4.8	5.7	5.7	5.5	5.2	4.5	4.2	3.7	3.6	4.0	4.8	5.1	5.5
Precipitation	PrecAvg	1305	133	115	104	106	101	96	86	83	89	111	138	152
	PrecMax	1747	239	209	175	194	197	210	202	215	212	202	246	285
	PrecMin	884	42	29	28	18	24	22	14	8	20	50	40	83
	PrecStd	169	46	45	37	38	48	45	53	54	44	42	51	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	10.0	11.8	15.6	19.9	23.4	25.4	25.5	23.8	19.9	16.3	12.9
		MCWB	10.9	9.3	9.1	11.2	15.4	18.6	20.5	20.6	20.4	17.4	15.3	12.5
	2%	DB	8.9	7.5	9.4	13.2	17.4	21.1	23.5	23.6	21.8	18.2	14.8	11.3
		MCWB	8.5	6.9	8.3	10.3	13.7	17.1	19.5	19.7	18.7	16.6	14.1	10.9
	5%	DB	7.0	5.7	7.8	11.2	15.7	19.5	22.2	22.3	20.4	16.9	13.3	9.6
		MCWB	6.4	5.0	6.3	9.1	12.3	16.2	18.7	18.9	18.1	15.5	12.3	9.0
	10%	DB	5.1	4.1	6.1	9.8	14.2	18.1	21.0	21.2	19.3	15.6	11.7	7.6
		MCWB	4.1	3.2	4.9	7.9	11.7	15.5	18.1	18.3	17.4	14.3	10.7	6.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	9.4	10.2	13.7	16.9	19.8	22.0	22.2	21.3	18.6	15.7	12.7
		MCDB	11.1	9.8	11.1	14.3	18.9	22.2	24.0	23.9	22.8	19.1	16.1	12.8
	2%	WB	8.7	7.1	8.7	11.2	14.8	18.3	20.5	21.0	19.9	17.1	14.3	10.9
		MCDB	8.9	7.4	9.2	12.0	16.3	19.9	22.3	22.4	20.9	17.8	14.7	11.2
	5%	WB	6.6	5.1	6.7	9.7	13.4	17.1	19.6	19.9	18.9	15.9	12.6	9.2
		MCDB	7.0	5.6	7.5	10.6	14.7	18.5	21.2	21.3	19.8	16.6	13.1	9.5
	10%	WB	4.3	3.4	5.0	8.2	12.2	16.1	18.8	19.0	17.9	14.6	10.9	7.0
		MCDB	4.9	3.9	5.8	9.3	13.7	17.5	20.3	20.4	18.9	15.4	11.6	7.5
Mean Daily Temperature Range	5% DB	MDBR	6.8	6.7	6.5	6.7	7.1	7.3	7.3	7.2	7.2	6.7	6.3	6.5
		MCDBR	9.4	8.0	8.6	9.0	9.5	9.4	9.1	8.7	8.1	7.5	7.5	8.3
		MCWBR	10.1	8.0	7.5	6.5	6.4	6.3	6.0	5.5	5.6	6.0	7.4	8.9
	5% WB	MCDBR	9.4	7.9	8.4	7.8	8.0	8.0	7.7	7.3	6.5	6.5	7.3	8.3
		MCWBR	10.1	8.2	8.1	6.8	6.2	6.1	5.7	5.3	5.3	6.1	7.7	9.0
Clear-Sky Solar Irradiance	taub		0.308	0.308	0.333	0.356	0.382	0.410	0.426	0.407	0.368	0.341	0.325	0.310
	taud		2.465	2.495	2.456	2.422	2.395	2.325	2.315	2.360	2.431	2.518	2.524	2.498
	Ebn at Noon		821	892	908	908	890	862	843	847	858	841	797	785
	Edh at Noon		72	83	98	110	116	125	125	116	100	81	68	64
All-Sky Solar Radiation	RadAvg		1.27	2.19	3.52	4.51	5.12	5.66	5.61	5.12	4.25	2.73	1.53	1.06
	RadStd		0.12	0.21	0.26	0.43	0.65	0.56	0.42	0.29	0.27	0.30	0.18	0.11

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.37	N/A	+0.75	+0.61	+0.85	+0.94	N/A	N/A	+85	+13
(47) Regional (16 neighbors)		N/A	N/A	+0.94	N/A	+0.49	+0.60	N/A	N/A	+62	+6

Nomenclature: See separate page