

NORTH MOUNTAIN, NS, Canada

WMO: 716040

Lat: 46.818N

Lon: 60.673W

Elev: 1442

StdP: 13.95

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.1	3.2	-3.3	4.8	1.4	0.3	5.9	4.6	40.7	6.3	36.4	8.5	17.6	270	0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	77.7	66.5	74.9	64.9	72.5	63.8	69.2	74.4	67.7	72.1	66.2	70.3	10.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	106.4	71.7	66.1	101.5	70.2	64.5	95.9	69.0	34.3	74.8	33.0	72.1	31.7	70.4	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.7	26.0	23.1	DB	-2.3	83.8	3.0	2.6	-4.4	85.7	-6.2	87.2	-7.8	88.7	-10.0	90.5	(4)
(5)			WB	-1.7	72.1	4.3	1.7	-4.9	73.3	-7.4	74.3	-9.8	75.3	-13.0	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.2	20.8	17.9	24.4	33.6	45.0	53.6	62.7	62.2	55.1	44.7	35.1	25.4	
	DBStd	17.25	9.06	8.93	8.58	7.83	8.49	8.16	5.92	5.24	6.96	7.17	8.35	7.95	
	HDD50	4793	905	899	795	493	209	52	1	0	26	197	453	763	
	HDD65	9153	1370	1319	1260	941	621	352	115	117	304	629	897	1228	
	CDD50	1211	0	0	0	2	53	160	396	380	181	33	6	0	
	CDD65	94	0	0	0	0	0	10	44	32	8	0	0	0	
	CDH74	334	0	0	0	0	4	39	155	112	23	1	0	0	
	CDH80	29	0	0	0	0	0	6	10	10	3	0	0	0	
Wind	WSAvg	11.2	13.7	14.0	12.3	11.2	9.5	9.0	8.6	8.6	10.1	11.4	12.4	13.5	
Precipitation	PrecAvg	57.7	5.8	4.6	4.4	4.1	3.5	3.5	3.4	4.4	4.6	6.5	5.5	6.7	
	PrecMax	68.1	8.7	7.4	7.4	7.1	6.3	7.4	6.2	10.4	11.3	10.0	9.3	15.9	
	PrecMin	40.4	2.7	2.0	1.9	2.2	1.3	1.7	1.4	2.1	1.1	2.6	3.6	3.1	
	PrecStd	6.1	1.6	1.5	1.5	1.4	1.3	1.3	1.3	1.9	2.6	2.0	1.4	2.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	48.7	50.4	59.9	73.2	77.9	81.3	81.0	77.0	67.7	60.9	54.0	
		MCWB	51.6	47.5	44.5	52.6	55.8	64.7	68.5	67.9	67.7	60.7	58.0	52.7	
	2%	DB	47.2	40.5	45.5	54.6	68.4	74.0	78.0	77.2	72.4	63.0	57.8	47.0	
		MCWB	45.8	39.7	42.1	49.8	56.5	62.7	67.1	66.5	65.1	57.6	55.8	45.7	
	5%	DB	39.3	33.3	41.4	50.2	63.5	70.7	75.3	73.9	69.1	59.5	53.7	41.5	
		MCWB	38.3	32.2	38.7	45.8	53.3	60.8	65.6	65.0	63.3	55.9	51.8	40.5	
	10%	DB	32.4	29.5	36.3	45.8	58.8	67.0	72.8	71.1	65.9	55.7	48.5	36.8	
		MCWB	31.9	28.8	33.6	41.8	52.0	59.0	64.6	63.9	61.7	52.4	46.6	36.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.8	47.5	47.2	55.5	63.1	68.8	71.7	70.9	70.1	63.4	58.9	52.7
			MCDB	53.3	49.0	48.9	57.6	69.0	74.7	77.8	77.4	74.5	65.9	60.6	53.6
2%		WB	45.9	40.3	43.2	51.4	59.6	66.3	69.5	68.7	66.9	59.4	56.3	46.3	
		MCDB	47.3	40.9	44.8	53.6	63.6	70.9	75.0	73.7	70.4	61.6	57.8	47.1	
5%		WB	38.0	32.7	38.8	46.7	56.1	63.5	68.0	67.1	64.7	56.2	52.3	41.0	
		MCDB	38.6	33.5	41.4	48.8	60.8	67.5	72.5	71.5	68.1	58.8	53.6	41.8	
10%		WB	31.5	28.8	34.1	42.5	52.3	60.4	66.5	65.5	62.3	52.7	47.0	36.7	
		MCDB	32.0	29.1	36.5	45.6	58.4	65.8	70.7	69.7	65.2	55.3	48.4	37.4	
Mean Daily Temperature Range		5% DB	MDBR	12.2	12.2	12.0	12.9	15.1	15.4	14.7	13.4	13.6	11.1	10.8	9.6
			MCDBR	22.7	21.5	20.1	19.2	20.4	19.2	17.5	17.3	16.7	16.6	19.0	18.3
	MCWBR		21.9	21.4	17.7	15.2	12.4	12.4	10.7	10.6	11.1	12.9	18.0	17.7	
	5% WB	MCDBR	22.5	21.6	19.8	19.0	18.4	16.3	15.0	14.8	15.2	16.0	19.0	18.2	
		MCWBR	21.9	21.4	18.5	17.2	14.1	12.2	10.0	10.6	11.6	14.2	18.4	17.8	
	Clear-Sky Solar Irradiance	taub	0.285	0.278	0.309	0.334	0.347	0.365	0.389	0.369	0.341	0.327	0.307	0.290	
taud		2.386	2.360	2.323	2.426	2.474	2.426	2.409	2.470	2.524	2.527	2.504	2.414		
Ebn at Noon		257	285	291	293	291	285	276	278	278	265	248	241		
Edh at Noon		22	28	34	34	34	36	36	32	28	24	20	20		
All-Sky Solar Radiation	RadAvg	292	541	954	1336	1623	1745	1748	1544	1175	716	357	222		
	RadStd	23	71	100	114	132	162	122	100	95	66	42	18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	+0.79	N/A	N/A	N/A	N/A

Nomenclature: See separate page