

NORTH MOUNTAIN, NS, Canada

WMO: 716040

Lat: 46.818N

Lon: 60.673W

Elev: 439

StdP: 96.16

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.7	-16.0	-19.6	0.7	-17.0	-17.6	0.8	-15.2	18.2	-14.3	16.3	-13.1	7.9	270	0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	25.4	19.2	23.8	18.3	22.5	17.7	20.7	23.6	19.8	22.3	19.0	21.3	4.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	15.2	22.1	18.9	14.5	21.2	18.1	13.7	20.6	61.8	23.8	58.8	22.3	56.0	21.3	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	11.6	10.3	-19.1	28.8	1.6	1.4	-20.2	29.8	-21.2	30.7	-22.1	31.5	-23.3	32.5		
(5)			-18.7	22.3	2.4	1.0	-20.5	23.0	-21.9	23.5	-23.2	24.1	-25.0	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-6.2	-7.8	-4.2	0.9	7.2	12.0	17.1	16.8	12.9	7.1	1.7	-3.7	(6)
(7)		DBStd	9.58	5.03	4.96	4.77	4.35	4.72	4.53	3.29	2.91	3.87	3.98	4.64	4.42	(7)
(8)		HDD10.0	2663	503	499	442	274	116	29	1	0	14	109	252	424	(8)
(9)		HDD18.3	5085	761	733	700	523	345	196	64	65	169	349	498	682	(9)
(10)		CDD10.0	673	0	0	0	1	29	89	220	211	101	18	3	0	(10)
(11)		CDD18.3	52	0	0	0	0	0	6	24	18	4	0	0	0	(11)
(12)		CDH23.3	186	0	0	0	0	2	22	86	62	13	1	0	0	(12)
(13)		CDH26.7	16	0	0	0	0	0	3	6	6	2	0	0	0	(13)
(14)	Wind	WSAvg	5.0	6.1	6.3	5.5	5.0	4.2	4.0	3.8	3.9	4.5	5.1	5.5	6.0	(14)
(15)	Precipitation	PrecAvg	1465	147	117	111	103	89	89	86	112	117	164	139	171	(15)
(16)		PrecMax	1729	222	187	189	180	160	188	158	264	286	253	236	403	(16)
(17)		PrecMin	1027	68	50	49	55	32	44	35	53	29	67	91	78	(17)
(18)		PrecStd	155	41	39	37	36	32	34	33	49	66	50	35	64	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	9.3	10.2	15.5	22.9	25.5	27.4	27.2	25.0	19.8	16.1	12.2	(19)
(20)			MCWB	10.9	8.6	7.0	11.5	13.2	18.2	20.3	19.9	19.8	16.0	14.4	11.5	(20)
(21)		2%	DB	8.5	4.7	7.5	12.6	20.2	23.3	25.6	25.1	22.4	17.2	14.3	8.3	(21)
(22)			MCWB	7.7	4.3	5.6	9.9	13.6	17.0	19.5	19.2	18.4	14.2	13.2	7.6	(22)
(23)		5%	DB	4.1	0.7	5.2	10.1	17.5	21.5	24.0	23.3	20.6	15.3	12.1	5.3	(23)
(24)			MCWB	3.5	0.1	3.7	7.6	11.8	16.0	18.7	18.3	17.4	13.3	11.0	4.7	(24)
(25)		10%	DB	0.2	-1.4	2.4	7.7	14.9	19.5	22.7	21.7	18.8	13.2	9.2	2.7	(25)
(26)			MCWB	-0.1	-1.8	0.9	5.5	11.1	15.0	18.1	17.7	16.5	11.3	8.1	2.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	8.6	8.4	13.1	17.3	20.4	22.1	21.6	21.2	17.5	15.0	11.5	(27)
(28)			MADB	11.9	9.4	9.4	14.2	20.5	23.7	25.4	25.2	23.6	18.8	15.9	12.0	(28)
(29)		2%	WB	7.7	4.6	6.2	10.8	15.3	19.0	20.8	20.4	19.4	15.2	13.5	8.0	(29)
(30)			MADB	8.5	4.9	7.1	12.0	17.5	21.6	23.9	23.1	21.3	16.4	14.3	8.4	(30)
(31)		5%	WB	3.3	0.4	3.8	8.2	13.4	17.5	20.0	19.5	18.2	13.5	11.3	5.0	(31)
(32)			MADB	3.7	0.8	5.2	9.3	16.0	19.7	22.5	21.9	20.1	14.9	12.0	5.5	(32)
(33)		10%	WB	-0.3	-1.8	1.2	5.8	11.3	15.8	19.2	18.6	16.8	11.5	8.3	2.6	(33)
(34)			MADB	0.0	-1.6	2.5	7.6	14.7	18.8	21.5	20.9	18.4	12.9	9.1	3.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.8	6.7	7.1	8.4	8.6	8.1	7.4	7.6	6.2	6.0	5.3	(35)
(36)			MCDBR	12.6	12.0	11.2	10.7	11.4	10.7	9.7	9.6	9.3	9.2	10.5	10.1	(36)
(37)			MCWBR	12.2	11.9	9.8	8.4	6.9	6.9	5.9	5.9	6.1	7.2	10.0	9.8	(37)
(38)		5% WB	MCDBR	12.5	12.0	11.0	10.5	10.2	9.0	8.4	8.2	8.4	8.9	10.5	10.1	(38)
(39)			MCWBR	12.2	11.9	10.3	9.6	7.8	6.8	5.6	5.9	6.4	7.9	10.2	9.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.285	0.278	0.309	0.334	0.347	0.365	0.389	0.369	0.341	0.327	0.307	0.290	(40)	
(41)		taud	2.386	2.360	2.323	2.426	2.474	2.426	2.409	2.470	2.524	2.527	2.504	2.414	(41)	
(42)		Ebn at Noon	810	900	916	923	918	899	871	877	876	835	783	759	(42)	
(43)		Edh at Noon	70	88	107	107	106	112	112	102	88	76	64	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.92	1.71	3.01	4.21	5.12	5.50	5.51	4.87	3.70	2.26	1.13	0.70	(44)	
(45)		RadStd	0.07	0.22	0.31	0.36	0.42	0.51	0.39	0.32	0.30	0.21	0.13	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.44	N/A	N/A	N/A	N/A

Nomenclature: See separate page