

PORT MELLON, BC, Canada

WMO: 716050

Lat: 49.526N

Lon: 123.496W

Elev: 402

StdP: 14.48

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.3	26.3	10.9	9.8	29.7	16.4	12.8	30.3	11.1	39.6	9.6	39.6	3.3	350	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	81.3	65.0	78.3	64.0	75.3	62.6	66.4	78.4	65.1	75.8	63.7	73.0	2.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.1	84.6	69.9	60.8	80.7	69.1	59.6	77.4	67.7	31.3	78.6	30.2	76.1	29.2	73.2	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	7.5	6.3	DB	18.7	88.6	3.7	2.5	16.0	90.4	13.9	91.9	11.8	93.3	9.1	95.1	(4)
(5)			WB	17.4	69.2	4.3	0.9	14.3	69.8	11.8	70.3	9.4	70.8	6.3	71.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	38.6	39.5	43.2	47.5	55.5	59.7	65.8	65.7	59.5	50.6	42.8	37.6
	DBStd	11.27	5.09	5.74	4.78	4.52	5.70	5.48	4.75	4.75	5.42	4.48	5.68	5.27
	HDD50	1628	353	293	217	100	13	1	0	0	1	46	221	383
	HDD65	5442	817	713	676	526	297	177	46	48	181	448	665	848
	CDD50	1839	0	0	6	25	185	293	488	486	287	63	6	0
	CDD65	177	0	0	0	0	4	19	69	69	16	0	0	0
	CDH74	926	0	0	0	0	21	122	393	322	68	0	0	0
	CDH80	155	0	0	0	0	1	19	76	53	6	0	0	0
Wind	WSAvg	2.3	2.4	2.4	2.8	3.0	2.4	2.2	2.0	1.9	2.0	2.0	2.3	2.4
Precipitation	PrecAvg	90.8	12.6	8.8	9.3	5.7	3.7	3.1	2.2	3.1	4.5	10.5	14.4	13.0
	PrecMax	120.7	23.9	20.1	17.4	12.2	6.8	6.5	4.4	12.5	10.9	22.7	28.6	19.8
	PrecMin	71.4	5.6	0.6	2.1	1.4	1.1	1.1	0.6	0.4	0.7	1.0	6.0	6.1
	PrecStd	11.9	3.9	4.2	3.4	2.5	1.4	1.5	1.2	2.8	2.6	4.8	6.3	3.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.6	53.6	61.3	66.9	76.8	82.9	86.8	86.1	80.3	66.6	56.8	51.5
		MCWB	50.1	46.3	51.7	52.4	59.1	64.3	66.9	66.8	64.1	56.7	54.5	50.7
	2%	DB	48.6	51.0	55.9	61.5	72.4	77.6	81.7	80.5	75.4	61.9	54.1	48.0
		MCWB	46.7	47.1	47.8	49.6	57.9	62.3	65.1	65.5	62.0	54.9	52.2	46.6
	5%	DB	47.0	48.7	52.6	58.2	68.9	72.9	78.3	77.5	71.3	59.2	52.0	46.2
		MCWB	45.4	45.8	46.5	48.8	57.0	60.4	64.4	64.4	60.0	54.4	50.3	45.2
	10%	DB	45.1	46.7	50.0	55.0	65.2	69.2	75.1	74.5	67.8	56.7	50.0	44.3
		MCWB	43.7	44.2	45.8	47.5	55.3	58.8	62.9	63.1	59.0	52.7	48.2	43.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	51.1	53.0	54.7	61.2	66.5	68.5	68.3	65.9	59.8	55.4	50.9
		MCDB	51.2	51.2	58.2	62.5	71.5	79.5	82.3	80.1	76.0	63.0	56.0	51.4
	2%	WB	47.6	48.5	50.1	52.3	59.3	63.5	66.5	66.4	63.6	57.5	52.7	47.2
		MCDB	48.1	49.2	53.5	58.3	69.2	75.1	79.2	77.8	71.5	59.8	53.7	47.6
	5%	WB	45.8	46.3	47.7	50.3	57.7	61.2	65.0	65.2	61.8	55.2	50.7	45.2
		MCDB	46.5	48.2	50.5	55.1	66.4	70.6	76.0	75.7	68.4	57.4	51.8	45.6
	10%	WB	43.9	44.5	46.2	48.6	56.1	59.5	63.6	63.8	60.2	53.3	48.6	43.3
		MCDB	44.9	46.3	49.0	53.0	63.8	67.8	73.3	72.8	65.8	56.0	49.6	43.9
Mean Daily Temperature Range	5% DB	MDBR	6.9	8.5	10.1	12.5	14.0	13.4	15.6	14.5	12.3	9.6	7.7	6.2
		MCDBR	8.1	10.1	14.4	17.6	19.8	19.7	20.3	19.2	17.4	13.3	8.8	7.2
		MCWBR	6.4	7.0	8.7	9.7	10.1	9.6	9.3	9.2	9.1	8.3	7.1	6.3
	5% WB	MCDBR	6.7	7.8	11.2	13.7	17.3	17.8	18.7	18.0	14.7	10.3	7.7	6.5
		MCWBR	6.1	6.1	7.9	8.7	9.3	9.2	9.0	8.9	8.3	7.3	6.8	6.0
Clear-Sky Solar Irradiance	taub	0.311	0.304	0.328	0.358	0.374	0.367	0.358	0.360	0.340	0.331	0.313	0.298	
	taud	2.396	2.470	2.422	2.376	2.383	2.425	2.478	2.487	2.543	2.546	2.500	2.428	
	Ebn at Noon	233	270	280	282	281	283	284	279	274	257	234	223	
	Edh at Noon	21	24	30	35	36	35	33	31	27	23	19	17	
All-Sky Solar Radiation	RadAvg	263	532	782	1234	1632	1731	1956	1665	1139	626	306	209	
	RadStd	47	85	116	142	148	226	189	140	106	95	62	35	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page