

MONT-ORFORD, QC, Canada

WMO: 716181

Lat: 45.312N

Lon: 72.242W

Elev: 846

StdP: 91.57

Time Zone: -5.00 (NAE)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.3	-25.1	-31.7	0.2	-28.0	-28.2	0.3	-24.9	18.3	-2.5	16.5	-7.3	7.6	300	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	25.1	18.5	23.5	17.7	22.0	17.1	20.5	23.1	19.3	21.5	18.3	20.5	4.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.7	16.0	21.8	18.6	14.9	20.5	17.5	13.9	19.4	63.2	23.3	58.8	21.6	55.3	20.5	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.7	13.5	12.2	-30.0	28.2	3.2	1.9	-32.4	29.6	-34.3	30.7	-36.1	31.7	-38.4	33.1		
			-30.7	22.3	3.0	1.7	-32.8	23.5	-34.6	24.5	-36.3	25.5	-38.5	26.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-12.0	-10.6	-5.7	1.3	8.8	14.9	16.5	15.9	11.7	4.6	-1.6	-7.9	(6)	(7)
	DBStd	11.44	7.70	6.81	6.42	5.23	4.83	4.38	3.20	3.44	4.19	5.12	5.28	5.87	(7)	(8)
	HDD10.0	3216	682	577	486	264	81	9	1	1	29	183	347	555	(8)	(9)
	HDD18.3	5628	941	810	744	510	298	119	74	92	203	427	597	813	(9)	(10)
	CDD10.0	684	0	0	1	4	43	156	203	183	79	14	0	0	(10)	(11)
	CDD18.3	54	0	0	0	0	1	16	18	15	4	0	0	0	(11)	(12)
	CDH23.3	158	0	0	0	0	3	64	43	34	14	0	0	0	(12)	(13)
	CDH26.7	15	0	0	0	0	0	8	3	2	2	0	0	0	(13)	(14)
(14) Wind	WSAvg	6.1	6.5	6.7	6.3	6.4	6.1	5.3	5.3	5.1	6.2	6.5	6.2	6.2	(14)	(15)
(15) Precipitation	PrecAvg	1182	89	67	78	86	97	114	131	117	101	110	93	99	(15)	(16)
	PrecMax	1415	156	94	114	189	158	169	226	189	215	233	143	203	(16)	(17)
	PrecMin	900	42	36	38	9	49	70	56	34	47	43	45	50	(17)	(18)
	PrecStd	130	29	18	19	43	27	31	40	39	42	52	25	38	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	5.6	12.4	18.7	23.6	27.9	26.7	26.3	25.4	20.0	13.2	7.7	(19)	(20)
		MCWB	9.1	3.3	9.9	12.3	14.8	21.4	21.3	19.6	17.8	14.7	11.9	6.2	(20)	(21)
	2%	DB	4.5	3.0	7.9	14.8	20.7	25.1	24.4	24.1	21.4	16.8	10.1	5.0	(21)	(22)
		MCWB	3.9	1.7	4.4	9.2	13.2	18.0	19.3	18.0	16.5	12.7	8.6	3.7	(22)	(23)
	5%	DB	0.1	0.5	5.3	11.7	18.1	23.1	22.8	22.3	19.2	14.5	8.3	2.4	(23)	(24)
		MCWB	0.0	-0.5	3.0	6.4	11.6	17.2	18.3	17.4	15.2	11.0	6.9	1.6	(24)	(25)
	10%	DB	-2.4	-1.4	3.0	8.8	15.9	21.3	21.3	20.8	17.3	11.9	6.3	0.0	(25)	(26)
		MCWB	-2.6	-2.4	1.0	5.2	11.0	16.5	17.7	16.6	14.7	9.2	5.0	-0.5	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	4.6	10.1	14.3	17.5	22.4	22.5	21.0	19.0	16.3	12.0	7.4	(27)	(28)
		MCDB	8.3	5.0	13.0	16.6	20.8	25.6	24.9	24.5	22.3	18.6	12.7	8.3	(28)	(29)
	2%	WB	3.7	1.8	6.1	10.2	15.3	20.2	20.7	19.5	17.7	13.1	9.2	4.1	(29)	(30)
		MCDB	3.9	2.6	7.2	13.3	18.2	22.7	22.9	22.0	20.1	15.9	9.5	4.4	(30)	(31)
	5%	WB	-0.2	-0.4	3.5	7.6	13.4	18.7	19.5	18.5	16.3	11.5	7.4	1.5	(31)	(32)
		MCDB	0.0	0.4	4.6	10.4	16.4	21.0	21.6	20.8	18.5	13.9	8.0	2.3	(32)	(33)
	10%	WB	-2.7	-2.3	1.1	5.5	11.8	17.3	18.4	17.5	15.1	9.7	5.0	-0.7	(33)	(34)
		MCDB	-2.6	-1.5	3.1	8.5	14.7	19.8	20.3	19.8	16.7	11.4	5.9	-0.1	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	7.5	7.2	7.4	7.9	7.9	7.1	7.1	7.1	6.1	6.0	6.6	(35)	(36)
		MCDBR	9.9	7.8	9.3	10.9	10.6	9.5	8.3	8.1	8.4	8.5	9.1	7.8	(36)	(37)
	5% WB	MCWBR	10.0	7.2	7.4	7.3	6.2	5.6	5.1	5.1	5.3	5.7	8.3	7.5	(37)	(38)
		MCWBR	10.0	8.3	9.1	10.1	9.4	8.2	7.4	7.2	7.1	8.2	9.1	7.7	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.236	0.258	0.286	0.314	0.332	0.370	0.375	0.358	0.328	0.297	0.277	0.252	(39)	(40)
		taud	2.424	2.329	2.399	2.458	2.460	2.326	2.316	2.370	2.460	2.564	2.537	2.425	(40)	(41)
	Ebn at Noon		906	937	954	948	935	896	886	891	894	886	845	840	(41)	(42)
		Edh at Noon	69	92	101	104	108	124	124	113	95	74	63	63	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		1.43	2.34	3.55	4.33	5.02	5.53	5.56	4.94	3.95	2.28	1.39	1.00	(43)	(44)
	RadStd		0.17	0.26	0.27	0.51	0.51	0.43	0.43	0.25	0.32	0.21	0.18	0.09	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+60	N/A

Nomenclature: See separate page