

UT MISSISSAUGA, ON, Canada

WMO: 716245

Lat: 43.5525N

Lon: 79.6665W

Elev: 433

StdP: 14.47

Time Zone: -5.00 (NAE)

Period: 00-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	4.0	-6.5	4.0	0.5	-1.1	5.3	5.9	29.0	27.9	26.0	26.4	8.2	250	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	89.6	76.0	86.3	74.0	83.3	72.2	78.7	85.6	76.4	83.2	74.4	80.8	10.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.9	142.4	81.9	74.5	131.0	80.4	72.3	121.4	78.0	42.5	86.1	40.2	83.4	38.2	81.0	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.5	22.9	20.0	-6.6	94.6	6.3	3.1	-11.1	96.8	-14.8	98.6	-18.3	100.3	-22.8	102.5		
			-7.0	81.1	6.1	2.0	-11.4	82.5	-15.0	83.7	-18.4	84.8	-22.8	86.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	24.2	24.9	33.4	44.7	56.6	65.6	70.4	69.5	62.3	50.0	40.0	29.1
	DBStd	18.45	10.71	9.76	9.70	8.42	8.05	6.56	5.39	5.30	6.88	7.83	7.98	8.94
	HDD50	3310	801	704	520	202	24	0	0	0	2	98	311	648
	HDD65	6826	1266	1124	980	610	285	71	11	18	129	468	751	1113
	CDD50	2463	0	0	6	43	228	469	632	604	371	98	11	1
	CDD65	502	0	0	0	1	24	90	178	157	49	3	0	0
	CDH74	4577	0	0	1	42	318	908	1615	1259	405	29	0	0
	CDH80	1458	0	0	0	11	95	303	550	375	120	4	0	0
Wind	WSAvg	8.7	10.2	10.9	11.1	11.1	8.8	6.7	6.4	6.2	5.9	7.5	8.8	10.5
Precipitation	PrecAvg	31.7	2.3	2.1	2.1	2.9	2.8	3.1	3.1	2.9	2.6	2.7	2.6	2.4
	PrecMax	40.4	5.1	4.3	4.3	5.1	5.1	6.7	7.0	5.5	6.5	5.2	5.0	4.5
	PrecMin	23.5	0.9	1.1	0.8	1.1	0.4	1.2	0.8	0.7	0.7	0.7	0.8	1.0
	PrecStd	4.6	1.0	0.9	1.0	1.1	1.1	1.6	1.5	1.2	1.2	1.3	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	55.6	67.0	79.3	87.5	91.7	93.5	93.0	89.7	78.0	65.0	54.8
		MCWB	50.7	51.5	56.7	61.7	72.9	76.0	78.8	76.8	74.9	67.2	57.3	51.6
	2%	DB	46.3	46.0	58.6	71.2	82.4	87.9	89.5	87.4	83.2	71.2	59.8	48.8
		MCWB	44.3	42.5	50.8	56.9	69.6	74.2	76.4	75.2	72.1	64.1	55.0	47.1
	5%	DB	41.2	41.0	52.6	65.3	76.7	83.3	86.0	84.1	78.4	65.9	56.7	44.5
		MCWB	39.4	38.5	46.7	53.8	65.2	72.1	73.9	73.2	69.0	61.0	52.9	42.9
	10%	DB	38.0	37.7	46.9	59.6	71.9	79.3	82.7	80.9	74.3	62.0	52.3	41.0
		MCWB	36.7	35.7	42.4	50.2	61.7	68.9	71.9	71.1	67.3	58.7	49.2	39.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.9	52.3	59.1	64.2	76.4	79.9	82.8	81.2	78.6	69.9	59.6	52.5
		MCDB	53.1	54.0	64.5	72.6	86.5	86.5	89.4	86.1	85.6	75.0	62.1	54.1
	2%	WB	44.4	43.0	52.5	59.9	71.5	76.4	78.7	78.0	74.1	65.6	56.4	47.3
		MCDB	46.3	45.1	56.3	67.9	79.6	85.1	85.7	83.6	79.8	69.2	58.9	48.5
	5%	WB	39.8	38.8	47.0	55.1	67.3	73.8	76.4	75.6	71.3	62.1	52.9	43.2
		MCDB	40.8	40.4	51.8	63.4	73.6	81.4	83.1	81.3	75.8	64.8	56.3	44.3
	10%	WB	36.7	35.8	42.6	50.8	63.7	70.8	74.0	73.5	68.8	59.3	49.5	39.6
		MCDB	37.9	37.4	46.3	58.5	70.2	76.5	80.1	79.2	72.9	61.9	51.9	40.8
Mean Daily Temperature Range	5% DB	MDBR	14.6	16.4	17.8	21.0	22.2	21.2	21.4	20.9	20.6	17.4	15.9	12.6
		MCDBR	16.2	19.4	25.9	31.8	28.9	27.0	25.1	24.3	26.4	23.2	21.9	15.8
		MCWBR	14.1	15.8	17.6	19.0	16.5	15.6	13.5	13.3	15.0	15.5	16.5	13.7
	5% WB	MCDBR	15.5	18.6	23.8	28.7	25.9	24.8	21.9	20.7	22.2	20.9	20.0	15.7
		MCWBR	14.3	16.1	17.7	19.5	16.9	15.9	14.1	13.3	14.4	15.5	16.3	14.3
Clear-Sky Solar Irradiance	taub	0.295	0.325	0.334	0.380	0.406	0.438	0.430	0.416	0.384	0.363	0.316	0.299	
	taud	2.404	2.301	2.395	2.303	2.281	2.217	2.265	2.293	2.362	2.402	2.494	2.442	
	Ebn at Noon	265	273	287	280	275	266	266	266	266	257	256	252	
	Edh at Noon	24	32	33	39	41	44	42	39	34	29	22	22	
All-Sky Solar Radiation	RadAvg	451	685	1092	1403	1701	1855	1857	1632	1310	788	495	357	
	RadStd	44	64	110	152	179	132	135	83	122	71	62	39	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page