

MONTREAL MIRABEL INTL, QC, Canada

WMO: 716278

Lat: 45.6685N

Lon: 74.0322W

Elev: 82

StdP: 100.34

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -25.7	(c) -22.8	(d) -31.8	(e) 0.2	(f) -24.8	(g) -28.9	(h) 0.3	(i) -22.1	(j) 9.6	(k) -5.1	(l) 8.7	(m) -6.5	(n) 2.5	(o) 240	(p) 0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	29.7	22.0	28.1	20.9	26.7	20.0	23.2	27.8	22.2	26.4	21.2	25.1	3.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.8	16.6	25.9	20.7	15.6	24.7	19.8	14.7	23.7	69.7	27.8	65.5	26.5	61.9	25.0	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.2	(b) 7.0	(c) 6.1	(e) -29.2	(f) 32.2	(g) 3.3	(h) 1.5	(i) -31.6	(j) 33.3	(k) -33.5	(l) 34.1	(m) -35.4	(n) 35.0	(o) -37.8	(p) 36.1		
(a) 8.2	(b) 7.0	(c) 6.1	(e) -29.5	(f) 25.4	(g) 3.2	(h) 1.1	(i) -31.8	(j) 26.2	(k) -33.7	(l) 26.9	(m) -35.5	(n) 27.5	(o) -37.9	(p) 28.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-10.8	-8.9	-2.9	5.4	13.0	18.0	20.4	19.4	15.2	8.1	1.1	-6.1		
	DBStd	11.96	7.28	6.34	5.85	4.67	4.18	3.63	2.74	2.96	4.06	4.32	5.00	6.29		
	HDD10.0	2606	644	528	402	152	17	1	0	0	4	90	269	500		
	HDD18.3	4669	902	762	659	389	171	49	11	23	109	317	518	758		
	CDD10.0	1172	0	0	1	12	111	240	322	292	162	31	1	0		
	CDD18.3	196	0	0	0	1	7	39	74	57	17	1	0	0		
	CDH23.3	1468	0	0	1	7	88	323	543	385	119	3	0	0		
	CDH26.7	319	0	0	0	1	17	76	124	78	25	0	0	0		
(14) Wind	WSAvg	2.7	3.1	3.1	3.1	3.3	2.9	2.4	2.2	2.0	2.1	2.6	2.8	2.9		
(15) Precipitation	PrecAvg	1095	92	65	76	91	94	101	103	87	91	105	90	90		
	PrecMax	1456	147	103	131	161	191	158	184	129	152	189	137	166		
	PrecMin	856	31	34	32	22	50	43	41	30	28	33	30	38		
	PrecStd	147	33	19	25	44	35	32	33	29	30	49	25	36		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	6.4	13.9	23.6	28.7	31.1	31.9	31.0	29.9	23.1	15.6	8.5		
		MCWB	5.2	3.9	9.4	15.0	19.7	22.9	23.5	22.8	21.8	17.2	12.7	7.1		
	2%	DB	3.1	3.7	9.0	19.2	25.8	28.9	29.6	28.7	26.5	19.9	12.7	5.4		
		MCWB	2.0	1.9	5.2	11.4	17.2	21.3	22.3	21.5	20.3	15.4	10.5	4.2		
	5%	DB	1.5	2.0	6.2	15.8	23.3	26.9	27.9	27.1	24.2	17.0	10.1	3.2		
		MCWB	0.7	0.8	3.0	9.5	15.7	19.8	21.2	20.4	18.9	13.1	7.8	2.0		
	10%	DB	-0.2	0.6	4.3	13.0	20.9	25.0	26.4	25.5	22.2	14.7	7.8	1.6		
		MCWB	-0.9	-0.5	1.8	7.6	14.4	18.5	20.2	19.7	17.8	11.7	5.9	0.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	4.4	10.7	16.4	21.2	24.4	25.2	24.0	22.9	18.8	13.5	7.5		
		MCDB	6.0	5.6	12.8	22.3	26.9	29.5	30.3	29.2	27.5	21.8	14.7	8.2		
	2%	WB	2.3	2.2	5.8	12.7	19.0	22.5	23.5	22.6	21.2	15.8	10.8	4.4		
		MCDB	2.7	3.3	8.3	16.8	23.5	27.3	27.8	26.9	25.0	18.7	12.4	5.2		
	5%	WB	0.7	0.9	3.6	10.3	17.2	21.0	22.3	21.6	19.9	13.9	8.1	2.2		
		MCDB	1.4	1.8	5.7	14.6	21.1	25.0	26.4	25.4	23.4	16.5	9.5	3.0		
	10%	WB	-1.0	-0.5	2.1	8.3	15.5	19.7	21.2	20.6	18.5	12.1	6.2	0.7		
		MCDB	-0.2	0.7	3.9	12.3	19.6	23.6	25.1	24.3	21.6	14.1	7.6	1.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	9.1	8.6	9.8	10.9	10.5	10.3	10.5	10.6	8.9	7.3	7.2		
		MCDBR	9.0	7.9	10.1	15.3	14.7	13.1	12.0	11.9	12.6	12.5	10.7	7.2		
		MCWBR	8.8	7.4	7.4	9.5	8.2	7.1	6.5	6.3	7.3	8.3	8.9	6.7		
		MCDBR	8.8	7.8	9.3	13.3	12.0	11.1	10.7	10.4	11.4	11.3	10.2	7.2		
	5% WB	MCWBR	8.7	7.5	7.3	9.2	7.8	6.8	6.4	6.1	7.1	8.2	9.0	6.9		
(40) Clear-Sky Solar Irradiance	taub		0.255	0.285	0.329	0.354	0.382	0.435	0.420	0.407	0.368	0.335	0.303	0.283		
	taud		2.348	2.253	2.264	2.378	2.361	2.216	2.265	2.299	2.399	2.497	2.495	2.329		
	Ebn at Noon		865	893	897	905	886	836	844	841	848	833	801	777		
	Edh at Noon		74	100	115	113	119	139	130	121	101	79	66	69		
(44) All-Sky Solar Radiation	RadAvg		1.41	2.38	3.67	4.45	5.14	5.63	5.67	5.00	3.93	2.29	1.38	1.00		
	RadStd		0.17	0.25	0.32	0.47	0.50	0.42	0.46	0.23	0.32	0.20	0.17	0.08		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page