

OTTAWA INTL, ON, Canada

WMO: 716280

Lat: 45.3171N

Lon: 75.6739W

Elev: 377

StdP: 14.50

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-6.5	-22.8	1.6	-9.9	-17.6	2.1	-5.7	26.9	20.3	24.1	16.2	8.3	290	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	87.5	71.6	84.5	69.7	81.6	68.4	74.3	83.4	72.4	80.7	70.7	78.4	10.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.4	117.6	79.2	69.7	110.6	76.9	67.9	104.1	75.1	38.1	83.6	36.3	80.9	34.8	78.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	20.2	18.1	-16.6	92.4	5.2	3.2	-20.4	94.7	-23.5	96.6	-26.4	98.4	-30.2	100.8
			-17.2	77.8	5.2	2.1	-20.9	79.3	-23.9	80.5	-26.8	81.7	-30.6	83.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.3	14.4	17.8	28.3	42.9	56.5	65.8	70.1	68.3	60.5	47.7	35.1	22.4
	DBStd	21.42	12.87	10.94	10.69	8.82	7.96	6.78	5.19	5.33	7.37	8.11	9.24	11.20
	HDD50	4406	1103	900	675	246	27	0	0	0	5	143	453	854
	HDD65	8012	1568	1320	1138	665	282	71	12	28	173	538	898	1319
	CDD50	2325	0	0	2	32	230	474	624	566	321	72	4	0
	CDD65	457	0	0	0	1	20	95	172	129	39	1	0	0
	CDH74	3596	0	0	1	19	230	784	1347	901	303	11	0	0
	CDH80	965	0	0	0	3	54	220	391	228	69	0	0	0
	WSAvg	8.5	9.5	9.4	9.6	9.9	8.6	7.5	7.1	6.8	7.2	8.4	8.9	9.1
	PrecAvg	37.0	2.8	2.1	2.4	3.0	3.7	3.5	3.3	3.6	3.4	2.9	3.1	3.1
(15) Precipitation	PrecMax	46.5	4.9	4.1	5.0	6.1	5.0	7.6	7.7	6.4	6.3	7.2	4.4	5.4
	PrecMin	31.2	1.2	0.9	0.9	0.6	1.1	0.7	0.7	1.5	1.7	0.9	0.9	1.0
	PrecStd	3.7	1.0	0.8	1.1	1.3	1.1	1.5	1.7	0.9	1.3	1.3	0.9	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	47.5	44.9	62.8	76.8	85.5	90.1	91.9	90.4	86.6	75.3	62.3	51.1	48.7
	0.4% MCWB	46.2	40.8	54.4	61.1	68.3	73.0	74.7	72.3	71.1	63.6	55.0	48.1	46.1
	2% DB	40.5	40.1	52.8	68.5	80.2	85.8	87.5	85.5	81.4	69.5	57.5	44.6	42.1
	2% MCWB	38.3	36.3	45.3	54.3	64.2	70.3	72.0	70.4	69.3	60.4	52.8	42.4	40.4
	5% DB	36.3	36.8	46.8	62.3	75.5	82.0	84.4	82.1	77.2	64.7	52.5	39.6	37.4
	5% MCWB	34.3	33.8	40.6	51.0	61.0	67.9	70.1	69.0	66.6	57.3	47.6	37.4	35.4
	10% DB	32.8	33.9	42.1	57.3	71.1	78.5	81.3	79.1	73.4	60.2	48.0	36.4	34.4
	10% MCWB	31.3	31.6	36.9	47.2	58.9	66.2	68.6	67.6	64.8	54.4	43.7	34.3	32.3
	0.4% WB	46.7	42.1	55.1	63.0	71.4	75.7	77.8	75.6	73.9	66.4	57.4	48.7	46.7
	0.4% MCDB	47.4	43.9	61.9	73.2	81.9	86.7	88.5	86.1	81.7	72.1	60.5	50.4	48.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	38.6	36.8	46.3	57.3	67.1	72.9	74.8	72.8	71.0	61.7	53.2	42.5	40.5
	2% MCDB	40.0	39.4	51.8	64.4	76.4	82.1	83.4	81.2	78.4	67.6	57.1	44.6	42.6
	5% WB	34.5	34.2	41.0	52.1	63.8	70.4	72.6	71.2	68.4	58.3	48.4	37.9	35.9
	5% MCDB	36.1	36.4	45.4	59.8	71.4	78.6	80.7	78.7	75.3	63.5	51.7	39.5	37.5
	10% WB	31.4	31.8	37.5	48.5	60.7	68.1	70.6	69.3	65.9	55.2	44.4	34.5	32.5
	10% MCDB	32.9	33.9	41.6	56.2	68.6	75.5	78.4	75.9	72.0	59.6	47.5	36.1	34.1
(35) Mean Daily Temperature Range	MDBR	14.7	15.6	15.5	17.9	19.4	18.6	18.8	18.5	18.6	15.4	13.3	12.4	12.4
	5% DB MCDBR	17.6	16.3	20.7	27.4	26.5	23.6	22.8	22.3	23.0	21.9	19.9	14.5	14.5
	5% DB MCWBR	17.1	14.8	14.7	16.6	14.0	11.7	10.9	10.5	12.3	14.0	16.0	13.5	13.5
	5% WB MCDBR	17.1	15.8	19.8	23.8	22.0	20.0	19.7	18.8	20.7	19.7	19.0	14.6	14.6
	5% WB MCWBR	16.9	15.0	15.7	16.8	13.9	11.4	11.0	10.3	12.5	14.0	16.4	13.9	13.9
(40) Clear-Sky Solar Irradiance	taub	0.263	0.287	0.322	0.344	0.380	0.413	0.417	0.400	0.368	0.338	0.308	0.278	0.278
	taud	2.385	2.312	2.362	2.416	2.353	2.273	2.264	2.320	2.400	2.481	2.497	2.403	2.403
	Ebn at Noon	273	285	289	291	282	272	269	269	269	263	254	253	253
	Edh at Noon	23	30	33	35	38	42	42	38	32	26	21	21	21
(44) All-Sky Solar Radiation	RadAvg	440	746	1164	1420	1649	1792	1822	1606	1259	742	455	323	323
	RadStd	51	72	99	146	162	139	151	76	105	67	52	29	29

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page